Mr. Harold W. Keiser Chief Nuclear Officer & President -Nuclear Business Unit Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION, ISSUANCE OF AMENDMENT, RE: CORRECTION OF TYPOGRAPHICAL AND EDITORIAL ERRORS (TAC NO. MA5540)

Dear Mr. Keiser:

The Commission has issued the enclosed Amendment No. ¹²³ to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 24, 1999, as supplemented June 21, 1999.

This amendment revises the TSs to correct typographical and editorial errors, and is considered administrative in nature.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

ORIGINAL SIGNED BY:

Richard B. Ennis, Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. Amendment No. ¹²³ to License No. NPF-57 2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

<u>AAC</u>

PDR

9909300194 990921

ADDCK 05000354

PDR

Docket FileJCliffordPUBLICREnnisPDI-2 ReadingTClarkEAdensam (EGA1)LBerry

ord OGC his ACRS rk WBeckner RScholl (E-mail SE) GHill(2) GMeyer, RGN-I

OFFICE	PDI-2/PM	PDI-2/LA	ogc A	PDI-2/SC
NAME	REnnis:	TClark	Mappio	JC
DATE	9/10/99	9110199	91/5/99	9 128, 199

OFFICIAL RECORD COPY DOCUMENT NAME: G:\PDI-2\Hope Creek\amda5540.wpd



)()



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 21, 1999

Mr. Harold W. Keiser Chief Nuclear Officer & President -Nuclear Business Unit Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION, ISSUANCE OF AMENDMENT, RE: CORRECTION OF TYPOGRAPHICAL AND EDITORIAL ERRORS (TAC NO. MA5540)

Dear Mr. Keiser:

The Commission has issued the enclosed Amendment No. 123 to Facility Operating License No. NPF-57 for the Hope Creek Generating Station. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 24, 1999, as supplemented June 21, 1999.

This amendment revises the TSs to correct typographical and editorial errors, and is considered administrative in nature.

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

- nut

Richard B. Ennis, Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosures: 1. Amendment No. 123 to License No. NPF-57 2. Safety Evaluation

cc w/encls: See next page

Hope Creek Generating Station

cc:

Jeffrie J. Keenan, Esquire Nuclear Business Unit - N21 P.O. Box 236 Hancocks Bridge, NJ 08038

Hope Creek Resident Inspector U.S. Nuclear Regulatory Commission Drawer 0509 Hancocks Bridge, NJ 08038

Mr. Louis Storz Sr. Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

General Manager - Hope Creek Operations Hope Creek Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Director - Licensing Regulation & Fuels Nuclear Business Unit - N21 P.O. Box 236 Hancocks Bridge, NJ 08038

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Dr. Jill Lipoti, Asst. Director Radiation Protection Programs NJ Department of Environmental Protection and Energy CN 415 Trenton, NJ 08625-0415 Manager - Joint Generation Atlantic Energy 6801 Black Horse Pike Egg Harbor Twp., NJ 08234-4130

Richard Hartung Electric Service Evaluation Board of Regulatory Commissioners 2 Gateway Center, Tenth Floor Newark, NJ 07102

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Mr. Elbert Simpson Senior Vice President-Nuclear Engineering Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-354

HOPE CREEK GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123 License No. NPF-57

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company (PSE&G) dated May 24, 1999, as supplemented June 21, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-57 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into the license. PSE&G shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance, and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

James W. Clifad

James W. Clifford, Chief, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: September 21, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 123

FACILITY OPERATING LICENSE NO. NPF-57

DOCKET NO. 50-354

Replace the following pages of the Appendix "A" Technical Specifications with the attached revised pages. The revised pages are identified by Amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
iv	iv
vi	vi
vii	vii
x	х
xiii	xiii
xiv	xiv
xviii	xviii
xix	xix

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

SECTI	ION		PAGE
2.1	SAFETY LIMITS		
	THERMAL POWER, Low	Pressure or Low Flow	2-1
	THERMAL POWER, High	Pressure and High Flow	2-1
	Reactor Coolant Sys	tem Pressure	2-1
	Reactor Vessel Wate	r Level	2-2
2.2	LIMITING SAFETY SYS	TEM SETTINGS	
	Reactor Protection	System Instrumentation Setpoints	2-3
	Table 2.2.1-1	Reactor Protection System Instrumentation Setpoints	2-4

BASES

2.1 SAFETY LIMITS

	THERMAL POWER, Low Pressure or Low Flow	B 2-1
	THERMAL POWER, High Pressure and High Flow	B 2-2
·	Table B2.1.2-1Uncertainties Used in the Determination of the Fuel Cladding Safety Limit	B 2-3
	Reactor Coolant System Pressure	B 2-5
	Reactor Vessel Water Level	B 2-5
2.2	LIMITING SAFETY SYSTEM SETTINGS	
	Reactor Protection System Instrumentation Setpoints	B 2-6

.

LIMITING	CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS	
SECTION		PAGE
3/4 2.2	APRM SETPOINTS	3/4 2-2
3/4.2.3	MINIMUM CRITICAL POWER RATIO	3/4 2-3
3/4.2.4	LINEAR HEAT GENERATION RATE	3/4 2-5
<u>3/4.3 I</u>	NSTRUMENTATION	
3/4.3.1	REACTOR PROTECTION SYSTEM INSTRUMENTATION	3/4 3-1
	Table 3.3.1-1 Reactor Protection System Instrumentation	3/4 3-2
	Figure 4.3.1.1-1 Reactor Protection System Surveillance Requirements	3/4 3-7
3/4.3.2	ISOLATION ACTUATION INSTRUMENTATION	3/4 3-9
	Table 3.3.2-1 Isolation Actuation Instrumentation	3/4 3-11
	Table 3.3.2-2 Isolation Actuation InstrumentationSetpoints	3/4 3-22
	Table 4.3.2.1-1 Isolation Actuation InstrumentationSurveillance Requirements	3/4 3-28

I

LIMITING	CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS	
SECTION		PAGE
3/4.3.3	EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION	3/4 3-32
	Table 3.3.3-1 Emergency Core Cooling System Actuation Instrumentation	3/4 3-33
	Table 3.3.3-2 Emergency Core Cooling System Actuation Instrumentation Setpoints	3/4 3-36
	Table 4.3.3.1-1 Emergency Core Cooling System ActuationInstrumentation SurveillanceRequirements	3/4 3-39
3/4.3.4	RECIRCULATION PUMP TRIP ACTUATION INSTRUMENTATION	
	ATWS Recirculation Pump Trip System Instrumentation	3/4 3-41
	Table 3.3.4.1-1 ATWS Recirculation Pump Trip SystemInstrumentation	3/4 3-42
	Table 3.3.4.1-2 ATWS Recirculation Pump Trip SystemInstrumentation Setpoints	3/4 3-43
	Table 4.3.4.1-1 ATWS Recirculation Pump Trip ActuationInstrumentation SurveillanceRequirements	3/4 3-44
	End-of-Cycle Recirculation Pump Trip System Instrumentation	3/4 3-45
	Table 3.3.4.2-1 End-of-Cycle Recirculation Pump TripSystem Instrumentation	3/4 3-47
	Table 3.3.4.2-2 End-of-Cycle Recirculation Pump TripSetpoints	3/4 3-48
	Table 3.3.4.2-3 End-of-Cycle Recirculation Pump TripSystem Response Time	3/4 3-49
	Table 4.3.4.2.1-1 End-of-Cycle Recirculation Pump Trip System Surveillance Requirements	3/4 3-50
3/4.5.5	REACTOR CORE ISOLATION COOLING SYSTEM ACTUATION	3/4 3-51

I

LIMITING CON	IDITIONS FOR OPP	ERATION AND SURVEILLANCE REQUIREMENTS		
SECTION			PAGI	3
Ta	uble 3.3.9-2 Fee	edwater/Main Turbine Trip System	- 1.	
	Act	cuation Instrumentation Setpoints	3/4	3-107
Па		Productor Main Turking This Custor		
Ta	IDIE 4.3.9.1-1 1	reedwater/Main Turbine Trip System		
	I I I I I I I I I I I I I I I I I I I	Actuation instrumentation Surveillance	2/4	2 1 0 0
	1		3/4	3-108
3/4.4 REAC	TOR COOLANT SYS	STEM		
<u></u>				
3/4.4.1 RE	CIRCULATION SYS	STEM		
Re	circulation Loc	pps	3/4	4-1
	, ,			
	Figure 3.4.1.1-	1 % Rated Thermal Power Versus		
		Core Flow	3/4	4-3
Je	t Pumps	• • • • • • • • • • • • • • • • • • • •	3/4	4-4
Re	circulation Loc	pp Flow	3/4	4-5
Id	le Recirculatio	on Loop Startup	3/4	4-6
3/4.4.2 SA	FETY/RELIEF VAL	JVES		
62	fety/Pelief Val	wag	2/1	4 7
ac Sa	fety/Relief Val	wes Low-Low Set Function	3/4	4-7
54	iecy/keiler val		5/4	4-9
3/4 4.3 RE	ACTOR COOLANT S	SYSTEM LEAKAGE		
,				
Le	akage Detection	1 Systems	3/4	4-10
Op	erational Leaka	.ge	3/4	4-11
Т	able 3.4.3.2-1	Reactor Coolant System Pressure		
		Isolation Valves	3/4	4-13
Т	able 3.4.3.2-2	Reactor Coolant System Interface	- • ·	
		Valves Leakage Pressure Monitors	3/4	4-14
			2/4	4 15
3/4.4.4 CH	EMISIRI		3/4	4-15
т	able 3.4 4-1	Reactor Coolant System Chemistry		
1		Limits	3/4	4-17
			5/4	/
3/4.4.5 SP	ECIFIC ACTIVITY		3/4	4-18
.,		· · · · · · · · · · · · · · · · · · ·	-/ -	
т	able 4.4.5-1	Primary Coolant Specific Activity Sample	2	
		and Analysis Program	3/4	4-20

LIMITING	CONDITIONS FOR OPERATION AND SORVEILLANCE REQUIREMENTS	
SECTION		PAGE
3/4.7.3	FLOOD PROTECTION	3/4 7-9
	Table 3.7.3-1 Perimeter Flood Doors	3/4 7-10
3/4.7.4	REACTOR CORE ISOLATION COOLING SYSTEM	3/4 7-11
3/4.7.5	SNUBBERS	3/4 7-13
	Table 4.7.5-1 Snubber Visual Inspection Interval	3/4 7-17a
	Figure 4.7.5-1 Sample Fian 27 for Shubber Functional Test	3/4 7-18
3/4.7.6	SEALED SOURCE CONTAMINATION	3/4 7-19
3/4.7.7	MAIN TURBINE BYPASS SYSTEM	3/4 7-21
<u>3/4.8 E</u>	LECTRICAL POWER SYSTEMS	
3/4.8.1	A.C. SOURCES	
	A.C. Sources-Operating	3/4 8-1
	Table 4.8.1.1.2-1 Diesel Generator Test Schedule	3/4 8-10
	A.C. Sources-Shutdown	3/4 8-11
3/4.8.2	D.C. SOURCES	
	D.C. Sources-Operating	3/4 8-12
	Table 4.8.2.1-1 Battery Surveillance Requirements	3/4 8-15
	D.C. Sources-Shutdown	3/4 8-17
3/4.8.3	ONSITE POWER DISTRIBUTION SYSTEMS	
• ·	Distribution - Operating	3/4 8-18
	Distribution - Shutdown	3/4 8-21
3/4.8.4	ELECTRICAL EQUIPMENT PROTECTIVE DEVICES	
•	Primary Containment Penetration Conductor Overcurrent Protective Devices	3/4 8-24
	Table 3.8.4.1-1 Primary Containment Penetration Condu Overcurrent Protective Devices	actor 3/4 8-26
	Motor Operated Valve Thermal Overload Protection	_ /
	(Bypassed)	3/4 8-30

IMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

Amendment No. 123

LIMITING	CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS	
SECTION		PAGE
	Motor Operated Valve Thermal Overload Protection (Not Bypassed)	3/4 8-38
	Table 3.8.4.3-1 Motor Operated Valves-Thermal Overload Protection (Not Bypassed)	3/4 8-39
	Reactor Protection System Electric Power Monitoring	3/4 8-40
	Devices (Breaker Tripped by LOCA Signal)	3/4 8-41
	Table 3.8.4.5-1 Class 1E Isolation Breaker Overcurrent Protective Devices (Breaker Tripped by a LOCA Signal)	3/4 8-42
	Power Range Neutron Monitoring System Electric Power Monitoring	3/4 8-44
<u>3/4.9 Re</u>	FUELING OPERATIONS	
3/4.9.1	REACTOR MODE SWITCH	3/4 9-1
3/4.9.2	INSTRUMENTATION	3/4 9-3
3/4.9.3	CONTROL ROD POSITION	3/4 9-5
3/4.9.4	DECAY TIME	3/4 9-6
3/4.9.5	COMMUNICATIONS	3/4 9-7
3/4.9.6	REFUELING PLATFORM	3/4 9-8
3/4.9.7	CRANE TRAVEL - SPENT FUEL STORAGE POOL	3/4 9-10
3/4.9.8	WATER LEVEL - REACTOR VESSEL	3/4 9-11
3/4.9.9	WATER LEVEL - SPENT FUEL STORAGE POOL	3/4 9-12
3/4.9.10	CONTROL ROD REMOVAL	
	Single Control Rod Removal	3/4 9-13
	Multiple Control Rod Removal	3/4 9-15

SECTION			AGE	
INSTRUMENTATION (Continued)				
	Remote Shutdown and Controls Accident Monitor Source Range Mon Traversing In-Co	Monitoring Instrumentation ing InstrumentationE itorsE re Probe SystemE	3/4 3/4 3/4 3/4	3-5 3-5 3-5 3-5
3/4.3.8	DELETED	E	3/4	3-7
3/4.3.9	FEEDWATER/MAIN T INSTRUMENTATION	URBINE TRIP SYSTEM ACTUATION	3/4	3-7
	Figure B3/4 3-1	Reactor Vessel Water LevelE	3/4	3-8
3/4.4 RE	ACTOR COOLANT SYS	STEM		
3/4.4.1	RECIRCULATION SY	STEM	3/4	4-1
3/4.4.2	SAFETY/RELIEF VA	LVESB	3/4	4-2
3/4.4.3	REACTOR COOLANT	SYSTEM LEAKAGE		
	Leakage Detectio Operational Leak	n SystemsB ageB	3/4 3/4	4-3 4-3
3/4.4.4	CHEMISTRY	B	3/4	4-3
3/4.4.5	SPECIFIC ACTIVIT	Үв	3/4	4-4
3/4.4.6	PRESSURE/TEMPERA	TURE LIMITSB	3/4	4-5
Table	B3/4.4.6-1 Reacto	or Vessel ToughnessB	3/4	4-7
Figure	B3/4.4.6-1	Fast Neutron Fluence (E>1Mev) at (1/4)T as a Function of Service lifeB	3/4	4-8

BASES

.

.

.

BASES	3			. <u> </u>
SECT	ION		PAGE	
	3/4.4.7	MAIN STEAM LINE ISOLATION VALVES	B 3/4	4-6
	3/4.4.8	STRUCTURAL INTEGRITY	B 3/4	4-6
	3/4.4.9	RESIDUAL HEAT REMOVAL	B 3/4	4-6
3/4.9	5 EMERGENCY	CORE COOLING SYSTEMS		
	3/4.5.1/2	ECCS - OPERATING and SHUTDOWN	B 3/4	5-1
	3/4.5.3	SUPPRESSION CHAMBER	B 3/4	5-3
3/4.0	5 CONTAINMEN	I SYSTEMS		
	3/4.6.1	PRIMARY CONTAINMENT		
		Primary Containment Integrity	B 3/4	6-1
		Primary Containment Leakage	B 3/4	6-1
		Primary Containment Air Locks	B 3/4	6-1
		MSIV Sealing System	B 3/4	6-1
		Primary Containment Structural Integrity	B 3/4	6-2
		Drywell and Suppression Chamber Internal Pressure	B 3/4	6-2
		Drywell Average Air Temperature	B 3/4	6-2
		Drywell and Suppression Chamber Purge System	B 3/4	6-2
	3/4.6.2	DEPRESSURIZATION SYSTEMS	B 3/4	6-3
	3/4.6.3	PRIMARY CONTAINMENT ISOLATION VALVES	B 3/4	6-5
	3/4.6.4	VACUUM RELIEF	B 3/4	6-5
	3/4.6.5	SECONDARY CONTAINMENT	в 3/4	6-5
	3/4.6.6	PRIMARY CONTAINMENT ATMOSPHERE CONTROL	B 3/4	6-6



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 123 TO FACILITY OPERATING LICENSE NO. NPF-57

PUBLIC SERVICE ELECTRIC & GAS COMPANY

ATLANTIC CITY ELECTRIC COMPANY

HOPE CREEK GENERATING STATION

DOCKET NO. 50-354

1.0 INTRODUCTION

By letter dated May 24, 1999, as supplemented June 21, 1999, the Public Service Electric & Gas Company (the licensee) submitted a request for changes to the Hope Creek Generating Station (HCGS) Technical Specifications (TSs). The proposed amendment would revise the TSs to correct typographical and editorial errors, and is considered administrative in nature. The June 21, 1999, letter provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the scope of the original <u>Federal Register</u> Notice.

2.0 BACKGROUND

The licensee's submittal proposed to make the following changes to the TSs:

- (1) revise TS Index pages iv, vi, vii and xiv to delete references to TS tables that were removed from the TSs in previous amendments;
- (2) revise TS Index pages vi, ix and x to correct TS table number references to reflect the actual table numbers within the TSs;
- (3) revise TS Index pages xiii, xviii and xix to correct TS page number references to reflect the actual page numbers within the TSs; and
- (4) revise TS Table 4.11.1.1-1 to correct the abbreviation for the Station Service Water System from "GSW" to "SSWS" and to delete a reference to a note that does not exist.

The licensee's submittal states that the proposed TS changes are considered to be administrative in nature and do not alter the manner in which any structure, system, or component is operated, tested, or maintained. In addition, the proposed TS changes do not represent changes to any licensing or design basis assumptions, analyses, or commitments.

.....

3.0 EVALUATION

The staff evaluated each of the proposed TS changes as described below.

3.1 TS Index Page iv

On TS Index page iv, the licensee has proposed to delete the reference to Table B2.1.2-2, "Nominal Values of Parameters Used in the Statistical Analysis of Fuel Cladding Integrity Safety Limit." This table was deleted in Amendment No. 42. Therefore, the proposed change is acceptable.

3.2 TS Index Pages vi and vii

On TS Index page vi, the licensee has proposed to delete the reference to Table 3.3.1-2, "Reactor Protection System Response Times," and Table 3.3.2-3, "Isolation System Response Times." On TS Index page vii, the licensee has proposed to delete the reference to Table 3.3.3-3, "Emergency Core Cooling System Response Times." These three tables were deleted in Amendment No. 85. Therefore, the proposed changes are acceptable.

Also, on TS Index page vi, the licensee has proposed to change the reference to Table 3.3.2-1, for "Isolation Actuation Instrumentation Setpoints," to Table 3.3.2-2. This is consistent with the actual table number as currently shown on TS page 3/4 3-22. Therefore, the proposed change is acceptable.

3.3 TS Index Page ix

On TS Index page ix, the licensee has proposed to correct TS table number references to reflect the actual table numbers within the TSs as follows:

- (1) The reference to Table 3.3.7.9-1, for "Radioactive Liquid Effluent Monitoring Instrumentation," would be changed to Table 3.3.7.10-1.
- (2) The reference to Table 4.3.7.9-1, for "Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements," would be changed to Table 4.3.7.10-1.
- (3) The reference to Table 3.3.7.10-1, for "Radioactive Gaseous Effluent Monitoring Instrumentation," would be changed to Table 3.3.7.11-1.
- (4) The reference to Table 4.3.7.10-1, for "Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements," would be changed to Table 4.3.7.11-1.

The proposed changes to TS Index page ix as described above are no longer necessary since Tables 3.3.7.10-1, 4.3.7.10-1, 3.3.7.11-1 and 4.3.7.11-1 (as well as the references to these tables on the TS Index page ix) were deleted in Amendment No. 121.

3.4 TS Index Page x

On TS Index page x, the licensee has proposed to change the reference to Table 3.4.3.1-1, for "Reactor Coolant System Pressure Isolation Valves," to Table 3.4.3.2-1. This is consistent with the actual table number as currently shown on TS page 3/4 4-13. Therefore, the proposed change is acceptable.

3.5 TS Index Page xiii

On TS Index page xiii, the licensee has proposed to correct the TS page number reference for Table 4.8.2.1-1 from page 3/4 8-16 to 3/4 8/15. This is consistent with the actual page number as currently shown for Table 4.8.2.1-1. Therefore, the proposed change is acceptable.

3.6 TS Index Page xiv

On TS Index page xiv, the licensee has proposed to delete the reference to Table 3.8.4.2-1, "Motor Operated Valves - Thermal Overload Protection (Bypassed)." This table was deleted in Amendment No. 103. Therefore, the proposed change is acceptable.

3.7 TS Index Page xviii

On TS Index page xviii, the licensee has proposed to correct the TS page number reference for the Bases for TS 3/4.4.2 from page B 3/4 4-1a to B 3/4 4-2. This is consistent with the actual page number as currently shown for the Bases for TS 3/4.4.2. Therefore, the proposed change is acceptable.

3.8 TS Index Page xix

On TS Index page xix, the licensee has proposed to correct the TS page number reference for the Bases for TS 3/4.5.3 from page B 3/4 5-2 to B 3/4 5-3. This is consistent with the actual page number as currently shown for the Bases for TS 3/4.5.3. Therefore, the proposed change is acceptable.

3.9 TS Page 3/4 11-2

On TS page 3/4 11-2, the licensee has proposed to revise Table 4.11.1.1.1-1 to correct the abbreviation for the Station Service Water System from "GSW" to "SSWS" and to delete a reference to a note that does not exist. The proposed changes to TS page 3/4 11-2 are no longer necessary since Table 4.11.1.1.1-1 was deleted in Amendment No. 121.

3.10 Summary

The proposed changes to TS Index pages iv, vi, vii, x, xiii, xiv, xviii, and xix were determined by the staff to be administrative in nature and are acceptable. The proposed changes to TS Index page ix and TS page 3/4 11-2 are no longer necessary due to changes made in Amendment No. 121.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New Jersey State Official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

Pursuant to 10 CFR 51.21, 51.32, and 51.35, an environmental assessment and finding of no significant impact has been prepared and published in the <u>Federal Register</u> on July 16,1999 (64 FR 38485). Accordingly, based on the environmental assessment, the staff has determined that the issuance of the amendment will not have a significant effect on the quality of the human environment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: R. Ennis

Date: September 21, 1999