



Entergy Nuclear Southwest
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751
Tel 504 739 6475
Fax 504 739 6698
aharris@entergy.com

Alan J. Harris
Director, Nuclear Safety Assurance
Waterford 3

W3F1-2001-0062
A4.05
PR

June 20, 2001

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Emergency Plan Implementing Procedure

Gentlemen:

In accordance with Appendix E of 10CFR50 and 10CFR50.4(b)(5), Entergy is submitting a changed Waterford 3 Emergency Plan Implementing Procedure. This change was reviewed in accordance with 10CFR50.54(q) requirements and was determined not to decrease the effectiveness of the emergency plan.

This letter does not contain any commitments.

Included in this submittal is the following procedure:

1. EP-003-070 (Revision 20, Change 1), Emergency Communications Systems Routine Testing. The change eliminates the guidance concerning not dialing a "1" when using the NRC Emergency Notification System telephone. This is required because the circuit is changed and the dialing protocol is different.


Please note that Revision 20, Change 1 only includes the revised pages and not the entire procedure. Please replace these effective pages with the pages in your Revision 20 copy.

A045

Emergency Plan Implementing Procedure
W3F1-2001-0062
Page 2
June 20, 2001

Should you have any questions concerning this procedure, please contact
Mr. J.J. Lewis, Emergency Planning Manager, at (504) 739-6624.

Very truly yours,



for
A.J. Harris
Director,
Nuclear Safety Assurance

AJH/DCM/ssf
Enclosure 1

cc: (w/Enclosure 1)
E.W. Merschoff, NRC Region IV (2 copies)

(w/o Enclosure 1)
N. Kalyanam (NRC-NRR), W.A. Maier (NRC Region IV), J. Smith,
N.S. Reynolds, NRC Resident Inspectors Office

**ENCLOSURE 1 TO
W3F1-2001-0062**

**EP-003-070, Revision 20, Change 1
(Emergency Communications Systems Routine Testing)**

SAFETY RELATED

Required Review Level (check one)



PORC



QUALIFIED REVIEWER

PROCEDURE NUMBER: EP-003-070 REVISION: 20 CHANGE: 1 DEVIATION 0

TITLE: Emergency Communications Systems Routine Testing

EFFECTIVE DATE/MILESTONE: N/A

(N/A If Same as Approval Date)

PROCEDURE OWNER: Emergency Planning Manager

(Position Title)

PREPARER (Print Name / Initial): J.J. Lewis / *[Signature]* DATE: 6-5-01

ACTION:

☐ New Procedure☐ Deletion☐ Revision

Change

EC? ☐

(Applicable W2.109 Step Numbers)



Deviation

Expiration Date/Milestone:



Temporary Procedure

Applicable Conditions:

DESCRIPTION AND JUSTIFICATION OF CHANGE: Change step 5.5.2.2 to eliminate the statement concerning not dialing a "1" to contact the NRC on a long distance number because the NRC system has changed to a regular long distance system that will now require the "1" to be dialed.

☐ Request/Approval Page Continuation Sheet(s) attached.

EC SUPERVISOR

APPROVAL:

N/A

DATE:

N/A

50.59 REVIEWER

Required? ☐

REVIEW:

Michael S. Huskey

DATE:

6-11-01

☐ PROGRAMMATICALLY EXCLUDED

PORC Mtg. No.:

N/A

DATE:

N/A

50.54 REVIEWER

Required? ☐

REVIEW:

Michael S. Huskey

DATE:

6-11-01

TECHNICAL REVIEWER

REVIEW:

Michael S. Huskey

DATE:

6-11-01

Change Notice (CN)? ☐

CHANGE NOTICE (CN) SUPERVISOR

APPROVAL:

N/A

DATE:

N/A

CHANGE NOTICE (CN) ON-SHIFT SM/CRS

APPROVAL:

N/A

DATE:

N/A

2 Week Final Approval DATE: N/A

QUALIFIED REVIEWER

Required? ☒

REVIEW:

G. S. [Signature]

DATE:

6/11/01

GROUP/DEPT. HEAD

REVIEW ☐ or APPROVAL ☒*Ronald J. Perry*

DATE:

6/11/01

GM, PLANT OPERATIONS

REVIEW ☐ or APPROVAL ☐

N/A

DATE:

N/A

VICE PRESIDENT, OPERATIONS

APPROVAL:

N/A

DATE:

N/A

W2.109, Rev. 3

CONTROLLED

Attachment 7.1 (Page 1 of 3)

LIST OF EFFECTIVE PAGES

1-17	Revision 20
2, 12	Change 1
18-22	Revision 16

LIST OF PAGES CONTAINING PROPRIETARY INFORMATION
7, 8, 9, 15

5.5 NRC EMERGENCY NOTIFICATION SYSTEM (ENS)

5.5.1 Test the ENS once each calendar month.

5.5.2 Test the ENS extensions in the Control Room, TSC and EOF in accordance with the following steps.

5.5.2.1 Notify the SM that you are going to conduct a test of the ENS.

5.5.2.2 To initiate the test, pick up the receiver. Dial the NRC Operations Center phone number provided on the phone.

1

A. If the line is busy, then dial the next number on the list.

B. Continue down the list until you reach an open line.

5.5.2.3 When the NRC answers, then state: "This is the Waterford 3 SES in Region IV, (your name) speaking. I am performing a test of the ENS."

5.5.2.4 Give the NRC Operations Center Duty Officer the ENS phone number you are calling from and ask the Duty Officer to hang up and call you back to verify incoming operation.

5.5.2.5 If any extension of the ENS is inoperable, then immediately inform the SM.

A. Any inoperable ENS extension must be reported to the NRC Operations Center within 1 hour and an alternate commercial telephone extension must be provided when reporting the problem.

B. Initiate a Condition Report, if necessary.

5.5.2.6 When all extensions have been tested, inform the NRC and SM that the test is complete.

5.5.2.7 Log the results of the test on Attachment 7.1, Emergency Communications Test Sheet.