

REPORT: P187R40

DOCUMENTATION MANAGEMENT
DOCUMENT ON-LINE CONTROL SYSTEM
TRANSMITTAL / RECEIPT ACKNOWLEDGMENT

TRANSMITTAL NUMBER: 0106-01001
TRANSMITTAL DATE : 06/18/2001
TRANSMITTAL PAGE : 001

COPY NUMBER : 1665

TO: DOC. CONTROL DESK,

USNRC
DIVISION OF EMERGENCY
PREPARDNESS
WASHINGTON, D.C. 20555

AS THE HOLDER OF THESE DOCUMENT COPIES, YOU ARE RESPONSIBLE FOR THEIR CONTROL AND MAINTENANCE IN ACCORDANCE WITH THE ACTIONS SPECIFIED BY THIS TRANSMITTAL. DOCUMENTS WHICH ARE NO LONGER CURRENT SHALL EITHER BE REMOVED AND DESTROYED OR MARKED TO REFLECT THAT THEY ARE SUPERSEDED OR VOIDED AND ARE NO LONGER CONSIDERED CONTROLLED.

***** ENSURE THAT DOCUMENTS ARE FILED IN TAB ORDER AS IDENTIFIED ON THE TABLE OF CONTENTS, AS APPLICABLE *****

IF YOU HAVE ANY QUESTIONS, PLEASE CONTACT DOCUMENT CONTROL, DAVIS-BESSE NUCLEAR POWER STATION, TELEPHONE (419) 321-7483.

THE ATTACHED DOCUMENT COPIES ARE DISTRIBUTION ONLY. NO RECEIPT ACKNOWLEDGMENT IS REQUIRED.

4045

REPORT: P187R40

DOCUMENTATION MANAGEMENT
DOCUMENT ON-LINE CONTROL SYSTEM
TRANSMITTAL / RECEIPT ACKNOWLEDGMENT

TRANSMITTAL NUMBER: 0106-01001
TRANSMITTAL DATE : 06/18/2001
TRANSMITTAL PAGE : 002

COPY NUMBER : 1665

TYPE		DOCUMENT	SHT/SEC:		STATUS	
-----		-----	-----		-----	
TOC	EPIB		SHT/SEC:			
REMOVE:	TOC	EPIB	SHT/SEC:	REV/SUB: 0054	REVISED	
INSERT:	TOC	EPIB	SHT/SEC:	REV/SUB: 0055	APPROVED	
MANUAL: EPIB			SHT/SEC:			
PROC	RA-EP-02110		SHT/SEC:			
REMOVE:	PROC	RA-EP-02110	SHT/SEC:	REV/SUB: 0001	REVISED	
INSERT:	PROC	RA-EP-02110	SHT/SEC:	REV/SUB: 0002	APPROVED	

END OF TRANSMITTAL

MANUAL TABLE OF CONTENTS
 DB EMERGENCY PLAN IMPLEMENTING PROCEDURES VOL B
 MANUAL: EPIB REVISION: 55

PAGE NO. 1
 6/18/2001

TAB	PROCEDURE NUMBER	REV	ST	EFFECT DATE	ALTERATIONS	ALTERATION EFF DATE	TITLE
001	RA-EP-02010	02	CE	1/29/1999			EMERGENCY MANAGEMENT
002	RA-EP-02110	02	CE	6/18/2001			EMERGENCY NOTIFICATION
003	RA-EP-02220	01	CE	2/5/2001			EMERGENCY CONTROL CENTER ACTIVATION AND RESPONSE
004	HS-EP-02230	03	CE	2/24/1989	C 897261	1/8/1990	DOSE ASSESSMENT CENTER ACTIVATION AND RESPONSE
					C 922045	1/1/1993	
005	HS-EP-02240	04	CE	12/29/1993	C 940669	4/22/1994	OFFSITE DOSE ASSESSMENT
					C 000388	3/30/2000	
006	RA-EP-02245	00	CE	4/8/1997	C 972719	6/11/1998	PROTECTIVE ACTION GUIDELINES
007	RA-EP-02250	00	CE	4/6/2001			RADIATION MONITORING TEAM SURVEYS
008	RA-EP-02260	00	CE	4/6/2001			RADIOLOGICAL CONTROLS IN THE DBAB
009	RA-EP-02270	01	CE	6/10/1997			FACILITIES SUPPORT
010	RA-EP-02310	01	CE	5/7/2001			TSC ACTIVATION AND RESPONSE
011	RA-EP-02320	01	CE	7/28/1995	C 972100	11/6/1997	EMERGENCY TECHNICAL ASSESSMENT
					C 972879	1/30/1998	
					C 990015	1/22/1999	
					C 992329	4/4/2000	

Davis-Besse Nuclear Power Station

EMERGENCY PLAN IMPLEMENTING PROCEDURE

RA-EP-02110

(Supersedes RA-EP-02110, R1)

Emergency Notification

REVISION 02

Prepared by: Patricia J. Smith 4/30/01
Date

Sponsor: Dmit H. Rockwood 5-7-01
Manager - Regulatory Affairs Date

Approved by: B. Worley 5/30/01
Director - Support Services Date

Approved by: J. W. Byrnes 6/1/01
Plant Manager Date

Effective Date: 6/18/01

Procedure Classification:

X Safety Related
 Quality Related
 Non-Quality Related

TABLE OF CONTENTS

	<u>Page</u>
1.0 PURPOSE	4
2.0 REFERENCES	4
3.0 DEFINITIONS	4
4.0 RESPONSIBILITIES	5
5.0 INITIATING CONDITIONS	5
6.0 PROCEDURE	6
6.1 Notification of the Emergency Response Organization Using the Computerized Automated Notification System (CANS)	6
6.2 Notification of the State and Counties	8
6.3 Notification of the Emergency Response Organization through Manual Activation of the Group Page	9
6.4 Individual Contact of Emergency Responders	10
6.5 Notification of the NRC	11
7.0 FINAL CONDITIONS	11
8.0 RECORDS	12
ATTACHMENT 1. Emergency Position Checklist	13
COMMITMENTS	14

1.0 PURPOSE

To provide guidelines for notifying the Emergency Response Organization and offsite agencies in accordance with the Davis-Besse Nuclear Power Station Emergency Plan.

2.0 REFERENCES

2.1 Developmental

2.1.1 Davis-Besse Nuclear Power Station Emergency Plan

2.2 Implementation

2.2.1 DB-OP-00002, Operations Section Event/Incident Notifications and Actions

2.2.2 DBNPS Emergency Plan Telephone Directory

3.0 DEFINITIONS

3.1 COMPUTERIZED AUTOMATED NOTIFICATION SYSTEM (CANS) - A computer assisted system that has the following capabilities:

3.1.1 Contacting emergency response personnel through the use of pagers or the telephone system.

3.1.2 Accepting calls from authorized emergency responders.

3.1.3 Maintaining an updated list of Emergency Responders that have or have not responded.

3.2 EMERGENCY RESPONSE ORGANIZATION (ERO) - The organization formed and trained to respond to various emergencies according to requirements in the DBNPS Emergency Plan.

3.3 EMERGENCY RESPONSE ORGANIZATION ON CALL REPORT - A weekly report, which lists the schedules of On Call, On Coming and Standby ERO Responders.

3.4 INTEGRATED ON CALL REPORT - A weekly report which lists positions that have on call Plant Duty Responsibilities along with their On Call ERO Responsibilities.

3.5 ON CALL TEAM - Personnel in the ERO who are designated as the primary responders.

3.6 ON COMING TEAM - Personnel in the ERO who are designated as the first alternate to the On Call Team responders.

3.7 SCENARIO ACTIVATION PASSWORD - Numbers assigned to designated individuals used to gain access to CANS.

3.8 STANDBY TEAM - Personnel in the ERO who are designated as the second alternate to the On Call Team responders.

3.9 INITIAL NOTIFICATION FORM - The form used when notifying the State and Counties of an emergency at the Davis-Besse Nuclear Power Station. The Initial Notification is also used when changing either the level of classification or the protective action recommendations.

3.10 PERIODIC UPDATE FORM - The form used when updating the State and Counties of the status of an emergency at the Davis-Besse Nuclear Power Station.

4.0 RESPONSIBILITIES

4.1 The Emergency Director shall be responsible for ensuring that Emergency Response Organization notification and offsite notifications are performed in accordance with this procedure.

4.2 The Shift Manager or designated alternate shall be responsible for the activation of CANS upon declaration of an emergency or drill classification.

4.3 The Supervisor - Emergency Preparedness shall be responsible for:

4.3.1 Review of documentation created from this procedure.

4.3.2 The corrective actions of any deficiencies found with the equipment.

5.0 INITIATING CONDITIONS

5.1 This procedure shall be activated when any of the following have been declared:

5.1.1 Unusual Event

5.1.2 Alert

5.1.3 Site Area Emergency

5.1.4 General Emergency

6.0 PROCEDURENOTE 6.1

- The priority for performing notification is as follows, however, steps may be performed concurrently:
 1. Notification of ERO using CANS - Section 6.1.
 2. Notification of State and Counties - Section 6.2.
 3. Notification of ERO using Sections 6.3 and 6.4.
 4. Notification of NRC - Section 6.5.
- Initial notification of the State and Counties or a change in Protective Actions is required within 15 minutes of declaration of an emergency or change in classification.

6.1 Notification of the Emergency Response Organization Using the Computerized Automated Notification System (CANS)6.1.1 IF the individual activating CANS is not a(n):

- Shift Manager,
- Emergency Assistant Plant Manager,
- Unit Supervisor,
- Shift Engineer,
- Supervisor – Security Shift
- Alarm Station Operator
- Emergency Planning Advisor,
- Emergency Offsite Manager, or
- ECC Communications Equipment Operator

THEN obtain a scenario activation password from one of these personnel.

6.1.2 To activate CANS, the Shift Manager or designee shall:

NOTE 6.1.2.a

- After CANS has been activated for an Alert, Site Area Emergency, or a General Emergency, use the manual ERO group page to notify the ERO of a change in emergency classification. Step 6.3

- a. IF upgrading an emergency classification from an Unusual Event, THEN activate CANS. GOTO step 6.1.2.c.
- b. IF reclassifying a previously declared drill or emergency, THEN manually activate the ERO group page. GOTO Step 6.3.

- c. Obtain the Emergency or Drill Classification from the Emergency Director.
- d. Obtain the CANS access number from the Immediate Notification Numbers section of the Emergency Plan Telephone Directory.
- e. Dial the CANS number from a touch tone telephone line:
 - 1. IF you fail to contact CANS after two attempts,
THEN manually activate the ERO group page. GOTO Step 6.3.
- f. REFER TO the CANS Activation Flow Chart in the Immediate Notification Numbers section of the Emergency Plan Telephone Directory for activation.

NOTE 6.1.2.g

Within 10 minutes the pager located in the Control Room or CAS should activate with displays of the selected classification code.

- g. Wait for the Control Room or CAS pager to activate with the proper display:
 - 1. If the Control Room and the CAS pager fail to respond, then contact the On Call Emergency Offsite Manager. (See the Integrated On Call Report for number.)
 - 2. Upon contact inquire if their pager has received the proper Emergency or Drill Classification Code.
 - 3. IF CANS is not working,
THEN manually activate the ERO group page. GOTO Step 6.3.
- h. Review the CANS Fax to ensure the ERO positions are being filled.
 - 1. IF the positions are not being filled, THEN contact the On Call Emergency Offsite Manager (see the Integrated On Call Report for numbers).

6.2 Notification of the State and CountiesNOTE 6.2

Initial notification of the State and Counties or a change in Protective Actions is required within 15 minutes of the declaration of an emergency or a change in classification.

- 6.2.1 When making an initial notification, the Shift Manager or designee shall fill out an Initial Notification form (DBEP-010).

NOTE 6.2.2

Periodic updates are required as conditions change or hourly, as a minimum, unless the offsite agencies agree to forgo them.

- 6.2.2 When making a periodic update, fill out a Periodic Update form (DBEP-009).
- 6.2.3 Review and obtain the Emergency Director's approval on a Davis-Besse Emergency Notification Coversheet (DBEP-012).
- 6.2.4 Activate the Davis-Besse 4-Way Ringdown Circuit (4-Way). (Detailed instructions are contained in the Emergency Plan Telephone Directory).
- a. If the 4-way is not operable, then obtain telephone numbers for the offsite agencies in the Immediate Notification section of the Emergency Plan Telephone Directory. Contact should be established in the following order:
 1. Ottawa County
 2. Lucas County
 3. State of Ohio
- 6.2.5 As agencies answer, identify yourself by name and facility (Control Room, ECC) and record the following:
- a. The agency notified.
 - b. Time of contact.
 - c. If the 4-way was used when making the notification.
- 6.2.6 Transmit the information from the approved form. Do not give out any other information.

6.2.7 If any of the required three agencies did not answer the 4-way, then contact them using the Emergency Plan Telephone Directory.

- a. Be aware that offsite agencies should call back to verify the notification if a telephone other than the 4-way was used.

6.2.8 Telefax all completed forms to the Emergency Control Center.

6.3 Notification of the Emergency Response Organization through Manual Activation of the ERO Group Page

6.3.1 Manually activate the ERO group page by performing the following:

- a. Obtain the Emergency or Drill Classification from the Emergency Director.
- b. Obtain the following number from the Emergency Plan Telephone Directory, Immediate Notification section, Emergency Response Organization:

- 1. ERO Numeric group pager number

- c. Contact the pager system by dialing the ERO numeric group pager number.

- 1. If you fail to contact the group page a second time, proceed to Step 6.4.

- d. Enter the appropriate classification code:

1111 - UNUSUAL EVENT

2222 - ALERT

3333 - SITE AREA EMERGENCY

4444 - GENERAL EMERGENCY

0000 - ALL CLEAR

- e. Depress the pound key (#) after entering the code.
- f. Repeat Steps 6.3.1.b through 6.3.1.e to activate the group page a second time.

NOTE 6.3.1.g

Within 10 minutes the pager located in the Control Room or CAS should activate with displays of the selected classification code.

- g. Wait for the pager to sound with the proper display.
 - 1. If the Control Room and the CAS pager fail to respond, then contact the On Call Emergency Offsite Manager (see the Integrated On Call Report for numbers.)
 - 2. Inquire if their pager has received the proper classification code.
 - 3. If the Emergency Offsite Manager has not received the page, proceed to Step 6.4.

6.4 Individual Contact of Emergency Responders

- 6.4.1 If CANS and the pager system fail, then the Shift Manager or designee shall obtain the following:
 - a. Attachment 1, Emergency Position Checklist
 - b. The ERO On Call Report
 - c. The Emergency Plan Telephone Directory
- 6.4.2 Contact the positions listed on the Emergency Position Checklist using the On Call Report to determine who is on duty. The Emergency Plan Telephone Directory lists both telephone numbers and pager numbers for these individuals.

NOTE 6.4.3

It is important that calls be as short and concise as possible in order to expedite the notification process.

- 6.4.3 Upon making contact inform the individual of the following:
 - 1. Your name and title.
 - 2. Basis for your call (CANS and pagers failed to initiate emergency notifications).
 - 3. The classification.
- 6.4.4 Record time of contact on Attachment 1, Emergency Position Checklist.

6.5 Notification of the NRC

6.5.1 The Shift Manager or designee shall activate the NRC Resident Inspector's pager(s) with the Emergency Classification code as follows:

- a. Obtain the NRC Resident Inspector's pager number(s) from the Emergency Plan Telephone Directory, Immediate Notification section.
- b. Contact the pager system by dialing the pager number(s).
- c. Enter the appropriate classification code:

1111 - UNUSUAL EVENT

2222 - ALERT

3333 - SITE AREA EMERGENCY

4444 - GENERAL EMERGENCY

0000 - ALL CLEAR

- d. Repeat steps 6.5.1.a through 6.5.1.c to activate the page a second time.

6.5.2 Initial notification to the NRC should be made by the Control Room staff, unless directed otherwise by the Emergency Director.

6.5.3 Make initial notification to the NRC immediately after notification of the local and state agencies, but no later than one hour after any emergency declaration.

6.5.4 For all NRC notifications, fill out the Reactor Plant Event Notification Worksheet (DB-0095), in accordance with DB-OP-00002, Operations Section Event/Incident Notifications and Actions.

6.5.5 Activate the NRC Emergency Notification System (ENS) (red phone) to contact the NRC Operations Center in Bethesda, Maryland.

- a. If the ENS red phone is out of service, then use the Emergency Plan Telephone Directory, Immediate Notification section, for backup telephone numbers.

6.5.6 Transmit the information on the form.

6.5.7 Telefax all forms to the Emergency Control Center.

7.0 FINAL CONDITIONS

7.1 The required personnel have been notified in accordance with the appropriate Emergency or Drill Classification.

7.2 Any system malfunctions have been reported to the Supervisor - Emergency Preparedness.

8.0 RECORDS

- 8.1 The following quality assurance records are completed by this procedure and shall be listed on the Nuclear Records List, captured, and submitted to Nuclear Records Management in accordance with NG-NA-00106:

8.1.1 Davis-Besse Emergency Notification Coversheet (DBEP-012)

8.1.2 Initial Notification Form (DBEP-010)

8.1.3 Periodic Update Form (DBEP-009)

- 8.2 The following non-quality assurance records are completed by this procedure and may be captured and submitted to Nuclear Records Management, in accordance with NG-NA-00106:

8.2.1 Emergency Position Checklist

ATTACHMENT 1: EMERGENCY POSITION CHECKLIST

For ERO Status Update use, place an "X" in the "No" space provided if the computer names the position.
For individual contact use, log the time each notification or unsuccessful attempt is made.

	<u>Emergency Title</u>	<u>Emergency Facility</u>	<u>Person Notified?</u>		<u>Time Notified*</u>
			<u>Yes</u>	<u>No</u>	
1.	Emergency Director	ECC/TSC	_____	_____	_____
2.	Emergency Plant Manager	TSC	_____	_____	_____
3.	Emergency Offsite Manager	ECC	_____	_____	_____
4.	Emergency Assistant Plant Manager	CTRM	_____	_____	_____
5.	OSC Manager	OSC	_____	_____	_____
6.	Emergency Radiation Protection Manager	TSC	_____	_____	_____
7.	TSC Engineering Manager	TSC	_____	_____	_____
8.	NRC Liaison	ECC	_____	_____	_____
9.	JPIC Manager	JPIC	_____	_____	_____
10.	Core/Thermal Hydraulic Engineer	TSC	_____	_____	_____
11.	Emergency Planning Advisor	ECC	_____	_____	_____
12.	Dose Assessment Coordinator	ECC	_____	_____	_____

Performed by: _____ Date: _____

*Complete only if individual contact of the emergency responders is required.

<u>Section</u>	<u>Reference</u>	<u>Comments</u>
Note 6.2	TERMS O 13969 Q 00784	Capability to notify State and Local agencies within 15 minutes after declaring an emergency.
Section 6.2	TERMS O 13462	Initial notifications should address all items in NUREG-0654, Rev. 1, Standard E Criterion 3.
Section 6.2	TERMS O 13532 O 13566 O 15211 O 15212 Q 02859 Q 03114 Q 03115	Notification of the State of Ohio as well as the Counties.
Section 6.2	TERMS O 13532 O 13567 O 15211 O 15212	Message content
Section 6.5	TERMS O 13532 O 15211 O 15212 Q 02859	NRC Notification.
Section 6.2	TERMS O 13534 O 14152 O 15211	Initial and follow up message content
Section 6.2	TERMS O 15212	Documenting receipt of notification

END