

JUN 15 2001
LRN-01-0198



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 1
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **May 2001** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow for 6/15/01".

D. F. Garchow
Vice President - Operations

RAR
Attachments

C Distribution

IE24

INDEX

<u>SECTION</u>	<u>NUMBER OF PAGES</u>
Operating Data Report	1
Monthly Operating Summary	1

DOCKET NO.: 50-272
 UNIT: Salem 1
 DATE: 06/13/01
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period May 2001

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1115		
1106		
Month	Year-to-date	Cumulative
302	2581	129589
215	2494	125073
0	0	0
166317	2651134	126225109

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
1	5/1/01 -	S	434	C	4	Refuel Outage
2	5/19/01 5/22/01 - 5/26/01	F	95	A	3	Failed Current Transformer Wires

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

DOCKET NO.: 50-272
UNIT: Salem 1
DATE: 06/13/01
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 1 began the month in a scheduled refueling outage. The unit was placed back on-line on May 19, reaching 100% power on May 22.
- On May 22, Salem 1 automatically shutdown due to failed Current Transformer wires. The unit was placed back on-line on May 26.
- On May 27, power was reduced from 82% to 40% to repair a stop valve in the Moisture Separator Reheater.
- At the end of the month, Salem 1 completed 5 days of continuous on-line operation.