

March 21, 1990

Docket No. 50-423

Mr. Edward J. Mroczka  
Senior Vice President  
Nuclear Engineering and Operations  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: CORRECTION TO AMENDMENT NO. 46 (TAC NO. 74110)

The subject amendment dated February 21, 1990, revised the Technical Specifications for Millstone Unit 3 and was in response to your application dated July 20, 1989, as supplemented October 16, 1989.

It has been brought to our attention that an incorrect version of Technical Specification page 3/4 7-9 was issued with the subject amendment. Enclosed is correct page 3/4 7-9.

Sincerely,

/s/

David H. Jaffe, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION	Docket File	NRC & Local PDR	Plant File
S. Varga (14E4)		B. Boger (14A2)	J. Stolz
S. Norris		D. Jaffe	OGC
D. Hagan (MNBB 3302)		E. Jordan (MNBB 3302)	G. Hill(4) (P1-137)
W. Jones (P-130A)		J. Calvo (11F23)	ACRS (10)
GPA/PA		ARM/LFMB	

\*See previous concurrence

9003290115 900321  
PDR ADOCK 05000423  
PDC

OFC	:LA:PDI-4*	:PM:PDI-4*	:PD:PDI-4	:	:	:	:
NAME	:SNorris	:DJaffe	:JStolz	:	:	:	:
DATE	:03/20/90	:03/21/90	:03/21/90	:	:	:	:

OFFICIAL RECORD COPY  
Document Name: CORR. TO AMDMT 46 TAC 74555

DF01  
111

CP-1

Mr. E. J. Mrocza  
Northeast Nuclear Energy Company

Millstone Nuclear Power Station  
Unit No. 3

cc:

Gerald Garfield, Esquire  
Day, Berry and Howard  
Counselors at Law  
City Place  
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager  
Generation Facilities Licensing  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President  
Nuclear Operations  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

D. O. Nordquist  
Director of Quality Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director  
Radiation Control Unit  
Department of Environmental Protection  
State Office Building  
Hartford, Connecticut 06106

Regional Administrator  
Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary  
Energy Division  
Office of Policy and Management  
80 Washington Street  
Hartford, Connecticut 06106

First Selectmen  
Town of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385

S. E. Scace, Nuclear Station Director  
Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector  
Millstone Nuclear Power Station  
c/o U. S. Nuclear Regulatory Commission  
Post Office Box 811  
Niantic, Connecticut 06357

C. H. Clement, Nuclear Unit Director  
Millstone Unit No. 3  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

M. R. Scully, Executive Director  
Connecticut Municipal Electric  
Energy Cooperative  
30 Stott Avenue  
Norwich, Connecticut 06360

Ms. Jane Spector  
Federal Energy Regulatory Commission  
825 N. Capitol Street, N.E.  
Room 8608C  
Washington, D.C. 20426

Mr. Alan Menard, Manager  
Technical Services  
Massachusetts Municipal Wholesale  
Electric Company  
Post Office Box 426  
Ludlow, Massachusetts 01056

Burlington Electric Department  
c/o Robert E. Fletcher, Esq.  
271 South Union Street  
Burlington, Vermont 05402

## PLANT SYSTEMS

### MAIN STEAM LINE ISOLATION VALVES

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.5 Each main steam line isolation valve (MSIV) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

MODE 1:

With one MSIV inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours; otherwise be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

MODES 2, 3, and 4:

With one MSIV inoperable, subsequent operation in MODE 2 or 3 or 4 may proceed provided the isolation valve is maintained closed. Otherwise, be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.1.5.1 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 5 seconds in Modes 1, 2, and 3 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.

4.7.1.5.2 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 120 seconds in Mode 4 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into Mode 3.