March 27, 1989

Docket No. 50-423

Mr. Edward J. Mroczka Senior Vice President Nuclear Engineering and Operations Northeast Nuclear Energy Company Post Office Box 270 Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 71786)

The Commission has issued the enclosed Amendment No. 32 to Facility Operating License No. NPF-49 for Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 6, 1989 as supplemented by letter dated January 20, 1989

The amendment changes Technical Specification (TS) 4.7.10b, "Snubbers", to allow an approximate two month extension in the snubber visual inspection interval, to permit continued operation until the next refueling outage.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,

original signed by

David H. Jaffe, Project Manager Project Directorate I-4 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.³² to NPF-49

2. Safety Evaluation

cc w/enclosures: See next page

[5520 Document Name: AMEND TAC 71786]

OFC	:LA:PDI-4	· PMTRRI A	:PD:PDI-4	:0GC XZ:	:	:
NAME	SNorris	:DJaffe:Im	:JStoffz	SH Lewis		
DATE	:03/ /5 /89	:03/15/89	:03/ 6/89	:03/24/89		

OFFICIAL RECORD COPY

8904030008 890327 PDR ADOCK 05000423 P PDC Mr. E. J. Mroczka Northeast Nuclear Energy Company

cc:

Gerald Garfield, Esquire Day, Berry and Howard Counselors at Law City Place Hartford, Connecticut 06103-3499

W. D. Romberg, Vice President Nuclear Operations Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

Kevin McCarthy, Director Radiation Control Unit Department of Environmental Protection State Office Building Hartford, Connecticut 06106

Bradford S. Chase, Under Secretary Energy Division Office of Policy and Management 80 Washington Street Hartford, Connecticut 06106

S. E. Scace, Station Superintendent Millstone Nuclear Power Station Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

C. H. Clement, Unit Superintendent Millstone Unit No. 3 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Ms. Jane Spector Federal Energy Regulatory Commission 825 N. Capitol Street, N.E. Room 8608C Washington, D.C. 20426

Burlington Electric Department c/o Robert E. Fletcher, Esq. 271 South Union Street Burlington, Vermont 05402 Millstone Nuclear Power Station Unit No. 3

R. M. Kacich, Manager Generation Facilities Licensing Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

D. O. Nordquist Manager of Quality Assurance Northeast Nuclear Energy Company Post Office Box 270 Hartford, Connecticut 06141-0270

Regional Administrator Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

First Selectmen Town of Waterford Hall of Records 200 Boston Post Road Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector Millstone Nuclear Power Station c/o U. S. Nuclear Regulatory Commission Post Office Box 811 Niantic, Connecticut 06357

 M. R. Scully, Executive Director Connecticut Municipal Electric Energy Cooperative
268 Thomas Road Groton, Connecticut 06340

Michael L. Jones, Manager Project Management Department Massachusetts Municipal Wholesale Electric Company Post Office Box 426 Ludlow, Massachusetts 01056 AMENDMENT NO. 32 TO FACILITY OPERATING LICENSE NO. NPF-49 DATED: March 27, 1989 Docket File NRC PDR Local PDR Gray File S. Lainas (14E4) B. Boger (14A2) S. Norris D. Jaffe OGC D. Hagan (MNBB 3302) E. Jordan (MNBB 3302) B. Grimes (9A2) T. Meek(4) (P1-137) W. Jones (P-130A) E. Butcher (11F23) ACRS (10) GPA/PA ARM/LFMB



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.*

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.³² License No. NPF-49

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated January 6, 1989 as supplemented by letter dated January 20, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*}Northeast Nuclear Energy Company is authorized to act as agent and representative for the following Owners: Central Maine Power Company, Central Vermont Public Service Corporation, Chicopee Municipal Lighting Plant, City of Burlington, Vermont, Connecticut Municipal Electric Light Company, Massachusetts Municipal Wholesale Electric Company, Montaup Electric Company, New England Power Company, The Village of Lyndonville Electric Department, Western Massachusetts Electric Company, and Vermont Electric Generation and Transmission Cooperative, Inc., and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 32, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Fordohn F. Stolz, Director Project Directorate I-4 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: March 27, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 32

FACILTIY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are provided to maintain document completeness.

Remove

--

3/4 7-22

<u>Insert</u> 3/4 7-22 (no change)

3/4 7-22a

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS

- Verifying a system flow rate of 30,000 cfm +10% during system operation when tested in accordance with ANSI N510-1980.
- c. After every 720 hours of charcoal adsorber operation, by verifying, within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978,* meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978,* for a methyl iodide penetration of less than 0.175%;
- d. At least once per 18 months by:
 - Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6.8 inches Water Gauge while operating the system at a flow rate of 30,000 cfm +10%,
 - Verifying that the system starts on a Safety Injection test signal, and
 - 3) Verifying that the heaters dissipate 180 ±18 kW when tested in accordance with ANSI N510-1980.
- e. After each complete or partial replacement of a HEPA filter bank, by verifying that the cleanup system satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1980 for a DOP test aerosol while operating the system at a flow rate of 30,000 cfm +10%; and
- f. After each complete or partial replacement of a charcoal adsorber bank, by verifying that the cleanup system satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1980 for a halogenated hydrocarbon refrigerant test gas while operating the system at a flow rate of 30,000 cfm ±10%.

*ANSI N510-1980 shall be used in place of ANSI N510-1975 referenced in Regulatory Guide 1.52, Revision 2, March 1978.

MILLSTONE - UNIT 3

3/4 7-21

Amendment No. 2 APR 7 1987

PLANT SYSTEMS

<u>3/4.7.10</u> SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.10 All snubbers shall be OPERABLE. The only snubbers excluded from the requirements are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

<u>APPLICABILITY</u>: MODES 1, 2, 3, and 4. MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES.

ACTION:

With one or more snubbers inoperable on any system, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.10g. on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

SURVEILLANCE REQUIREMENTS

4.7.10 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.0.5.

a. <u>Inspection Types</u>

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. <u>Visual Inspections</u>

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these groups (inaccessible and accessible) may be inspected independently according to the schedule below. The first inservice visual inspection of each type of snubber shall be performed after 4 months but within 10 months of commencing POWER OPERATION and shall include all snubbers. If all snubbers of each type are found OPERABLE during the first inservice visual inspection, the second inservice visual inspection shall be performed at the first refueling outage. Otherwise, subsequent visual inspections shall be performed in accordance with the following schedule:

SURVEILLANCE REQUIREMENTS (Continued)

No. of Inoperable Snubbers of
Each Type per Inspection Period
0
1
2
3,4
5,6,7
8 or more

Subsequent Visual <u>Inspection Period</u>* # ** 18 months <u>+</u>25% 12 months <u>+</u>25% 6 months <u>+</u>25% 124 days <u>+</u>25% 62 days <u>+</u>25% 31 days <u>+</u>25%

MILLSTONE - UNIT 3

3/4 7-22a

Amendment No. 32

^{*}The inspection interval for each type of snubber shall not be lengthened more than one step at a time unless a generic problem has been identified and corrected; in that event the inspection interval may be lengthened one step the first time and two steps thereafter if no inoperable snubbers of that type are found.

[#]The provisions of Specification 4.0.2 are not applicable.

^{**}Those surveillances which must be performed on or before April 30, 1989, and are required per Specification 4.7.10.b, may be delayed for a period of two months and will be performed during the refueling outage scheduled to begin on May 20, 1989.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 32

TO FACILITY OPERATING LICENSE NO. NPF-49

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

INTRODUCTION

By application for license amendment dated January 6, 1989 as supplemented by letter dated January 20, 1989, Northeast Nuclear Energy Company, et al. (the licensee), requested changes to Millstone Unit 3 Technical Specification (TS) 4.7.10b, "Snubbers", to allow an approximate two month extension in the snubber visual inspection interval, to permit continued operation until the next refueling outage.

DISCUSSION AND EVALUATION

8904030012 890327 PDR ADOCK 05000423

Technical Specification 4.7.10b requires that snubbers on safety-related components and piping be visually inspected at various intervals depending upon snubber failure rate determined by the previous inspection. An increased number of snubber failures would decrease the surveillance intervals from as great as 18 months \pm 25% to as little as 31 days \pm 25%. The current inspection interval for Millstone Unit 3 is 18 months for all snubbers except for Type PSA-1/2 and PSA-1/4, which have a 12 month interval. During the last round of inspections, the licensee found all snubbers operable which enabled the licensee to increase the inspection interval for the Type PSA-1/2 and PSA-1/4 snubbers to 12 months. The next required inspection interval would end April 30, 1989. The licensee has requested that the surveillance interval be extended to allow snubber inspection during the next refueling outage, which is scheduled to begin on May 20, 1989. The proposed change to the TS would also have the effect of restarting the inspection interval so that the subsequent inspection interval will not be unduely short.

In reviewing the licensee's proposed TS change, the NRC staff notes that it is unlikely that a one time extension of approximately 20% of the snubber inspection interval will appreciably increase the incidence of undetected snubber failure. Moreover, although there may be small, localized, reductions in safety margins with regard to seismic resistance of safety systems due to undetected snubber failures, the overall reduction in safety margin will not be significant. Accordingly, the proposed change to TS 4.7.10b is acceptable.

ENVIRONMENTAL CONSIDERATION

This amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The staff has previously published a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amend-ment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: March 27, 1989

Principal Contributor: D. Jaffe