June 18, 1990

Corrected Copy

Docket No. 50-423

Mr. Edward J. Mroczka Senior Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company Post Office Box 270 Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

※其他國家的人類的人類實驗的時間。如果就是一些成素的情況也是在一個人的人力。

SUBJECT: MILLSTONE NUCLEAR POWER STATION UNIT 3 - ISSUANCE OF AMENDMENT (TAC NO. 75516)

The Commission has issued the enclosed Amendment No. 51 to Facility Operating License No. NPF-49 for Millstone Nuclear Power Station, Unit No. 3, in response to your application dated December 11, 1989 as supplemented by letter dated March 2, 1990.

The amendment modifies Technical Specification (TS) 3/4.5.1, "Accumulators," to increase the allowable out-of-service time (for reasons other than a closed discharge isolation valve) from 1 hour to 8 hours.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

Original signed by

David H. Jaffe, Project Manager Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

1

Enclosures: 1. Amendment No. 51 to NPF-49 2. Safety Evaluation

cc w/enclosures: See next page

OFC	:LA:PDI-4	: PM: PDI-4X	:PD:PDI-4	:OGC	A: OTSB	
NAME	SNOrris	:DJaffie:lm	JStold		Jalu	(PAL)
DATE	415/90	4/13/90	4/13/90	1/1-5/90		
	OFFICIAL Document	RECORD COPY Name: AMEND 75516 250293 500618 250293 05000423 ADDCK 05000423		CH CBORTS S-31-90 S-C	Durt Nermoure North	n/12/91 KCA Fol ut Last 1/1

DATED: June 18, 1990 AMENDMENT NO. 51 TO FACILITY OPERATING LICENSE NO. NPF-49

DISTRIBUTION: Docket-File NRC & Local PDRs Plant File S. Varga (14E4) B. Boger (14A2) J. Stolz S. Norris D. Jaffe OGC D. Hagan (MNBB 3302) E. Jordan (MNBB 3302) G. Hill(4) (P1-137) W. Jones (P-130A) J. Calvo (11F23) ACRS (10) GPA/PA ARM/LFMB

1.

E. J. Mroczka Northeast Nuclear Energy Company

15

5 . F.

. . . Gerald Garfield, Esquire; Day, Berry and Howard Counselors at Law City, Place Hartford, Connecticut 06103-3499

W. D. Romberg, Vice President Nuclear Operations Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

Kevin McCarthy, Director Radiation Control Unit Department of Environmental Protection State Office Building Hartford, Connecticut 06106

Bradford S. Chase, Under Secretary Energy Division Office of Policy and Management 80 Washington Street Hartford, Connecticut 06106

S. E. Scace, Nuclear Station Director Millstone Nuclear Power Station Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

C. H. Clement, Nuclear Unit Director Millstone Unit No. 3 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Ms. Jane Spector Federal Energy Regulatory Commission 825 N. Capitol Street, N.E. Room 8608C Washington, D.C. 20426

Burlington Electric Department c/o Robert E. Fletcher, Esq. 271 South Union Street Burlington, Vermont 05402

Millstone Nuclear Power Station Unit No. 3

R. M. Kacich, Manager Generation Facilities Licensing Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

D. O. Nordquist Director of Quality Services Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

Regional Administrator Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

First Selectmen Town of Waterford Hall of Records 200 Boston Post Road Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector Millstone Nuclear Power Station c/o U. S. Nuclear Regulatory Commission Post Office Box 811 Niantic, Connecticut 06357

M. R. Scully, Executive Director Connecticut Municipal Electric Energy Cooperative 30 Stott Avenue Norwich, Connecticut 06360

Mr. Alan Menard, Manager **Technical Services** Massachusetts Municipal Wholesale Electric Company Post Office Box 426 Ludlow, Massachusetts 01056

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 51 License No. NPF-49

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated December 11, 1989 as supplemented by letter dated March 2, 1990 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9006250306 900618 PDR ADUCK 05000423 P

小菱類形式 装飾を装む 法定部分 人名法格兰尔 読みがいます あいしょう たいしょう

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:
 - (2) Technical Specifications

1999年の1999年の「1999年の「1999年の日本には、1999年の日本には、1999年の1999年の1999年の1999年の1999年の1999年の1999年の1999年の1999年の1999年の1

The Technical Specifications contained in Appendix A, as revised through Amendment No. 51 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

John/F. Stolz, Director Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: June 18, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 51

FACILTIY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace page 3/4 5-1 of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains a vertical line indicating the area of change. The corresponding overleaf page is provided to maintain document completeness.

This attachment to 504/23P (9006250293) 6/18/90 Was to tgel yttrateveloni no as yostage ut fo A filoned for at tremhartto

3/4.5 EMERGENCY CORE COOLING SYSTEMS

3/4.5.1 ACCUMULATORS

LIMITING CONDITION FOR OPERATION

3.5.1 Each Reactor Coolant System (RCS) accumulator shall be OPERABLE with:

- a. The isolation valve open and power removed,
- b. A contained borated water volume of between 6618 and 6847 gallons,
- c. A boron concentration of between 2200 and 2600 ppm, and
- d. A nitrogen cover-pressure of between 636 and 694 psia.

APPLICABILITY: MODES 1, 2, and 3*.

ACTION:

- a. With one accumulator inoperable, except as a result of a closed isolation valve, restore the inoperable accumulator to OPERABLE status within 8 hours or be in at least HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
- b. With one accumulator inoperable due to the isolation valve being closed, either immediately open the isolation valve or be in at least HOT STANDBY within 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.

SURVEILLANCE REQUIREMENTS

- 4.5.1.1 Each accumulator shall be demonstrated OPERABLE:
 - a. At least once per 12 hours by:
 - 1) Verifying the contained borated water volume and nitrogen cover-pressure in the tanks to be within the above limits, and
 - 2) Verifying that each accumulator isolation valve is open.
 - b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the accumulator solution; and

*Pressurizer pressure above 1000 psig.

MILLSTONE - UNIT 3

3/4 5-1

Amendment No. 12, 51

56423P

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. G. 2000

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 51

TO FACILITY OPERATING LICENSE NO. NPF-49

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

INTRODUCTION

By application for license amendment dated December 11, 1989, as supplemented by letter dated March 2, 1989, Northeast Nuclear Energy Company, et. al (the licensee), requested changes to Millstone Unit 3 Technical Specifications (TS). The proposed amendment would modify Technical Specification (TS) 3/4.5.1, "Accumulators," to increase the allowable out-of-service time (for reasons other than a closed discharge isolation valve) from 1 hour to 8 hours.

DISCUSSION AND EVALUATION

The Millstone Unit 3 coolant system is equipped with four large tanks pressurized with nitrogen and containing borated water. In the event of a loss-of-coolant accident (LOCA) that causes a significant decrease in reactor coolant system pressure, these "accumulator" tanks discharge their borated water into the reactor coolant system. The accumulator's function is to temporarily reflood the reactor coolant system and thus supply coolant until the Emergency Core Cooling System can begin operation.

At the present time, TS 3.5.1 requires that, during Modes 1, 2 and 3, each accumulator be operable with the following conditions being met:

a. The isolation valve open and power removed,

- b. A contained borated water volume of between 6618 and 6847 gallons,
- c. A boron concentration of between 2200 and 2600 ppm, and
- d. A nitrogen cover-pressure of between 636 and 694 psia.

If one accumulator is inoperable for reasons other than a closed isolation valve, TS 3.5.1 would require restoration of the inoperable accumulator to operable status within 1 hour or place the plant in Hot Standby within 6 hours. The licensee has requested that the 1 hour restoration time be extended to 8 hours.

900618 2006250313 PDR ADDCK ADDCK 0500

The NRC staff has reviewed a requested change to the TS for Seabrook Unit 1 Docket NO. 50-443 that is identical to the request considered herein. Seabrook Unit 1 utilizes a Westinghouse 4 loop PWR that is similar to Millstone Unit 3 in many respects. In the case of Seabrook Unit 1, the change to TS to increase allowable out of service time for the accumulators (except as a result of a closed isolation valve) from one hour to eight hours was found to be safe and acceptable as the contribution to risk from this change was determined to be small and the necessity that all four accumulators be operable is conservative. The NRC staff considerations associated with the Seabrook Unit 1 TS change are documented in a May 20, 1986 letter from Thomas M. Novak, NRC, to Robert J. Harrison, Public Service Company of New Hampshire.

In addition, using an NRC staff-approved probabilistic risk assessment (PRA) model, the Millstone Unit 3 licensee found that the probability of a medium-tolarge break LOCA concurrent with an inoperable accumulator increased from 3.75E-8/yr to 3.00E-7/yr. The increase in core melt frequency, however, only increases by 2.63E-7/yr. This increase is negligible (e.g. less than .5%) when compared to the overall core melt frequency due to internally initiated events of 6.34 E-5/yr.

We have reviewed the licensee's calculations concerning inoperability of an accumulator and we concur that the associated increase in core melt frequency is negligible and acceptable. Accordingly, the proposed change to the TS is acceptable.

ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The staff has previously published a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: June 18, 1990

Principal Contributor: David H. Jaffe