

April 22, 1991

DISTRIBUTION

Docket #1
NRC & L PDRs
PDI-4 plant
SVarga
JCalvo
SNorris
DJaffe
OGC
DHagan

GHill (3)
Wanda Jones
ACRS (10)
GPA/PA
OC/LFMB

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 79628)

The Commission has issued the enclosed Amendment No. 61 to Facility Operating License No. NPF-49 for Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 18, 1991 as supplemented by letters dated April 5, 1991 and April 8, 1991.

Northeast Nuclear Energy Company requested that the proposed license amendment be reviewed on an emergency basis and that a Temporary Waiver of Compliance (TWC) be issued until such time as the NRC acts on the proposed license amendment. The TWC was issued on April 9, 1991.

The amendment changes Technical Specification (TS) 4.6.4.2.b.4, "Electric Hydrogen Recombiners," and adds the following note to the pressure - dependent flow requirements for the hydrogen recombiners in TS Figure 3.6-2:

Until September 30, 1991, a flow rate of 72.4 scfm or greater at a pressure of 14.5 to 14.8 psia is acceptable in lieu of the values indicated by Figure 3.6-2.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance and opportunity for hearing will be included in this Commission's biweekly Federal Register notice.

Sincerely,

/s/

David H. Jaffe, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 61 to NPF-49
- 2. Safety Evaluation

NRC FILE CENTER COPY

cc w/enclosures:

See next page

Document Name: AMEND 79628

OFC	:PDI-4:LA	:PDI-4:PM	:SPLB	:PDI-4:D	:OGC
NAME	:SNorris	:DJaffe/Bah	:CMcCracken	:JStolz	:Jaffe
DATE	: 4/11/91	: 4/11/91	: 4/12	: 4/12/91	: 4/12/91
OFC	:AD/RI	:	:	:	:
NAME	:JCalvo	:	:	:	:
DATE	: 4/17/91	:	:	:	:

Mr. E. J. Mroczka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit No. 3

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Nuclear Station Director
Millstone Nuclear Power Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector
Millstone Nuclear Power Station
c/o U. S. Nuclear Regulatory Commission
Post Office Box 811
Niantic, Connecticut 06357

C. H. Clement, Nuclear Unit Director
Millstone Unit No. 3
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

Ms. Jane Spector
Federal Energy Regulatory Commission
825 N. Capitol Street, N.E.
Room 8608C
Washington, D.C. 20426

Mr. Alan Menard, Manager
Technical Services
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Burlington Electric Department
c/o Robert E. Fletcher, Esq.
271 South Union Street
Burlington, Vermont 05402



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 61
License No. NPF-49

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated January 18, 1991 as supplemented by letters dated April 5, 1991 and April 8, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 61, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Jose A. Calvo

Jose A. Calvo, Assistant Director
for Region I Reactors
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 22, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 61

FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace page 3/4 6-36a of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the areas of change.




FIGURE 3.6-2
 HYDROGEN RECOMBINER ACCEPTANCE CRITERIA
 FLOW VS CONTAINMENT PRESSURE *

3/4 6-36a

Amendment No. 47, 61

MILLSTONE - UNIT 3

*Until September 30, 1991, a flow rate of 72.4 scfm or greater at a pressure of 14.5 to 14.8 psia is acceptable in lieu of the values indicated by Figure 3.6-2.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 61

TO FACILITY OPERATING LICENSE NO. NPF-49

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

1.0 INTRODUCTION

By letter dated January 18, 1991, as supplemented by letters dated April 5, 1991 and April 8, 1991, the Northeast Nuclear Energy Company, (the licensee) submitted a request for changes to the Millstone Nuclear Power Station, Unit No. 3 Technical Specifications (TS).

The proposed amendment would change Technical Specification (TS) 4.6.4.2.b.4, "Electric Hydrogen Recombiners," and would add the following note to the pressure - dependent flow requirements for the hydrogen recombiners in TS Figure 3.6-2:

Until September 30, 1991, a flow rate of 72.4 scfm or greater at a pressure of 14.5 to 14.8 psia is acceptable in lieu of the values indicated by Figure 3.6-2.

The licensee also requested that the NRC staff issue a temporary waiver of compliance (TWC) to be effective until such time as the NRC staff could act on the licensee's application. The NRC staff has previously issued a proposed no significant hazards consideration determination on the January 18, 1991 application which was published in the Federal Register on April 3, 1991 (56 FR 13666). The April 5, 1991 and April 8, 1991 supplements, however, substantially changed the proposal contained in the January 18, 1991 application.

2.0 DISCUSSION

On March 26, 1991, as a part of the 18-month surveillance test, a functional test of the Millstone Unit No. 3 hydrogen recombiner (A) was performed using the acceptance criterion included in TS 4.6.4.2.b.4. The test results indicated that the hydrogen recombiner was capable of delivering a flow rate of approximately 74.5 scfm at a containment pressure of 14.77 psia. This represents a failure to meet the acceptance criterion of TS Figure 3.6-2, which is a pressure dependent flow curve, by approximately 2 scfm. On April 2, 1991, NNECO performed the same test on hydrogen recombiner (B). The test results indicate that the hydrogen recombiner (B) is capable of delivering a flow rate of approximately 72.8 scfm at 14.725 psia whereas the required flow rate at that

pressure is 75 scfm. Millstone Unit 3 is provided with two 100 percent capacity electric hydrogen recombiners which are designed to process the post-LOCA containment atmosphere to maintain the hydrogen concentration at a safe level (below 4 percent). Based on these test results, NNECO could not verify the operability of both the hydrogen recombiners using the acceptance criterion included in Figure 3.6-2. Therefore, on April 2, 1991, NNECO informed the staff of the current situation and NNECO's plan to request that the NRC staff process a license amendment on an emergency basis.

Since the issuance of TS Figure 3.6-2 on March 2, 1990 (License Amendment 47), new technical information has been received, by NNECO, from the hydrogen recombiner blower manufacturer, M-D Pneumatics, which indicates that the information used to generate Figure 3.6-2 was not appropriate and was overly conservative. This has resulted in the recent test failures. Figure 3.6-2 was developed using generic information for this type of blower. NNECO's letter of April 5, 1991, as supplemented by letter dated April 8, 1991, proposed that the following footnote be added to TS Figure 3.6-2:

Until September 30, 1991, a flow rate of 72.4 scfm or greater at a pressure of 14.5 to 14.8 psia is acceptable in lieu of the values indicated by Figure 3.6-2.

3.0 EVALUATION

Hydrogen recombiner (A) passed the surveillance test as required by the current TS, as a result of subsequent testing. Recombiner (B) fell short of the TS flow rate requirement by only 2% when it was tested. The licensee's analysis shows that there is substantial margin between the flow rate required by the current TS and the flow rate that would actually be required during a LOCA for the recombiner to fulfill its design function. Although the staff has not completed a detailed review of the licensee's analysis, there is reasonable assurance that the small shortfall in flow rate has not rendered the recombiner inoperable. The proposed TS reduces the required flow rate slightly and thus would allow the licensee to declare both recombiners to be operable, having satisfied the new surveillance acceptance criteria. Therefore, for the relatively short time period allowed by the proposed TS, and considering the relatively low probability of a LOCA occurring during that period, the staff finds that the proposed TS is acceptable.

4.0 EMERGENCY CIRCUMSTANCES

The licensee, in its January 18, 1991 application as supplemented by letters dated April 5, 1991 and April 8, 1991, requested that, pursuant to 10 CFR 50.91(a)(5), the proposed TS change be approved on an emergency basis. The licensee stated that emergency approval is needed because "...an emergency

situation exists, in that failure to act in a timely way would result ... in shutdown of a nuclear power plant," the situation could not have been avoided and because the proposed amendment does not involve a significant hazards consideration. As stated in Section 2.0 of this safety evaluation, the licensee identified the concern associated with the hydrogen recombiner flow testing and made every reasonable attempt to resolve these concerns prior to requesting an emergency license amendment.

The licensee was granted a TWC from the requirements of TS 4.6.4.2.b.4 on April 9, 1991 to allow Millstone Unit 3 to resume power operation following the refueling outage. In granting the Temporary Waiver of Compliance, the NRC staff recognized that emergency circumstances existed that warranted prompt approval in that failure to act would result in extending the Millstone Unit 3 shutdown, that the situation could not have been avoided, and that the licensee promptly applied for the amendment. Thus, pursuant to 10 CFR 50.91(a)(5), the staff finds that an emergency situation exists which would result in extending the plant shutdown.

5.0 FINAL NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

The Commission's regulations in 10 CFR 50.92 state that the Commission may make a final determination that the license amendment involves no significant hazards consideration if operation of the facility, in accordance with the amendment, would not:

1. Involve a significant increase in the probability or consequences of an accident previously analyzed.

The proposed changes to Section 4.6.4.2.b.4 will continue to verify the capability of the hydrogen recombiners to meet design basis analysis assumptions. The appropriate plant procedures are in place to ensure that the hydrogen recombiners are placed in service within 24 hours of a LOCA. Therefore, it is concluded that the LOCA and its consequences as analyzed remain valid. Since no physical modifications are proposed, there is no impact on the probability of failure. Therefore, probability of a LOCA is not affected.

2. Create the possibility of a new or different kind of accident from any previously analyzed.

The proposed changes do not impact the plant response to a LOCA. Since there are no changes in the way the plant is operated, the potential for an unanalyzed accident is not created, and no new failure modes are introduced.

3. Involve a significant reduction in the margin of safety.

The proposed changes do not increase the consequences of any accidents. Also, none of the protective boundaries are adversely affected. The performance level of the hydrogen recombiners assured by the proposed

surveillance requirements along with the appropriate plant procedures maintain the margin of safety as defined in the existing and proposed Technical Specifications.

Accordingly, the NRC staff concludes that the proposed amendment involves no significant hazards considerations.

6.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Connecticut State official was notified of the proposed issuance of the amendment. The State official had no comments.

7.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has made a final no significant hazards consideration determination with respect to this amendment. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

8.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: David H. Jaffe

Date: April 22, 1991