May 17, 1995

Mr. John F. Opeka Executive Vice President, Nuclear Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company Post Office Box 270 Hartford, CT 06141-0270

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M91372)

Dear Mr. Opeka:

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 18, 1995.

The amendment revises the Technical Specifications to increase the minimum required boron concentration in the boric acid tank (BAT) from 6300 to 6600 ppm. The increase is required to meet the latest analysis for cycle 6 which includes additional conservatisms which are meant to ensure the new required boron concentration will bound future cycle variations.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

Original signed by:

Vernon L. Rooney, Senior Project Manager Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosures: 1. Amendment No.¹¹³ to NPF-49 2. Safety Evaluation

cc w/encls: See next page

Distribution	RJones	
Docket File	OGC	
PUBLIC	GHill (2)	
PD I-3 Plant	CGrimes	
SVarga	GSchwenk	
JZwolinski	ACRS (4)	
РМсКее	OPA	
SNorris	OC/LFDCB	
VRooney	LNicholson,	RI
-	200642	

MRC FILE GENTER COPY

DOCUMENT NAME: G:\ROONEY\M91372.AMD

JOCOMENT	INTE: G. (ROOHLI)	115107 211010			
OFFICE	LA:PDI-3 /	PM:PDI-BM	BC:SRXB	D:PDI-3	OGC RB
NAME	SNorris pr	VRooney: on	RJones	PMcKee	n RBachmann
DATE	05/2/95	05/3/95	05/ /95	05/3/95	05/9/95
9: Pi P	505240150 950517 DR ADUCK 050004 PE	7 5 123 XR	ICIAL RECORD COPY	`	DEC1'

May 17, 1995

Mr. John F. Opeka Executive Vice President, Nuclear Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company Post Office Box 270 Hartford, CT 06141-0270

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M91372)

Dear Mr. Opeka:

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 18, 1995.

The amendment revises the Technical Specifications to increase the minimum required boron concentration in the boric acid tank (BAT) from 6300 to 6600 ppm. The increase is required to meet the latest analysis for cycle 6 which includes additional conservatisms which are meant to ensure the new required boron concentration will bound future cycle variations.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

Original signed by:

Vernon L. Rooney, Senior Project Manager Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosures: 1. Amendment No.¹¹³ to NPF-49 2. Safety Evaluation

cc w/encls: See next page

Distribution:	RJones OGC
PUBLIC	GHill (2)
PD I-3 Plant	CGrimes
SVarga	GSchwenk
JZwolinski	ACRS (4)
PMcKee	OPA
SNorris	OC/LFDCB
VRooney	LNicholson, RI

DOCUMENT NAME: G:\ROONEY\M91372.AMD

OFFICE	LA:PDI-3	PM:PDI-BA	BC.SRXB	D:PDI-30	OGC AC
NAME	SNorris	VRooney: cn	RJones	PMcKee WAY	RBachmann
DATE	05/2/95	05/3/95	05/ /95	05/3_/95	<u> </u>

OFFICIAL RECORD COPY



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 17, 1995

Mr. John F. Opeka Executive Vice President, Nuclear Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company Post Office Box 270 Hartford, CT 06141-0270

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M91372)

Dear Mr. Opeka:

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 18, 1995.

The amendment revises the Technical Specifications to increase the minimum required boron concentration in the boric acid tank (BAT) from 6300 to 6600 ppm. The increase is required to meet the latest analysis for cycle 6 which includes additional conservatisms which are meant to ensure the new required boron concentration will bound future cycle variations.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

4

Sincerely,

Vernon L. Rooney, Senior Project Manager Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosures: 1. Amendment No. 113 to NPF-49 2. Safety Evaluation

cc w/encls: See next page

Mr. John F. Opeka Northeast Nuclear Energy Company

cc:

Ms. L. M. Cuoco, Senior Nuclear Counsel Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

F. R. Dacimo, Vice President Haddam Neck Station Connecticut Yankee Atomic Power Company 362 Injun Hollow Road East Hampton, Connecticut 06424-3099

Kevin T. A. McCarthy, Director Monitoring and Radiation Division Department of Environmental Protection 79 Elm Street Hartford, Connecticut 06106-5127

Allan Johanson, Assistant Director Office of Policy and Management Policy Development and Planning Division 80 Washington Street Hartford, Connecticut 06106

S. E. Scace, Vice President Nuclear Operations Services Northeast Utilities Service Company Post Office Box 128 Waterford, Connecticut 06385

Nicholas S. Reynolds Winston & Strawn 1400 L Street, NW Washington, DC 20005-3502

R. M. Kacich, Director Nuclear Planning, Licensing & Budgeting Northeast Utilities Service Company Post Office Box 128 Waterford, Connecticut 06385

J. M. Solymossy, Director Nuclear Quality and Assessment Services Northeast Utilities Service Company Post Office Box 128 Waterford, Connecticut 06385 Millstone Nuclear Power Station Unit 3

> Regional Administrator Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

First Selectmen Town of Waterford Hall of Records 200 Boston Post Road Waterford, Connecticut 06385

P. D. Swetland, Resident Inspector Millstone Nuclear Power Station c/o U.S. Nuclear Regulatory Commission Post Office Box 513 Niantic, Connecticut 06357

Donald B. Miller, Jr. Senior Vice President Millstone Station Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

M. H. Brothers, Nuclear Unit Director Millstone Unit No. 3 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Burlington Electric Department c/o Robert E. Fletcher, Esq. 271 South Union Street Burlington, Vermont 05402

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

David W. Graham Fuel Supply Planning Manager Massachusetts Municipal Wholesale Electric Company Post Office Box 426 Ludlow, Massachusetts 01056



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113 License No. NPF-49

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated January 18, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part
 51 of the Commission's regulations and all applicable
 requirements have been satisfied.

9505

052401

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-49 is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 113 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Phillip F. McKee, Director Project Directorate I-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 17, 1995

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 113

FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Appendix A, Technical Specifications, with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove	<u>Insert</u>
3/4 1-1	3/4 1-1
3/4 1-3	3/4 1-3
3/4 1-8	3/4 1-8
3/4 1-17	3/4 1-17
3/4 1-18	3/4 1-18
3/4 9-1	3/4 9-1
3/4 10-1	3/4 10-1
B 3/4 1-3	B 3/4 1-3

3/4.1.1.1 BORATION CONTROL

<u>SHUTDOWN MARGIN - MODES 1 AND 2</u>

LIMITING CONDITION FOR OPERATION

3.1.1.1.1 The SHUTDOWN MARGIN shall be greater than or equal to 1.3% $\Delta k/k$ for both four loop and three loop operation.

<u>APPLICABILITY</u>: MODES 1 and 2*.

ACTION:

With the SHUTDOWN MARGIN less than 1.3% $\Delta k/k$, immediately initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or equivalent until the required SHUTDOWN MARGIN is restored.

SURVEILLANCE REQUIREMENTS

4.1.1.1.1 The SHUTDOWN MARGIN shall be determined to be greater than or equal to 1.3% $\Delta k/k$:

- a. Within 1 hour after detection of an inoperable control rod(s) and at least once per 12 hours thereafter while the rod(s) is inoperable. If the inoperable control rod is immovable or untrippable, the above required SHUTDOWN MARGIN shall be verified acceptable with an increased allowance for the withdrawn worth of the immovable or untrippable control rod(s);
- b. When in MODE 1 or MODE 2 with K_{eff} greater than or equal to 1 at least once per 12 hours by verifying that control bank withdrawal is within the limits of Specification 3.1.3.6;
- c. When in MODE 2 with K_{eff} less than 1, within 4 hours prior to achieving reactor criticality by verifying that the predicted critical control rod position is within the limits of Specification 3.1.3.6;
- d. Prior to initial operation above 5% RATED THERMAL POWER after each fuel loading, by consideration of the factors of Specification 4.1.1.1.2, with the control banks at the maximum insertion limit of Specification 3.1.3.6; and

*See Special Test Exceptions Specification 3.10.1.

3/4.1.1 BORATION CONTROL

SHUTDOWN MARGIN - MODES 3. 4 AND 5 LOOPS FILLED

LIMITING CONDITION FOR OPERATION

3.1.1.1.2 The SHUTDOWN MARGIN shall be greater than or equal to the limits shown in Figures 3.1-1, 3.1-3 and 3.1-4 for four loop operation and in Figure 3.1-2 for three loop operation.

<u>APPLICABILITY</u>: MODES 3, 4 and 5

ACTION:

With the SHUTDOWN MARGIN less than the required value, immediately initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or equivalent until the required SHUTDOWN MARGIN is restored.

SURVEILLANCE REQUIREMENTS

4.1.1.1.2.1 The SHUTDOWN MARGIN shall be determined to be greater than or equal to the required value:

- a. Within 1 hour after detection of an inoperable control rod(s) and at least once per 12 hours thereafter while the rod(s) is inoperable. If the inoperable control rod is immovable or untrippable, the above required SHUTDOWN MARGIN shall be verified acceptable with an increased allowance for the withdrawn worth of the immovable or untrippable control rod(s); and
- b. At least once per 24 hours by consideration of the following factors:
 - 1) Reactor Coolant System boron concentration,
 - 2) Control rod position,
 - 3) Reactor Coolant System average temperature,
 - 4) Fuel burnup based on gross thermal energy generation,
 - 5) Xenon concentration, and
 - 6) Samarium concentration.

4.1.1.1.2.2 Valve 3CHS-V305 shall be verified closed and locked at least once per 31 days.

SHUTDOWN MARGIN - COLD SHUTDOWN - LOOPS NOT FILLED

LIMITING CONDITION FOR OPERATION

- 3.1.1.2 The SHUTDOWN MARGIN shall be greater than or equal to
 - a) the limits shown in Figure 3.1-5 or
 - b) the limits shown in Figure 3.1-4, with the chemical and volume control system (CVCS) aligned to preclude reactor coolant system boron concentration reduction.

APPLICABILITY: MODE 5 LOOPS NOT FILLED

ACTION:

- a. With the SHUTDOWN MARGIN less than the above, immediately initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or equivalent until the required SHUTDOWN MARGIN is restored.
- b. With the CVCS dilution flow paths not closed and secured in position in accordance with Specification 3.1.1.2(b), immediately close and secure the paths or meet the limits shown in Figure 3.1-5.

SURVEILLANCE REQUIREMENTS

4.1.1.2.1 The SHUTDOWN MARGIN shall be determined to be greater than or equal to the above:

- a. Within 1 hour after detection of an inoperable control rod(s) and at least once per 12 hours thereafter while the rod(s) is inoperable. If the inoperable control rod is immovable or untrippable, the SHUTDOWN MARGIN shall be verified acceptable with an increased allowance for the withdrawn worth of the immovable or untrippable control rod(s); and
- b. At least once per 24 hours by consideration of the following factors:
 - 1) Reactor Coolant System boron concentration,
 - 2) Control rod position,
 - 3) Reactor Coolant System average temperature,
 - 4) Fuel burnup based on gross thermal energy generation,

BORATED WATER SOURCE - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A Boric Acid Storage System with:
 - 1) A minimum contained borated water volume of 6700 gallons,
 - 2) A boron concentration between 6600 and 7175 ppm, and
 - 3) A minimum solution temperature of 67°F.
- b. The refueling water storage tank (RWST) with:
 - 1) A minimum contained borated water volume of 250,000 gallons,
 - 2) A minimum boron concentration of 2700 ppm, and
 - 3) A minimum solution temperature of 40°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.

SURVEILLANCE REQUIREMENTS

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1) Verifying the boron concentration of the water,
 - 2) Verifying the contained borated water volume, and
 - 3) Verifying the Boric Acid Transfer Pump Room temperature and the boric acid storage tank solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the RWST temperature when it is the source of borated water and the outside air temperature is less than 35°F.

10.00

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2:

- a. A Boric Acid Storage System with:
 - 1) A minimum borated water usable volume of 21,802 gallons,
 - 2) A boron concentration between 6600 and 7175 ppm, and
 - 3) A minimum solution temperature of 67°F.
- b. The refueling water storage tank (RWST) with:
 - 1) A minimum contained borated water volume of 1,166,000 gallons,
 - 2) A boron concentration between 2700 and 2900 ppm,
 - 3) A minimum solution temperature of 40°F, and
 - 4) A maximum solution temperature of 50°F.

<u>APPLICABILITY</u>: MODES 1, 2, 3, and 4.

ACTION:

- a. With the Boric Acid Storage System inoperable, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least the limits as shown in Figure 3.1-4 at 200°F; restore the Boric Acid Storage System to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the RWST inoperable, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3/4.9 REFUELING OPEN JONS

3/4.9.1 BORON CONCENTRATION

LIMITING CONDITION FOR OPERATION

3.9.1.1 The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained uniform and sufficient to ensure that the more restrictive of the following reactivity conditions is met; either:

- a. A K_{eff} of 0.95 or less, or
- b. A boron concentration of greater than or equal to 2600 ppm.

Additionally, the CVCS valves of Specification 4.1.1.2.2 shall be closed and secured in position.

APPLICABILITY: MODE 6.*

ACTION:

- a. With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or its equivalent until $K_{\rm off}$ is reduced to less than or equal to 0.95 or the boron concentration is restored to greater than or equal to 2600 ppm, whichever is the more restrictive.
- b. With any of the CVCS values of Specification 4.1.1.2.2 not closed** and secured in position, immediately close and secure the values.

SURVEILLANCE REQUIREMENTS

4.9.1.1.1 The more restrictive of the above two reactivity conditions shall be determined prior to:

- a. Removing or unbolting the reactor vessel head, and
- b. Withdrawal of any full-length control rod in excess of 3 feet from its fully inserted position within the reactor vessel.

4.9.1.1.2 The boron concentration of the Reactor Coolant System and the refueling canal shall be determined by chemical analysis at least once per 72 hours.

4.9.1.1.3 The CVCS valves of Specification 4.1.1.2.2 shall be verified closed and locked at least once per 31 days.

*The reactor shall be maintained in MODE 6 whenever fuel is in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

****Except those opened under administrative control.**

MILLSTONE	-	UNIT 3	3/4	9-1
0311			•	-

Amendment No. \$9, \$9, 99, 113

3/4.10 SPECIAL TEST EXCEPTIONS

3/4.10.1 SHUTDOWN MARGIN

LIMITING CONDITION FOR OPERATION

3.10.1 The SHUTDOWN MARGIN requirement of Specification 3.1.1.1 may be suspended for measurement of control rod worth and SHUTDOWN MARGIN provided reactivity equivalent to at least the highest estimated control rod worth is available for trip insertion from OPERABLE control rod(s).

APPLICABILITY: MODE 2.

ACTION:

- a. With any full-length control rod not fully inserted and with less than the above reactivity equivalent available for trip insertion, immediately initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or its equivalent until the SHUTDOWN MARGIN required by Specification 3.1.1.1 is restored.
- b. With all full-length control rods fully inserted and the reactor subcritical by less than the above reactivity equivalent, immediately initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or its equivalent until the SHUTDOWN MARGIN required by Specification 3.1.1.1 is restored.

SURVEILLANCE REQUIREMENTS

4.10.1.1 The position of each full-length control rod either partially or fully withdrawn shall be determined at least once per 2 hours.

4.10.1.2 Each full-length control rod not fully inserted shall be demonstrated capable of full insertion when tripped from at least the 50% withdrawn position within 24 hours prior to reducing the SHUTDOWN MARGIN to less than the limits of Specification 3.1.1.1.

BASES

BORATION SYSTEMS (Continued)

MARGIN from expected operating conditions of equivalent to that required by Figure 3.1-5 after xenon decay and cooldown to 200°F. The maximum boration capability (minimum boration volume) requirement is established to conservatively bound expected operating conditions throughout core operating life. The initial RCS boron concentration is based on a minimum expected hot full power or hot zero power condition (peak xenon). The final RCS boron concentration assumes that the most reactive control rod is not inserted into the core. This set of conditions requires a minimum usable volume of 21,802 gallons of 6600 ppm borated water from the boric acid storage tanks or 1,166,000 gallons of 2700 ppm borated water from the refueling water storage tank (RWST). A minimum RWST volume of 1,166,000 gallons is specified to be consistent with ECCS requirement.

With the RCS temperature below 200°F, one Boron Injection System is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity changes in the event the single Boron Injection System becomes inoperable.

The limitation for a maximum of one centrifugal charging pump to be OPER-ABLE and the Surveillance Requirement to verify all charging pumps except the required OPERABLE pump to be inoperable below 350°F provides assurance that a mass addition pressure transient can be relieved by the operation of a single PORV.

The boron capability required below 200°F is sufficient to provide a SHUTDOWN MARGIN of $1.3\% \Delta k/k$ after xenon decay and cooldown from 200°F to 140°F. This condition requires either a usable volume of 4100 gallons of 6600 ppm borated water from the boric acid storage tanks or 250,000 gallons of 2700 ppm borated water from the RWST. The unusable volume in each boric acid storage tank is 1300 gallons.

The contained water volume limits include allowance for water not available because of discharge line location and other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 7.0 and 7.5 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

The minimum RWST solution temperature for MODES 5 and 6 is based on analysis assumptions in addition to freeze protection considerations. The minimum/maximum RWST solution temperatures for MODES 1, 2, 3 and 4 are based on analysis assumptions.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 113

TO FACILITY OPERATING LICENSE NO. NPF-49

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

1.0 INTRODUCTION

By letter dated January 18, 1995 the Northeast Nuclear Energy Company (the licensee) submitted a request for changes to the Millstone Nuclear Power Station, Unit No. 3 Technical Specifications (TSs). The requested changes would revise the TSs to increase the minimum required boron concentration in the boric acid tank (BAT) from 6300 to 6600 ppm. The increase is required to meet the latest analysis for Cycle 6 which includes additional conservatisms which are meant to ensure the new required boron concentration will bound future cycle variations.

2.0 EVALUATION

The current Cycle 5 TS value for the minimum boron concentration in the BAT is 6300 ppm. This value was set by previous Westinghouse BORDER analyses. The BORDER evaluation determines the ability to maintain shutdown margin when the plant is taken from initial operating condition of Mode 1 or 2 to a final condition of mode 5 or 6 using an assumed minimum BAT concentration.

For Millstone 3 Cycle 6 the BORDER evaluation included the following conservatisms which attempt to ensure that future cycle variations and redesign effects are bounded:

- 1. The best-estimate critical boron concentration for the Mode 1/2 initial condition was decreased by 50 ppm.
- 2. The best-estimate maximum required Mode 5/6 boron concentration was increased by 50 ppm.

Based on the results of this evaluation, it was determined that the minimum BAT boron concentration needed to meet shutdown margin requirements is 6600 ppm. The licensee believes that increasing the minimum BAT concentration to 6600 ppm at this time should ensure that shutdown margin requirements will be

9505240161 950517 PDR ADOCK 05000423 P PDR PDR maintained for subsequent cycles. This will avoid additional increases if future operations and core loading are similar to that of Cycle 6.

The licensee is proposing to increase the current BAT minimum concentration from 6300 ppm to a value of 6600 ppm. This implementation is achieved by changes to the following TSs.

Section 3.1.1.1.1 Shutdown Margin - Modes 1 and 2 Section 3.1.1.1.2 Shutdown Margin - Modes 3,4, and 5 - Loops filled Section 3.1.1.2 Shutdown Margin - Cold Shutdown - Loops not Filled Section 3.1.2.5 Borated Water Source - Shutdown Section 3.1.2.6 Borated Water Sources - Operating Section 3.9.1.1 Boron Concentration Section 3.10.1 Shutdown Margin Bases Section 3/4 1.2 Boration Systems

Increasing the required minimum BAT concentration from 6300 ppm to 6600 ppm enhances plant safety. The methods used to calculate the cycle-specific boron limit have been previously reviewed by the staff and have been approved. The proposed changes to TSs for Millstone 3 are acceptable to the staff.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Connecticut State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (60 FR 8753). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: G. Schwenk

Date: May 17, 1995