

December 13, 1990

Docket No. 50-423

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT -
APPLICATION FOR LICENSE AMENDMENT CONCERNING CONTAINMENT PRESSURE-
MILLSTONE UNIT 3 (TAC 76066)

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact which relates to your request for license amendment, dated February 26, 1990, as supplemented April 30, 1990 regarding changes in the Technical Specifications which are required in order to allow an increase in normal containment operating pressure to a maximum of 14.0 psia.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

151
David H. Jaffe, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION	Docket File	NRC PDR & Local PDR	Plant File
S. Varga (14E4)	E. Greenman	J. Stolz	S. Norris
D. Jaffe	OGC	E. Jordan (MNBB 3302)	ACRS (10)
GPA/PA	E. Wenzinger (Region I)		LCunningham (11D4)

OFC	:LA:PDI-4	:PM:PDI-4	:PD:PDI-4	:BC:RPB	:OGC	:
NAME	:SNorris	:DJaffe:lm	:JStolz	:LCunningham	:bmb	:
DATE	:11/8/90	:11/15/90	:11/30/90	:11/ /90	:11/03/90	:

OFFICIAL RECORD COPY
Document Name: TAC 76066

170013

9012190213 901213
PDR ADDCK 05000423
PDR

DF01
DAB

Mr. E. J. Mrocza
Northeast Nuclear Energy Company

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

S. E. Scace, Nuclear Station Director
Millstone Nuclear Power Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

C. H. Clement, Nuclear Unit Director
Millstone Unit No. 3
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Ms. Jane Spector
Federal Energy Regulatory Commission
825 N. Capitol Street, N.E.
Room 8608C
Washington, D.C. 20426

Burlington Electric Department
c/o Robert E. Fletcher, Esq.
271 South Union Street
Burlington, Vermont 05402

Millstone Nuclear Power Station
Unit No. 3

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector
Millstone Nuclear Power Station
c/o U. S. Nuclear Regulatory Commission
Post Office Box 811
Niantic, Connecticut 06357

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

Mr. Alan Menard, Manager
Technical Services
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

UNITED STATES NUCLEAR REGULATORY COMMISSIONNORTHEAST NUCLEAR ENERGY COMPANY- MILLSTONE NUCLEAR POWER STATION, UNIT NO 3DOCKET NO. 50-423ENVIRONMENTAL ASSESSMENT AND FINDING OFNO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of a license amendment to Northeast Nuclear Energy Company, et al. (the licensee) for the Millstone Nuclear Power Station, Unit No 3, located at the licensee's site in New London County, Connecticut.

ENVIRONMENTAL ASSESSMENTIdentification of Proposed Action:

The proposed amendment would modify the Technical Specifications (TS) to allow an increase in the normal containment pressure range; the proposed range is 10.6 psia to 14.0 psia. The current containment pressure range has a lower value of 8.9 psia with a variable upper value, depending upon service water temperature, up to approximately 10.6 psia.

The Need for the Proposed Action:

The license amendment is needed to eliminate the need for supplemental oxygen for workers, to reduce the potential for personnel injury when entering containment due to pressure changes and to permit more expedient entry into the containment for inspection and problem resolution.

Assessment:

The licensee addressed the environmental impacts of the proposed action in the application dated February 26, 1990 and a supplement dated April 30, 1990.

The NRC staff has evaluated the effect of the proposed increase in normal containment pressure on post-Loss of Coolant Accident (LOCA), offsite doses.

Using the proposed containment leak rates with a full credit allowed for iodine removal by the containment spray and the assumptions and parameters in Table 15.2 of Millstone Unit 3 Safety Evaluation Report (NUREG-1031 dated July 1984), the staff computed the offsite doses for the Millstone Unit 3 Exclusion Area (EAB) and Low Population Zone (LPZ) boundaries. The computed offsite doses are within the acceptance criteria given in Section 15.7.5 of the Standard Review Plan (SRP) and the exposure guidelines of 10 CFR Part 100.

With regard to normal station effluents, the Millstone Unit No. 3 containment would still be maintained at a negative pressure of approximately 1 psig. Hence, there will be no leakage of airborne radioactivity from the containment during normal power operations. The only potential effect of the changes will be a reduction in the amount of radioactivity released during containment drawdowns (containment pressure reduction). This results from the reduced time required to draw a 1 psig negative pressure compared to the time required for the current, more negative containment pressure, and the reduced probability of requiring additional drawdowns. This benefit is expected to be negligible as containment drawdowns currently represent a small percent of normal station effluents.

Based upon the above, the licensee concluded, and the NRC staff concurs, that the proposed changes result in a decrease in normal station effluents and computed offsite doses within the acceptance criteria of SRP 15.7.5 and the exposure guidelines of 10 CFR 100. The proposed changes would not affect

any other evaluations as presented in the Final Environmental Statement (NUREG-1064 dated December 1984). Therefore, the proposed changes have no negative environmental impact.

Alternative to the Proposed Action:

It has been concluded that there is no measurable impact associated with the proposed exemption; any alternatives to the exemption would have either essentially the same or greater environmental impact.

Alternative Use of Resources:

This action does not involve the use of any resources different from or beyond the scope of resources used during normal plant operation, which were assessed in the Final Environmental Statement relating to plant operation.

Agencies and Persons Consulted:

The Commission's staff reviewed the licensee's request that supports the proposed exemption. The staff did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT


Based upon the foregoing environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed amendment.

For further details with respect to this action, see the request for license amendment dated February 26, 1990 and the supplement dated April 30, 1990. A copy is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW, Washington, D.C. 20555,

and at the local public document room located at the Learning Resources Center,
Thames Valley State Technical College, 574 New London Turnpike, Norwich,
Connecticut 06360.

Dated at Rockville, Maryland this 13th day of December 1990.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation