

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. Required Action and associated Completion Time of Condition A not met in MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS.</p>	<p>D.1 Place OPERABLE CRAVS train in operation.</p> <p><u>OR</u></p> <p>D.2.1 Suspend CORE ALTERATIONS.</p> <p><u>AND</u></p> <p>D.2.2 Suspend movement of irradiated fuel assemblies.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>E. Two CRAVS trains inoperable in MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS.</p>	<p>E.1 Suspend CORE ALTERATIONS.</p> <p><u>AND</u></p> <p>E.2 Suspend movement of irradiated fuel assemblies.</p>	<p>Immediately</p> <p>Immediately</p>
<p>F. Two CRAVS trains inoperable in MODE 1, 2, 3, or 4 for reasons other than Condition B.</p>	<p>F.1 Enter LCO 3.0.3.</p>	<p>Immediately</p> <p>(continued)</p>

B 3.7 PLANT SYSTEMS

B 3.7.10 Control Room Area Ventilation System (CRAVS)

BASES

BACKGROUND

The CRAVS ensures that the control room will remain habitable for personnel during and following all credible accident conditions. This function is accomplished by pressurizing the control room to $\geq 1/8$ (0.125) inch water gauge with respect to all surrounding areas, filtering the outside air used for pressurization, and filtering a portion of the return air from the control room to clean up the control room environment.

The CRAVS consists of two independent, redundant trains of equipment. Each train consists of:

- a pressurizing filter train fan (1CRA-PFTF-1 or 2CRA-PFTF-1)
- a filter unit (1CRA-PFT-1 or 2CRA-PFT-1) which includes moisture separator/prefilters, HEPA filters, and carbon adsorbers
- the associated ductwork, dampers/valves, and controls

Inherent in the CRAVS ability to pressurize the control room is the control room pressure boundary. This pressure boundary includes: (1) the control room walls, floor, roof, doors, and all penetrations of those, (2) any piping or ductwork which penetrates into the control room, and (3) the control room ventilation system proper consisting of ductwork, filter units, dampers, and fans. These boundaries must be intact or properly isolated for the CRAVS to function properly.

The CRAVS can be operated either manually or automatically. Key operated selector switches located in the control room initiate operation of all train related CRAVS equipment. The selected train is in continuous operation. Outside air for pressurization and makeup to the control room is supplied from two independent intakes. This outside air is mixed with return air from the control room before being passed through the filter unit. In the filter unit, moisture separator/prefilters remove any large particles in the air, and any entrained water droplets present, to prevent excessive loading of the HEPA filters and carbon adsorbers. Continuous operation of each train for at least 10 hours per month, with the heaters on, reduces moisture buildup on the HEPA filters and adsorbers.

Upon receipt of an Engineered Safety Feature (ESF) signal, the selected CRAVS train continues to operate and the pressurizing filter train fan of

BASES

BACKGROUND (continued)

the non-selected train is started. This assures control room pressurization, assuming an active failure of one of the pressurizing filter train fans.

The outside air for pressurization is continuously monitored for the presence of smoke, radiation, or chlorine by non-safety related detectors. If smoke, radiation, or chlorine is detected in an outside air intake, an alarm is received in the control room, alerting the operators of this condition. The operator will take the required action to close the affected intake, if necessary, per the guidance of the Annunciator Response Procedures.

A single CRAVS train is capable of pressurizing the control room to greater than or equal to 0.125 inches water gauge. The CRAVS is designed in accordance with Seismic Category 1 requirements. The CRAVS operation in maintaining the control room habitable is discussed in the UFSAR, Sections 6.4 and 9.4.1 (Refs. 1 and 2).

The CRAVS is designed to maintain the control room environment for 30 days of continuous occupancy after a Design Basis Accident (DBA) without exceeding a 5 rem whole body dose or its equivalent to any part of the body.

APPLICABLE
SAFETY ANALYSES

The CRAVS components are arranged in redundant, safety related ventilation trains. The CRAVS provides airborne radiological protection for the control room operators, as demonstrated by the control room accident dose analyses for the most limiting design basis loss of coolant accident, fission product release presented in the UFSAR, Chapter 15 (Ref. 3).

The analysis of toxic gas releases demonstrates that the toxicity limits are not exceeded in the control room following a toxic chemical release, as presented in Reference 1.

The worst case single active failure of a component of the CRAVS, assuming a loss of offsite power, does not impair the ability of the system to perform its design function.

The CRAVS satisfies Criterion 3 of 10 CFR 50.36 (Ref. 4).

LCO

Two independent and redundant CRAVS trains are required to be

BASES

LCO (continued)

OPERABLE to ensure that at least one is available assuming a single failure disables the other train. Total system failure could result in exceeding a dose of 5 rem to the control room operator in the event of a large radioactive release.

The CRAVS is considered OPERABLE when the individual components necessary to limit operator exposure are OPERABLE in both trains. A CRAVS train is OPERABLE when the associated:

- a. Pressurizing filter train fan is OPERABLE;
- b. HEPA filters and carbon adsorbers are not excessively restricting flow, and are capable of performing their filtration functions; and
- c. Ductwork, valves, and dampers are OPERABLE, and air circulation can be maintained.

In addition, the control room pressure boundary must be maintained, including the integrity of the walls, floors, roof, ductwork, and access doors.

The CRAVS is shared between the two units. The system must be OPERABLE for each unit when that unit is in the MODE of Applicability. Additionally, both normal and emergency power must also be OPERABLE because the system is shared. If a CRAVS component becomes inoperable, or normal or emergency power to a CRAVS component becomes inoperable, then the Required Actions of this LCO must be entered independently for each unit that is in the MODE of applicability of the LCO.

The LCO is modified by a Note allowing the control room pressure boundary to be opened intermittently under administrative controls. For entry and exit through doors, the administrative control of the opening is performed by the person(s) entering or exiting the area. For other openings, these controls consist of stationing a dedicated individual at the opening who is in continuous communication with the control room. This individual will have a method to rapidly close the opening when a need for control room pressure boundary isolation is indicated.

APPLICABILITY	In MODES 1, 2, 3, 4, 5, and 6, and during movement of irradiated fuel assemblies and during CORE ALTERATIONS, CRAVS must be OPERABLE to control operator exposure during and following a DBA.
---------------	---

BASES

ACTIONS (continued)

D.1, D.2.1, and D.2.2

In MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS, if the inoperable CRAVS train cannot be restored to OPERABLE status within the required Completion Time, action must be taken to immediately place the OPERABLE CRAVS train in operation. This action ensures that the operating (or running) train is OPERABLE, that no failures preventing automatic actuation will occur, and that any active failure would be readily detected.

An alternative to Required Action D.1 is to immediately suspend activities that could result in a release of radioactivity that might enter the control room. This places the unit in a condition that minimizes risk. This does not preclude the movement of fuel to a safe position.

E.1 and E.2

In MODE 5 or 6, or during movement of irradiated fuel assemblies, or during CORE ALTERATIONS, with two CRAVS trains inoperable, action must be taken immediately to suspend activities that could result in a release of radioactivity that might enter the control room. This places the unit in a condition that minimizes accident risk. This does not preclude the movement of fuel to a safe position.

F.1

If both CRAVS trains are inoperable in MODE 1, 2, 3, or 4, for reasons other than Condition B, the CRAVS may not be capable of performing the intended function and the unit is in a condition outside the accident analyses. Therefore, LCO 3.0.3 must be entered immediately.

G.1 and G.2

With one or more CRAVS heaters inoperable, the heater must be restored to OPERABLE status within 7 days. Alternatively, a report must be initiated per Specification 5.6.6, which details the reason for the heater's inoperability and the corrective action required to return the

BASES

ACTIONS (continued)

heater to OPERABLE status.

The heaters do not affect OPERABILITY of the CRAVS filter trains because charcoal adsorber efficiency testing is performed at 30°C and 95% relative humidity. The accident analysis shows that site boundary radiation doses are within 10 CFR 100 limits during a DBA LOCA under these conditions.

SURVEILLANCE — SR 3.7.10.1
REQUIREMENTS

Standby systems should be checked periodically to ensure that they function properly. As the environment and normal operating conditions on this system are not too severe, testing each train once every month provides an adequate check of this system. Monthly heater operations dry out any moisture accumulated in the carbon from humidity in the ambient air. Systems with heaters must be operated from the control room for ≥ 10 continuous hours with the heaters energized and flow through the HEPA filters and charcoal adsorbers. The 31 day Frequency is based on the reliability of the equipment and the two train redundancy availability.

SR 3.7.10.2

This SR verifies that the required CRAVS testing is performed in accordance with the Ventilation Filter Testing Program (VFTP). The CRAVS filter tests are in accordance with Regulatory Guide 1.52 (Ref. 5). The VFTP includes testing the performance of the HEPA filter and carbon adsorber efficiencies and the physical properties of the activated carbon. Specific test Frequencies and additional information are discussed in detail in the VFTP.

SR 3.7.10.3

This SR verifies that each CRAVS train starts and operates on an actual or simulated actuation signal. The Frequency of 18 months is specified in Regulatory Guide 1.52 (Ref. 5).

BASES

SURVEILLANCE REQUIREMENTS (continued)SR 3.7.10.4

This SR verifies the integrity of the control room enclosure, and the assumed inleakage rate (or makeup rate) assumed in the dose analysis. The control room positive pressure, with respect to potentially contaminated adjacent areas, is periodically tested to verify proper functioning of the CRAVS. The CRAVS is designed to pressurize the control room ≥ 0.125 inches water gauge positive pressure with respect to adjacent areas in order to prevent unfiltered inleakage. The CRAVS is designed to maintain this positive pressure with one train at a makeup flow rate of ≤ 4000 cfm. The Frequency of 18 months on a STAGGERED TEST BASIS is consistent with the guidance provided in NUREG-0800 (Ref. 6).

REFERENCES

1. UFSAR, Section 6.4.
2. UFSAR, Section 9.4.1
3. UFSAR, Chapter 15.
4. 10 CFR 50.36, Technical Specifications, (c)(2)(ii).
5. Regulatory Guide 1.52, Rev. 2.
6. NUREG-0800, Section 6.4, Rev. 2, July 1981.