

December 6, 1993

Docket No. 50-423

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING
LICENSE, AND OPPORTUNITY FOR A HEARING - MILLSTONE UNIT 3
(TAC NO. M88290)

The Commission has requested the Office of the Federal Register to publish the
enclosed "Notice of Consideration Issuance of Amendment to Facility Operating
License and Opportunity for Hearing."

The notice relates to your application dated November 24, 1993. The proposed
amendment to the Technical Specification would reduce the minimum reactor coolant
system flow rate from 387,480 gpm to 371,920, with corresponding changes in loop
flow.

Sincerely,

Original signed by:

Vernon L. Rooney, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File OPA
NRC & Local PDRs OC/LFDCB
PDI-4 Plant LDoerflein, RI
SVarga
JCalvo
JStolz
SNorris
V Rooney
OGC
DHagan
ACRS (10)

9312150322 931206
PDR ADOCK 05000423
P PDR

NRC FILE CENTER COPY

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME	SNorris:bp	V Rooney:bp	JStolz		
DATE	12/6/93	12/6/93	12/6/93	1/1	1/1

OFFICIAL RECORD COPY

Document Name: G:\INOT88290

December 6, 1993

Docket No. 50-423

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING
LICENSE, AND OPPORTUNITY FOR A HEARING - MILLSTONE UNIT 3
(TAC NO. M88290)

The Commission has requested the Office of the Federal Register to publish the
enclosed "Notice of Consideration Issuance of Amendment to Facility Operating
License and Opportunity for Hearing."

The notice relates to your application dated November 24, 1993. The proposed
amendment to the Technical Specification would reduce the minimum reactor coolant
system flow rate from 387,480 gpm to 371,920, with corresponding changes in loop
flow.

Sincerely,

Original signed by:

Vernon L. Rooney, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File OPA
NRC & Local PDRs OC/LFDCB
PDI-4 Plant LDoerflein, RI
SVarga
JCalvo
JStolz
SNorris
V Rooney
OGC
DHagan
ACRS (10)

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME	SNorris:bp	V Rooney:bp	JStolz		
DATE	12/6/93	12/6/93	12/6/93	1/1	1/1

OFFICIAL RECORD COPY

Document Name: G:\INOT88290



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 6, 1993

Docket No. 50-423

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING
LICENSE, AND OPPORTUNITY FOR A HEARING - MILLSTONE UNIT 3
(TAC NO. M88290)

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration Issuance of Amendment to Facility Operating License and Opportunity for Hearing."

The notice relates to your application dated November 24, 1993. The proposed amendment to the Technical Specification would reduce the minimum reactor coolant system flow rate from 387,480 gpm to 371,920, with corresponding changes in loop flow.

Sincerely,

A handwritten signature in black ink, appearing to read "V. L. Rooney", is written over a horizontal line.

Vernon L. Rooney, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 3

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. M. Solymossy, Director
Nuclear Quality & Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, Connecticut 06106-5127

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

F. R. Dacimo, Nuclear Unit Director
Millstone Unit No. 3
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

Burlington Electric Department
c/o Robert E. Fletcher, Esq.
271 South Union Street
Burlington, Vermont 05402

David W. Graham
Fuel Supply Planning Manager
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

UNITED STATES NUCLEAR REGULATORY COMMISSIONNORTHEAST NUCLEAR ENERGY COMPANYDOCKET NO. 50-423NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-49, issued to Northeast Nuclear Energy Company (the licensee), for operation of the Millstone Nuclear Power Station, Unit No. 3 located in New London County, Connecticut.

The proposed amendment would revise the technical specifications to reduce the minimum reactor coolant system flow rate from 387,480 gpm to 371,920 gpm, with corresponding changes in loop flow.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By January 12, 1994, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current

copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555 and at the local public document room located at the Learning Resources Center, Thames Valley State Technical College, 574 New London Turnpike, Norwich, Connecticut 06360. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days

prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to John F. Stolz: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to Gerald Garfield, Esquire, Day, Berry & Howard, City Place, Hartford, Connecticut 06103-3499, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the

completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated November 24, 1993, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, and at the local public document room located at the Learning Resources Center, Thames Valley State Technical College, 574 New London Turnpike, Norwich, Connecticut 06360.

Dated at Rockville, Maryland, this 6th day of December 1993.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "John F. Stolz", is written over the typed name and title.

John F. Stolz, Director
Project Directorate
Division of Reactor Projects -
Office of Nuclear Reactor Regulation