

August 7, 1998

Mr. Martin L. Bowling, Jr.  
Recovery Officer - Technical Services  
Northeast Nuclear Energy Company  
c/o Ms. Patricia A. Loftus  
Director - Regulatory Affairs  
P. O. Box 128  
Waterford, CT 06385

SUBJECT: ISSUANCE OF AMENDMENT - MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3 (TAC NO. MA0661)

Dear Mr. Bowling:

The Commission has issued the enclosed Amendment No. 162 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 22, 1998, as supplemented July 17, 1998.

The amendment revises the Millstone Unit 3 licensing basis to accept the existing use of epoxy coatings on safety related components. The revised licensing basis will be incorporated into Chapter 9 of the Final Safety Analysis Report.

The Commission has amended the Facility Operating License to include an Appendix C, which is a list of additional license conditions. This is an administrative action by the NRC that only involves the format of the License and does not authorize any activities outside the scope of the January 22, 1998, application. The license condition was agreed to and documented in Northeast Nuclear Energy Company's letter dated July 17, 1998, in order to grant approval of the license amendment.

Please notify the Commission, by letter, upon satisfying the condition in Appendix C of the Millstone Unit 3 Facility Operating License.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by: S. Dembek for/  
James W. Andersen, Project Manager  
Special Projects Office - Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosures: 1. Amendment No. 162 to NPF-49  
2. Safety Evaluation

cc w/encls: See next page

**DISTRIBUTION:**

Docket File THarris (e-mail SE)  
PUBLIC WBeckner  
SPO-L RF DScenci, RI (e-mail)  
SPO RF GHill (2)  
Elmbro JDurr, RI  
WDean LBerry  
JAndersen OGC ACRS

1/1  
DFol

DOCUMENT NAME: G:\ANDERSEN\MA0661.AMD

\*see previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy w/o encl "E" = Copy w/encl "N" = No copy

OFFICE	SPO-L:PM	SPO-L:LA	E	*OGC	SPO-L:DD
NAME	JAndersen	LBerry		RBachmann	WDean
DATE	01 7 198	8 1 6 198		07/27/98	08/ 07 198

OFFICIAL RECORD COPY

9808120294 980807  
PDR ADOCK 05000423  
P PDR

FOR FILE CONTROL COPY

CP-1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 7, 1998

Mr. Martin L. Bowling, Jr.  
Recovery Officer - Technical Services  
Northeast Nuclear Energy Company  
c/o Ms. Patricia A. Loftus  
Director - Regulatory Affairs  
P. O. Box 128  
Waterford, CT 06385

SUBJECT: ISSUANCE OF AMENDMENT - MILLSTONE NUCLEAR POWER STATION,  
UNIT NO. 3 (TAC NO. MA0661)

Dear Mr. Bowling:

The Commission has issued the enclosed Amendment No. 162 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated January 22, 1998, as supplemented July 17, 1998.


The amendment revises the Millstone Unit 3 licensing basis to accept the existing use of epoxy coatings on safety related components. The revised licensing basis will be incorporated into Chapter 9 of the Final Safety Analysis Report.

The Commission has amended the Facility Operating License to include an Appendix C, which is a list of additional license conditions. This is an administrative action by the NRC that only involves the format of the License and does not authorize any activities outside the scope of the January 22, 1998, application. The license condition was agreed to and documented in Northeast Nuclear Energy Company's letter dated July 17, 1998, in order to grant approval of the license amendment.

Please notify the Commission, by letter, upon satisfying the condition in Appendix C of the Millstone Unit 3 Facility Operating License.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

  
James W. Andersen, Project Manager  
Special Projects Office - Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosures: 1. Amendment No. 162 to NPF-49  
2. Safety Evaluation

cc w/encls: See next page

Millstone Nuclear Power Station  
Unit 3

cc:

Lillian M. Cuoco, Esquire  
Senior Nuclear Counsel  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, CT 06141-0270

Mr. Kevin T. A. McCarthy, Director  
Monitoring and Radiation Division  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, CT 06385

Mr. Wayne D. Lanning  
Deputy Director of Inspections  
Special Projects Office  
475 Allendale Road  
King of Prussia, PA 19406-1415

Mr. M. H. Brothers  
Vice President - Millstone Unit 3  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. M. R. Scully, Executive Director  
Connecticut Municipal Electric  
Energy Cooperative  
30 Stott Avenue  
Norwich, CT 06360

Mr. David Amerine  
Vice President - Human Services  
Northeast Utilities Service Company  
P. O. Box 128  
Waterford, CT 06385

Joseph R. Egan, Esquire  
Egan & Associates, P.C.  
2300 N Street, NW  
Washington, DC 20037

Mr. F. C. Rothen  
Vice President - Work Services  
Northeast Utilities Service Company  
P. O. Box 128  
Waterford, CT 06385

Ernest C. Hadley, Esquire  
1040 B Main Street  
P.O. Box 549  
West Wareham, MA 02576

Mr. John Buckingham  
Department of Public Utility Control  
Electric Unit  
10 Liberty Square  
New Britain, CT 06051

Mr. James S. Robinson, Manager  
Nuclear Investments and Administration  
New England Power Company  
25 Research Drive  
Westborough, MA 01582

Mr. John Streeter  
Recovery Officer - Nuclear Oversight  
Northeast Utilities Service Company  
P. O. Box 128  
Waterford, CT 06385

Deborah Katz, President  
Citizens Awareness Network  
P.O. Box 83  
Shelburne Falls, MA 03170

Mr. Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning  
Division  
450 Capitol Avenue - MS# 52ERN  
P. O. Box 341441  
Hartford, CT 06134-1441

Millstone Nuclear Power Station  
Unit 3

cc:

The Honorable Terry Concannon  
Nuclear Energy Advisory Council  
Room 4035  
Legislative Office Building  
Capitol Avenue  
Hartford, CT 06106

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Mr. John W. Beck, President  
Little Harbor Consultants, Inc.  
Millstone - ITPOP Project Office  
P.O. Box 0630  
Niantic, CT 06357-0630

Mr. B. D. Kenyon (Acting)  
Chief Nuclear Officer - Millstone  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. Daniel L. Curry  
Project Director  
Parsons Power Group Inc.  
2675 Morgantown Road  
Reading, PA 19607

Mr. Don Schopfer  
Verification Team Manager  
Sargent & Lundy  
55 E. Monroe Street  
Chicago, IL 60603

Mr. P. D. Hinnenkamp  
Director - Unit 3  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Senior Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 513  
Niantic, CT 06357

Mr. William D. Meinert  
Nuclear Engineer  
Massachusetts Municipal Wholesale  
Electric Company  
P.O. Box 426  
Ludlow, MA 01056

Attorney Nicholas J. Scobbo, Jr.  
Ferriter, Scobbo, Caruso, Rodophele, PC  
1 Beacon Street, 11th Floor  
Boston, MA 02108

Citizens Regulatory Commission  
ATTN: Ms. Susan Perry Luxton  
180 Great Neck Road  
Waterford, CT 06385



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

DOCKET NO. 50-423

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 162  
License No. NPF-49

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated January 22, 1998, as supplemented July 17, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


9808120297 980807  
PDR ADOCK 05000423  
P PDR

2. Accordingly, the license is amended to authorize revision of the Final Safety Analysis Report (FSAR) as set forth in the application for amendment by the licensee, dated January 22, 1998, as supplemented July 17, 1998. The licensee shall update the FSAR to reflect the use of epoxy coatings on safety-related components.

In addition, the license is amended to add the following paragraph to 2.C. to Facility Operating License No. NPF-49.

- (5) The Additional Conditions contained in Appendix C, as revised through Amendment No. 162 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the additional conditions.
3. This license amendment is effective as of the date of issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



William M. Dean  
Deputy Director for Licensing  
Special Projects Office  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Facility  
Operating License

Date of Issuance: August 7, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 162

TO FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Facility Operating License with the enclosed pages. The revised areas are indicated by marginal lines.

Remove

3

9

-

Insert

3

9

Appendix C

(Next Page is 8)

- (3) NNECO, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use at any time any byproducts, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required:
  - (4) NNECO, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use in amounts as required any byproducts, source, or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
  - (5) NNECO, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operations of the facility.
- c. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provision of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
- (1) Maximum Power Level  
Northeast Nuclear Energy Company is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100 percent rated power) in accordance with the conditions specified herein.
  - (2) Technical Specifications  
The technical specifications contained in Appendix A revised through Amendment No. 162, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Northeast Nuclear Energy Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
  - (3) DELETED
  - (4) DELETED
  - (5) The Additional Conditions contained in Appendix C, as revised through Amendment No. 162, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the additional conditions.



The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- I. This license is effective as of the date of issuance and shall expire at Midnight on November 25, 2025.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by H.R. Denton

Harold R. Denton, Director  
Office of Nuclear Reactor Regulation

Attachments/Appendices:

1. Appendix A - Technical Specifications (NUREG-1176)
2. Appendix B - Environmental Protection Plan
3. Appendix C - Additional Conditions

Date of Issuance: January 31, 1986

APPENDIX C

ADDITIONAL CONDITIONS  
OPERATING LICENSE NO. NPF-49

Northeast Nuclear Energy Company (NNECO) shall comply with the following conditions on the schedules noted below:

<u>Amendment Number</u>	<u>Additional Condition</u>	<u>Condition Completion Date</u>
162	Millstone Unit No. 3 will incorporate the changes into the Final Safety Analysis Report (FSAR) as requested by letter dated January 22, 1998, as supplemented by letter dated July 17, 1998, that accepts the use of epoxy coatings on service water system components. Future changes to the design described in this submittal may be made in accordance with the provisions of 10 CFR 50.59.	During the next revision of the FSAR required by 10 CFR 50.71(e) or no later than June 30, 1999.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20565-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 162

TO FACILITY OPERATING LICENSE NO. NPF-49

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3

DOCKET NO. 50-423

1.0 INTRODUCTION

By letter dated January 22, 1998, as supplemented by letter dated July 17, 1998, the Northeast Nuclear Energy Company, et al. (the licensee), submitted a request for a change to the Millstone Nuclear Power Station, Unit 3 design basis. The requested change would revise the Millstone Unit 3 licensing basis to accept the existing use of epoxy coatings on safety-related components. The July 17, 1998, supplement provided clarifying information that did not change the scope of the January 22, 1998, application and the initial proposed no significant hazards consideration determination.

2.0 BACKGROUND

ARCOR epoxy coatings are applied to the inside diameter of large bore service water system (SWS) piping, heat exchanger channel heads, and some pump and valve components. The purpose of the coating material is to protect the surface of the substrate material from erosion and corrosion. In a previous analysis, the licensee assumed that the ARCOR epoxy coatings were unlikely to fail, but if they did fail, they would do so in small chips. Recent experience has shown that the ARCOR epoxy coatings can fail in large sheets. The licensee conducted a root cause evaluation that indicated that these failures were a result of improper application of the epoxy coatings. The application parameters have been modified and documented to reduce the probability of future failures. The licensee is proposing to modify Chapter 9 of the Final Safety Analysis Report (FSAR) to describe the use of epoxy coatings in the SWS piping and is proposing periodic surveillances to monitor coating degradation and heat exchanger performance.

3.0 EVALUATION

3.1 NRC Requirements and Regulatory Guidance

Nuclear power plants, such as Millstone Unit 3, whose construction permits were issued after May 21, 1971, are designed to meet minimum requirements established in general design criteria (GDC) specified in 10 CFR Part 50, Appendix A. GDC 44, "Cooling Water," requires

that a service water system exists to transfer heat from structures, systems, and components important to safety to an ultimate heat sink. GDC 45, "Inspection of Cooling Water System," requires the system be designed to permit appropriate periodic inspection of important components, such as heat exchangers and piping, to ensure the integrity and capability of the system. GDC 46, "Testing of Cooling Water System," requires the system be designed to permit appropriate periodic pressure and functional testing of the service water system.

Generic Letter (GL) 89-13, "Service Water System Problems Affecting Safety-Related Equipment," dated July 18, 1989, deals specifically with service water problems. GL 89-13 recommends the establishment of a routine maintenance program to ensure adequate performance of safety-related systems cooled by service water. This includes the repair of defective protective coating systems that could potentially impair the heat transfer capability of safety-related heat exchangers cooled by service water.

On March 24, 1997, the staff issued NRC Information Notice (IN) 97-13, "Deficient Conditions Associated with Protective Coatings at Nuclear Power Plants." This IN describes the ARCOR failure at Millstone Unit 3 along with other protective coating failures. The IN states that industry standards for coatings as well as vendor instructions and recommendations provide guidance pertaining to various aspects of coating such as surface preparation, temperature control, humidity control, timing requirements for multiple coating applications, application methods, and personnel qualification and training requirements.

### 3.2 Licensee's Proposed Change

The licensee proposed to change the FSAR to include a description of the use of epoxy coatings on the interior of large bore SWS piping, heat exchanger channel heads, and some pump and valve components. The change includes a discussion on the use of periodic surveillance to monitor coating degradation and heat exchanger performance.

The licensee stated that the preponderance of evidence indicated that the ARCOR material in the SWS is unlikely to fail, but if it does fail, it will fail as chips. However, the licensee further stated that there is also evidence that ARCOR material can fail by delamination if it is not properly applied. It can fail by the top coat delaminating from the base coat or by delamination of the base coat from the carbon steel pipe or component surface. A single sheet of ARCOR was retrieved that was 2 ft<sup>2</sup>. Another 15 ft<sup>2</sup> area was discovered missing the top coat. It is not known if this area delaminated and then broke up into smaller chips or if it failed as chips.

In the January 22, 1998, submittal, the licensee provided its conclusions about the effect of ARCOR material failure on the various components in the SWS. The licensee concluded that coating failure will not adversely affect the performance of SWS pumps or valves. Each SWS train has two small booster pumps that are not likely to be a primary flow path for system debris. Any material that enters the pumps would be fragmented and would not likely result in degraded pump performance for any extended time. The active valves in the SWS are mostly large butterfly valves with rubber seats which are not susceptible to positioning problems due to ARCOR pieces. The licensee looked at flow orifices and concluded that flow orifices in lines less than 2 inches in diameter could become plugged with failed ARCOR coating. The licensee postulated that this could occur in the emergency diesel generator heat exchanger bypass flow

line; however, the licensee stated that if this bypass line were to become clogged, it would not affect the operability of the diesel generators. Since there is no flow through pressure and temperature indicators in the SWS, the licensee determined that flow-related blockage of temperature and pressure indicators is not a concern. The licensee conducted a review of flow-related instrumentation signals and the review indicated that there are no automatic actions/signals which could be adversely affected by blockage caused by ARCOR material.

The licensee conducted an engineering evaluation to determine what equipment important to safety could be affected by the proposed change in the FSAR. The main finding was that only a small fraction of the ARCOR material would have to fail to cause blockage, which exceeds currently analyzed plugging limits and/or flow margins for heat exchangers. Equipment supported by the SWS whose functionality is potentially degraded by released ARCOR material includes emergency diesel generators, safety injection pumps, charging pumps, containment recirculation heat exchangers, reactor plant component cooling water heat exchangers, residual heat removal, quench spray, safety injection pump ventilation units, containment recirculation pump ventilation units, and control room chillers.

The licensee stated that the primary root cause of the ARCOR failures was improper environmental controls placed on the application process. The corrective action was to replace a significant portion of the coatings using a modified coating procedure that has strict environmental controls on the application process. ARCOR coatings that were not replaced were X-cut tested to differentiate sound coating from disbonded material.

The licensee proposed conducting weekly heat exchanger performance surveillance's to minimize the potential for disbonded ARCOR coating to degrade SWS components. The frequency of the surveillance's is based on GL 89-13 commitments. The frequencies have been modified based on actual system performance and inspection results. Results to date indicate that the present steps are adequate to find developing problems.

The licensee concluded that the application of ARCOR within the SWS is acceptable because (1) strict procedural controls have been placed on new ARCOR applications; (2) as-left coatings will be tested using a more effective method; (3) frequent monitoring and surveillance of SWS heat exchangers for tubesheet fouling will detect coating degradation; and (4) a coating failure assessment and impact determination procedure has been developed to ensure that the SWS heat exchangers remain operable.

### 3.3 Staff Evaluation

The staff concludes that the proposed revision to the FSAR to permit the application of ARCOR material on the inside surfaces of large bore SWS piping, heat exchanger channel heads, and some pump and valve components is acceptable. This conclusion is based on that (1) a sample of the existing ARCOR coating has been tested for bond of the top coat to the base coat and base coat to the substrate; (2) any defective coating detected in this manner has been removed and new ARCOR coating has been applied using the new application procedures; (3) a monitoring and surveillance program has been established for safety-related SWS heat exchangers that will detect coating degradation; and (4) the licensee has developed a coating

failure assessment and impact determination procedure to ensure that the SWS heat exchangers remain operable.

#### 4.0 LICENSEE COMMITMENTS RELIED UPON

By letter dated July 17, 1998, the licensee committed to incorporate the changes requested in the January 22, 1998, letter into the Millstone Unit 3 FSAR. The licensee committed to incorporate the changes during the next revision of the FSAR required by 10 CFR 50.71(e) or no later than June 30, 1999. The NRC staff finds this commitment and schedule acceptable and has placed it in Appendix C of the Millstone Unit 3 Facility Operating License. The licensee must notify the staff, in writing, when the condition in Appendix C is satisfied.

#### 5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Connecticut State official was notified of the proposed issuance of the amendment. The State official had no comments.

#### 6.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (63 FR 9606 dated February 25, 1998). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### 7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner; (2) such activities will be conducted in compliance with the Commission's regulations; and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: J. Davis

Date: August 7, 1998