

July 1, 1998

Mr. Martin L. Bowling, Jr.
Recovery Officer - Technical Services
Northeast Nuclear Energy Company PUBLIC
c/o Ms. Patricia A. Loftus
Director - Regulatory Affairs
P. O. Box 128
Waterford, Connecticut 06385

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT 3 - AMENDMENT NO. 160
(TAC NO. MA1421)

Dear Mr. Bowling:

By letter dated May 27, 1998, the Commission issued Amendment No. 160 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated April 7, 1998.

It has come to our attention that the wording in our Safety Evaluation in the second paragraph of Section 2.0 had a number of inaccurate statements. The paragraph should have read (changes made are in bold).

In the April 7, 1998, letter, the licensee proposed to expand the current TS [Technical Specification] 3.4.3 into two separate TS (TS 3.4.3.1 and TS 3.4.3.2). TS 3.4.3.1 will be applicable to Modes 1 and 2. TS Figure 3.4-5 provides the curves of programmed pressurizer level and the operational limits (programmed level +/-6 percent of full scale) for power operation. Limiting Condition for Operation (LCO) 3.4.3.1 requires that the pressurizer water level be maintained at a programmed level +/-6 percent of full scale. **The initial conditions for those transients where pressurizer overfill is a concern (e.g., loss of feedwater, feedwater line break, and inadvertent actuation of safety injection system at power), will bound the proposed TS.** The +/-6 percent of full scale acceptance criterion in the TS **does not cover** the instrumentation uncertainties.

1/0

We regret any inconvenience this may have caused.

Sincerely,
Original signed by:
James W. Andersen, Project Manager
Special Projects Office - Licensing
Office of Nuclear Reactor Regulation

DFU

Docket No. 50-423

cc: See next page

DISTRIBUTION:

Docket File	PMcKee	WBeckner, TSB
PUBLIC	JAndersen	JDurr, RI
SPO-L Reading	LBerry	DScrenci, RI
SPO Reading	OGC	
WTravers	ACRS	

DOCUMENT NAME: G:VANDERSENA1421.COR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	SPO-L:PM	SPO-L:LA	SPO-L:DD		
NAME	JAndersen	LBerry	PMcKee		
DATE	07/1/98	07/1/98	07/1/98	07/1/98	07/1/98

OFFICIAL RECORD COPY

9807060026 980701
PDR ADDCK 05000423
P PDR

NRC FILE CENTER COPY

CP-1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

July 1, 1998

Mr. Martin L. Bowling, Jr.
Recovery Officer - Technical Services
Northeast Nuclear Energy Company
c/o Ms. Patricia A. Loftus
Director - Regulatory Affairs
P. O. Box 128
Waterford, Connecticut 06385

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT 3 - AMENDMENT NO. 160
(TAC NO. MA1421)

Dear Mr. Bowling:

By letter dated May 27, 1998, the Commission issued Amendment No. 160 to Facility Operating License No. NPF-49 for the Millstone Nuclear Power Station, Unit No. 3, in response to your application dated April 7, 1998.

It has come to our attention that the wording in our Safety Evaluation in the second paragraph of Section 2.0 had a number of inaccurate statements. The paragraph should have read (changes made are in bold).

In the April 7, 1998, letter, the licensee proposed to expand the current TS [Technical Specification] 3.4.3 into two separate TS (TS 3.4.3.1 and TS 3.4.3.2). TS 3.4.3.1 will be applicable to Modes 1 and 2. TS Figure 3.4-5 provides the curves of programmed pressurizer level and the operational limits (programmed level +/-6 percent of full scale) for power operation. Limiting Condition for Operation (LCO) 3.4.3.1 requires that the pressurizer water level be maintained at a programmed level +/-6 percent of full scale. **The initial conditions for those transients where pressurizer overflow is a concern (e.g., loss of feedwater, feedwater line break, and inadvertent actuation of safety injection system at power), will bound the proposed TS.** The +/-6 percent of full scale acceptance criterion in the TS does not cover the instrumentation uncertainties.

We regret any inconvenience this may have caused.

Sincerely,

A handwritten signature in black ink, appearing to be "James W. Andersen".

James W. Andersen, Project Manager
Special Projects Office - Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-423

cc: See next page

**Millstone Nuclear Power Station
Unit 3**

cc:

**Lillian M. Cuoco, Esquire
Senior Nuclear Counsel
Northeast Utilities Service Company
P. O. Box 270
Hartford, CT 06141-0270**

**Mr. Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127**

**Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406**

**First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, CT 06385**

**Mr. Wayne D. Lanning
Deputy Director of Inspections
Special Projects Office
475 Allendale Road
King of Prussia, PA 19406-1415**

**Mr. M. H. Brothers
Vice President - Millstone Unit 3
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385**

**Mr. M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, CT 06360**

**Mr. David Amerine
Vice President - Human Services
Northeast Utilities Service Company
P. O. Box 128
Waterford, CT 06385**

**Joseph R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, NW
Washington, DC 20037**

**Mr. F. C. Rothen
Vice President - Work Services
Northeast Utilities Service Company
P. O. Box 128
Waterford, CT 06385**

**Ernest C. Hadley, Esquire
1040 B Main Street
P.O. Box 549
West Wareham, MA 02576**

**Mr. John Buckingham
Department of Public Utility Control
Electric Unit
10 Liberty Square
New Britain, CT 06051**

**Mr. James S. Robinson, Manager
Nuclear Investments and Administration
New England Power Company
25 Research Drive
Westborough, MA 01582**

**Mr. John Streeter
Recovery Officer - Nuclear Oversight
Northeast Utilities Service Company
P. O. Box 128
Waterford, CT 06385**

**Deborah Katz, President
Citizens Awareness Network
P.O. Box 83
Shelburne Falls, MA 03170**

**Mr. Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning
Division
450 Capitol Avenue - MS# 52ERN
P. O. Box 341441
Hartford, CT 06134-1441**

Millstone Nuclear Power Station
Unit 3

cc:

The Honorable Terry Concannon
Nuclear Energy Advisory Council
Room 4035
Legislative Office Building
Capitol Avenue
Hartford, CT 06106

Mr. Evan W. Woollacott
Co-Chair
Nuclear Energy Advisory Council
128 Terry's Plain Road
Simsbury, CT 06070

Mr. John W. Beck, President
Little Harbor Consultants, Inc.
Millstone - ITPOP Project Office
P.O. Box 0630
Niantic, CT 06357-0630

Mr. B. D. Kenyon (Acting)
Chief Nuclear Officer - Millstone
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385

Mr. Daniel L. Curry
Project Director
Parsons Power Group Inc.
2675 Morgantown Road
Reading, PA 19607

Mr. Don Schopfer
Verification Team Manager
Sargent & Lundy
55 E. Monroe Street
Chicago, IL 60603

Mr. P. D. Hinnenkamp
Director - Unit 3
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385

Senior Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
P. O. Box 513
Niantic, CT 06357

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056

Attorney Nicholas J. Scobbo, Jr.
Ferriter, Scobbo, Caruso, Rodophele, PC
1 Beacon Street, 11th Floor
Boston, MA 02108

Citizens Regulatory Commission
ATTN: Ms. Susan Perry Luxton
180 Great Neck Road
Waterford, CT 06385