

September 13, 1994

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, CT 06141-0270

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3  
(TAC NO. M90331)

Dear Mr. Opeka:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing" to the Office of the Federal Register for publication.

The notice relates to your application dated September 9, 1994. The proposed amendment would revise the Technical Specifications to modify surveillance requirements by increasing the acceptance criterion for the closure of the main steam isolation valves from 5 seconds to 10 seconds.

Sincerely,

Guy S. Vissing for Vernon L. Rooney  
Original signed by

Vernon L. Rooney, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

Docket File	JStolz	ACRS (10)
NRC & Local PDRs	SNorris	OPA
PDI-4 Plant	VRooney	OC/LFDCB
SVarga	OGC	LDoerflein, RGI

9409200188 940913  
PDR ADOCK 05000423  
P PDR

190007

**NRC FILE CENTER COPY**

OFFICE:	LA:PDI-4	PM:PDI-4	DPDI-4		
NAME:	SNorris	VRooney:cn	JStolz		
DATE:	9/13/94	9/11/94	9/13/94		

OFFICIAL RECORD COPY  
DOCUMENT NAME: G:\ROONEY\M90331NO.CON

*DFD*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 13, 1994

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, CT 06141-0270

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3  
(TAC NO. M90331)

Dear Mr. Opeka:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing" to the Office of the Federal Register for publication.

The notice relates to your application dated September 9, 1994. The proposed amendment would revise the Technical Specifications to modify surveillance requirements by increasing the acceptance criterion for the closure of the main steam isolation valves from 5 seconds to 10 seconds.

Sincerely,

A handwritten signature in cursive script, appearing to read "Vernon L. Rooney".

Vernon L. Rooney, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: As stated

cc w/encl: See next page

Mr. John F. Opeka  
Northeast Nuclear Energy Company

Millstone Nuclear Power Station  
Unit 3

cc:

Ms. L. M. Cuoco, Senior Nuclear Counsel  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

J. J. LaPlatney  
Haddam Neck Unit Director  
Connecticut Yankee Atomic Power Company  
362 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

Kevin T. A. McCarthy, Director  
Monitoring and Radiation Division  
Department of Environmental Protection  
79 Elm Street  
Hartford, Connecticut 06106-5127

Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning Division  
80 Washington Street  
Hartford, Connecticut 06106

S. E. Scace, Vice President  
Nuclear Operations Services  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

R. M. Kacich, Director  
Nuclear Planning, Licensing & Budgeting  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

J. M. Solymossy, Director  
Nuclear Quality and Assessment Services  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

First Selectmen  
Town of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385

P. D. Swetland, Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 513  
Niantic, Connecticut 06357

Donald B. Miller, Jr.  
Senior Vice President  
Millstone Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

F. R. Dacimo, Nuclear Unit Director  
Millstone Unit No. 3  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Burlington Electric Department  
c/o Robert E. Fletcher, Esq.  
271 South Union Street  
Burlington, Vermont 05402

M. R. Scully, Executive Director  
Connecticut Municipal Electric  
Energy Cooperative  
30 Stott Avenue  
Norwich, Connecticut 06360

David W. Graham  
Fuel Supply Planning Manager  
Massachusetts Municipal Wholesale  
Electric Company  
Post Office Box 426  
Ludlow, Massachusetts 01056

UNITED STATES NUCLEAR REGULATORY COMMISSIONNORTHEAST NUCLEAR ENERGY COMPANYDOCKET NO. 50-423NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS  
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-49, issued to Northeast Nuclear Energy Company (NNECO/the licensee), for operation of the Millstone Nuclear Power Station, Unit No. 3, located in New London County, Connecticut.

The proposed amendment would revise the Technical Specifications (TS) to modify surveillance requirements by increasing the acceptance criterion for the closure of the main steam isolation valves (MSIVs) from 5 seconds to 10 seconds.

The proposed change would permit Millstone Unit 3 to resume plant operation. To resume plant operations Millstone Unit 3 must meet the operability requirements of the Technical Specifications for the MSIVs. On September 8, 1994, during monthly testing of the "C" MSIV, it was determined that the MSIV was inoperable because its closure time was determined to be greater than 5 seconds. Subsequent efforts to meet the required closure time have been unsuccessful.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

Pursuant to 10 CFR 50.91(a)(6) for amendments to be granted under exigent circumstances, the NRC staff must determine that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration (SHC), which is presented below:

...The proposed change does not involve an SHC because the change would not:

1. Involve a significant increase in the probability or consequences of an accident previously analyzed.

NNECO's proposal to modify Surveillance Requirement 4.7.1.5.1 of the Millstone Unit No. 3 Technical Specifications does not involve a significant increase in the probability or consequences of an accident previously analyzed.

The increase in the MSIV stroke time from 5 seconds to 10 seconds has no adverse impact on the FSAR [Final Safety Analysis Report] analyses for the feedwater line break and the main steam line break. The applicable acceptance criteria (e.g., DNBR [departure from nucleate boiling ratio] and pressure) for both 3-loop and 4-loop operation continue to be met with an increase in the MSIV closure time from 5 to 10 seconds. No other accident analyses discussed in Chapter 15 of the FSAR are affected by the proposed increase in the MSIV closure time.

Additionally, evaluations have determined that the proposal does not affect the environmental qualification program for either the main steam valve building or the containment, does not impact the design basis accident radiological consequence calculations, does not negatively impact fluid transient evaluations, has a negligible impact on the long term cooling capacity of the steam generators, and does not change pipe rupture mechanistic effects.

2. Create the possibility of a new or different kind of accident from any previously analyzed.

The proposed change does not introduce any new failure modes. It simply modifies an acceptance criterion for a surveillance requirement. As such, increasing the MSIV stroke time from 5 seconds to 10 seconds affects only the FSAR analyses for the feedwater line break and the main steam line break. No other accident analyses discussed in Chapter 15 of the FSAR are affected by the proposed increase in the MSIV closure time. The applicable acceptance criteria (e.g., DNBR and pressure) for both 3-loop and 4-loop operation continue to be met with an increase in the MSIV closure time from 5 to 10 seconds.

Additionally, evaluations have determined that the proposal does not affect the environmental qualification program for either the main steam valve building or the containment, does not impact the design basis accident radiological consequence calculations, does not negatively impact fluid transient evaluations, has a negligible impact on the long term cooling capacity of the steam generators, and does not change pipe rupture mechanistic effects.

Thus, the proposed change does not create the possibility of a new or different kind of accident from any previously analyzed.

3. Involve a significant reduction in the margin of safety.

The increase in the MSIV stroke time from 5 seconds to 10 seconds has no adverse impact on the FSAR analyses for the feedwater line break and the main steam line break. The applicable acceptance criteria (e.g., DNBR and pressure) for both 3-loop and 4-loop operation continue to be met with an increase in the MSIV closure time from 5 to 10 seconds. No other accident analyses discussed in Chapter 15 of the FSAR are affected by the proposed increase in the MSIV closure time. Additionally, the proposed change does not impact the consequences of an accident previously analyzed.

Based on the above, there is no significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 15 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 15-day notice period. However, should circumstances change during the notice period, such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 15-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Rules Review and Directives Branch, Division of Freedom of Information and Publications Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and should cite the publication date and page number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D22, Two White Flint North, 11545 Rockville Pike, Rockville Maryland, from

7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By October 19, 1994 , the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555 and at the local public document room located at the Learning Resource Center, Three Rivers Community-Technical College, Thames Valley Campus, 574 New London Turnpike, Norwich Connecticut 06360. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which

the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If the amendment is issued before the expiration of the 30-day hearing period, the Commission will make a final determination on the issue of no significant hazards consideration. If a hearing is requested, the final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to John F. Stolz: petitioner's name and telephone number, date petition was mailed, plant name, and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to Gerald Garfield, Esquire, Day, Berry & Howard, City Place, Hartford, Connecticut 06103-3499, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated September 9, 1994, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, and at the local public document room, located at the Learning Resource Center, Three Rivers Community-Technical College, Thames Valley Campus, 574 New London Turnpike, Norwich, Connecticut 06360.

Dated at Rockville, Maryland, this 13th day of September 1994.

FOR THE NUCLEAR REGULATORY COMMISSION



Guy S. Vissing, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects -I/II  
Office of Nuclear Reactor Regulation