Perry January 2001

NRC COMMENTS ON WRITTEN EXAMINATION

Original Question	Exam	RO Question	SRO Question	New / Bank /	Level	Answer / Comments
Number	RO/SRO/Both	Number	Number	Mod Bank	1/2/3	
1	SRO	N/A	1	New	L1	В
2	SRO	N/A	2	New	L3	A Not part of 25 SRO Group
3	SRO	N/A	3	New	L1	D
4	SRO	N/A	4	New	L1	В
5	SRO	N/A	5	New	L2	B Not part of 25 SRO Group
6	SRO	N/A	6	New	L2	C
7	SRO	N/A	7	New	L3	В
8	SRO	N/A	8	Bank	L3	D TS 3.1.7
9	BOTH	50	50	New	L2	В
10	BOTH	56	56	New	L1	A
11	SRO	N/A	11	New	L1	В
12	SRO	N/A	12	New	L1	A
13	SRO	N/A	13	New	L3	D
14	SRO	N/A	14	Bank	L1	D OT-3039-01
15	SRO	N/A	15	New	L3	С
16	SRO	N/A	16	New	L3	D
17	SRO	N/A	17	Mod Bank	L1	В
18	SRO	N/A	18	New	L1	D
19	SRO	N/A	19	New	L1	A
20	SRO	N/A	20	New	L1	C
21	SRO	N/A	21	Bank	L1	D
22	SRO	N/A	22	New	L3	В
23	BOTH	45	45	New	L1	В
24	RO	24	N/A	Bank	L1	A OT-3036-04
25	SRO	N/A	24	New	L1	D
26	BOTH	73	73	New	L1	C
27	BOTH	100	100	New	L1	D
28	BOTH	28	28	New	L2	Α
29	BOTH	29	29	New	L1	C
30	BOTH	30	30	New	L3	В

•

Ĵ

Original Question	Exam	RO Question	SRO Question	New / Bank /	Level	Answer / Comments
Number	RO/SRO/Both	Number	Number	Mod Bank	1/2/3	
31	BOTH	31	31	New	L2	Α
32	BOTH	32	32	New	L2	С
33	BOTH	33	33	New	L3	В
34	BOTH	34	34	Bank	L2	D
35	BOTH	35	35	New	L1	D Simplified FDW System
36	BOTH	36	36	New	L2	D
37	BOTH	37	37	New	L1	A
38	BOTH	38	38	New	L1	В
39	BOTH	39	39	New	L1	Α
40	BOTH	40	40	New	L3	С
41	BOTH	41	41	New	L3	С
42	BOTH	42	42	New	L3	A PEI-SPI Suppl. Figure 1a
43	BOTH	43	43	New	L1	Α
44	BOTH	44	44	New	L3	С
45	SRO	N/A	25	New	L3	D PEI-M51/56
46	BOTH	46	46	New	L2	В
47	BOTH	47	47	New	L3	С
48	BOTH	48	48	New	L1	Α
49	BOTH	49	49	New	L2	В
50	SRO	N/A	26	New	L2	С
51	BOTH	51	51	New	L2	A
52	BOTH	52	52	New	L2	D
53	BOTH	53	53	New	L3	С
54	BOTH	54	54	New	L2	В
55	BOTH	55	55	New	L3	D
56	SRO	N/A	27	New	L2	В
57	BOTH	57	57	Bank	L2	C OT-3036-06
58	BOTH	58	58	New	L1	Α
59	BOTH	59	59	New	L3	В
60	BOTH	60	60	New	L1	A

2

ş

...

1

N

Original Question	Exam	RO Question	SRO Question	New / Bank /	Level	Answer / Comments
Number	RO/SRO/Both	Number	Number	Mod Bank	1/2/3	
61	BOTH	61	61	Mod Bank	L2	D OT-3036-01
62	BOTH	62	62	New	L1	D
63	BOTH	63	63	New	L2	C
64	BOTH	64	64	New	L1	С
65	BOTH	65	65	New	L2	D
66	BOTH	66	66	New	L2	D
67	BOTH	67	67	Bank	L2	D
68	BOTH	68	68	Bank	L1	С
69	BOTH	69	69	New	L2	В
70	BOTH	70	70	Bank	L2	D
71	BOTH	71	71	New	L3	В
72	BOTH	72	72	New	L2	С
73	RO	26	N/A	New	L2	С
74	BOTH	74	74	New	L3	D
75	BOTH	75	75	New	L2	В
76	BOTH	76	76	New	L2	D
77	BOTH	77	77	New	L2	В
78	BOTH	78	78	New	L1	В
79	BOTH	79	79	New	L2	D
80	BOTH	80	80	Bank	L1	В
81	BOTH	81	81	New	L2	В
82	BOTH	82	82	New	L2	В
83	BOTH	83	83	New	L3	В
84	BOTH	84	84	New	L1	С
85	BOTH	85	85	New	L1	D
86	BOTH	86	86	Mod Bank	L2	С
87	BOTH	87	87	Mod Bank	L2	В
88	BOTH	88	88	New	L1	В
89	BOTH	89	89	New	L2	В
90	BOTH	90	90	New	L3	C

۵

Ņ

Original Question	Exam	RO Question	SRO Question	New / Bank /	Level	Answer / Comments
Number	RO/SRO/Both	Number	Number	Mod Bank	1/2/3	
91	BOTH	91	91	Mod Bank	L2	A OT-3036-06
92	BOTH	92	92	New	L1	В
93	BOTH	93	93	New	L2	В
94	BOTH	94	94	New	L1	D
95	BOTH	95	95	New	L2	D
96	BOTH	96	96	New	L1	В
97	BOTH	97	97	New	L2	C
98	BOTH	98	98	Bank	L1	C
99	BOTH	99	99	New	L1	C
100	RO	27	N/A	New	L1	A
101	RO	1	N/A	New	L2	В
102	RO	2	N/A	New	L2	C
103	RO	3	N/A	New	L1	D
104	RO	4	N/A	New	L1	D
105	RO	5	N/A	New	L2	В
106	RO	6	N/A	New	L2	A
107	RO	7	N/A	Bank	L1	B OT-3036-02
108	RO	8	N/A	New	L1	A
109	RO	9	N/A	Bank	L1	B OT-3036-06
110	RO	10	N/A	New	L2	D
111	RO	11	N/A	New	L2	В
112	RO	12	N/A	Bank	L1	C OT-3036-06
113	RO	13	N/A	New	L1	В
114	RO	14	N/A	New	L1	В
115	RO	15	N/A	New	L2	В
116	RO	16	N/A	New	L1	В
117	RO	17	N/A	New	L1	С
118	RO	18	N/A	New	L1	В
119	RO	19	N/A	New	L1	D
120	RO	20	N/A	Mod Bank	L2	A

.

۲

1

Original Question	Exam	RO Question	SRO Question	New / Bank /	Level	Answer / Comments
Number	RO/SRO/Both	Number	Number	Mod Bank	1/2/3	
121	RO	21	N/A	Mod Bank	L2	A OT-3036-03
122	RO	22	N/A	New	L1	D
123	RO	23	N/A	Bank	L2	A
124	SRO	N/A	23	New	L3	D
125	RO	25	N/A	New	L1	С
126	SRO	N/A	9	New	L2	A
127	SRO	N/A	10	New	L3	B PAP-1914

ES-401	Written Examination	Form ES-401-9
	Review Worksheet	

	1.	2.	3	. Psyc	homet	ric Flaw	'S	4.	Job Con	tent Fl	aws	5. C	Other	5 6.	*	67.
	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K/A	SRO Only	U/E/S	B/M/N	Explanation
1	F	2	-									ok	SRO	S	N	Weak link to K/A 10 CFR 55.43 (b)(2)
2	н	3	*									ok	RO	E	N	10 CFR 55.41 (b)(1 or 2) are applicable. Suggest rewording the stem t o read "Which of the following will cause fuel temperature to act first" Change: Licensee accepted enhancement comment.
3	F	3				*						ok	SRO	E	N	 10 CFR 55.41 (b)(10) but at an SRO-level (applicability of 10 CFR 50 54 (x) Distractor a and b state damage is immediate while stem says may occur. Not very credible. Distractor c doesn't make sense. Suggest rewording distractors: a. Equipment damage is expected to occur immediately. A 10 CFR 50.54 (x) determination must be made prior to operating a pump at a suppression pool level less than 5.75 ft. b. Equipment damage is expected to occur immediately. However, a 10 CFR 50.54 (x) determination is NOT necessary prior to operating a pump at a suppression pool level less than 5.75 ft. c. Equipment damage is NOT expected to be immediate. However, a 10 CFR 50.54 (x) determination must be made prior to operating a pump at a suppression pool level less than 5.75 ft. d. Equipment damage is NOT expected to be immediate. However, a 10 CFR 50.54 (x) determination is NOT necessary prior to operating a pump at a suppression pool level less than 5.75 ft. d. Equipment damage is NOT expected to be immediate. However, a 10 CFR 50.54 (x) determination is NOT necessary prior to operating a pump at a suppression pool level less than 5.75 ft.

	1.	2.	3	. Psycl	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. C	other	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K∕A	SRO Only	U/E/S	B/M/N	Explanation
4	н	2		х								ok	SRO	U	N	10 CFR 55.43 (b)(2) Entry condition for TS but question also addresses what should be the next direction. (Application of TS)
																Distractor b is the only one which doesn't mention PEI-T23. Cue.
													-			Suggest hitting on other TS requirements - such as scramming the reactor (above 110),
																Change: Licensee changed distractor c to include reference to TS but no reference to PEI-T23.
5	н	3										ok	RO	E	N	10 CFR 55.41 (b)(7) System knowledge
																Distractor a and b reverse logic. Suggest rewording: a. The SDC system will isolate if pressure exceeds 135 psig b. The RHR pump seals could be damaged if pressure exceeds 135 psig.
																Change: Licensee accepted enhancement comment.
6	Н	3										ok	SRO	S	N	10 CFR 55.43 (b)(5) Spelling error - assures not assure
7	Н	1				x						ok	SRO	υ	N	10 CFR 55.43 (b)(5)
											- - -					LOD - Stem states Max safe operating condition is 4R and that areas are 4.1 and 4.2. Distractor b states two areas exceed max limits - too easy. Only analysis is whether 4.1 and 4.2 are > 4.0.
																Distractor c not credible - states only 1 exceeds max limit. Why would someone believe 4.2 > 4.0 but not 4.1 > 4.0?
																Distractor a not credible - shutdown required to protect components- not to isolatecould be worded better.
																Change: Licensee changed stem to read only one area exceeded max limit - same answer as this condition implies other areas exceed max limit also.
8	н	2										ok	SRO	S	В	10 CFR 55.43 (b)(1 and 2)
9	н	2										ok	RO	S	N	Final question 50 on both exams.
10	F	2/3										ok	RO	s	N	Final question 56 on both exams.

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	tent Fla	aws	5. C	ther	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
11		1										ok	U-S	U	N	RO applicants should know the definition of reactor modes. Careful - RO question 114 deals with mode.
11N	F	2										ok	SRO	s	N	
12	F	2				*						ok	SRO	E	N	10 CFR 55.43 (b)(1) Change 30 days to 4 hour notification in distractor c and d - more credible.
																Change: Licensee accepted enhancement comment.
13	т	2/3		*								ok	SRO	E	N	10 CFR 55.43 (b)(5) Take out "the main turbinescram" since this somewhat cues that an ATWS occurred. Suggest replacing with "the unit remained at 100% power."
					i .											Change: Licensee accepted enhancement comment.
14	F	2				*						ok	SRO	s	В	10 CFR 55.41 (b)(10) but test knowledge of SRO responsibilities.
																Is distractor really incorrect - can't shift supervisor sign? Also, double negative stem - which is NOTwithout
																Change: Licensee unable to switch to a positive statement. There were no problems during examination validation. Also, changed shift supervisor to supervising operator to verify only one correct answer.
15	н	2										ok	SRO	S	N	10 CFR 55.43 (b)(7)
16	н	3										ok	SRO	s	N	10 CFR 55.43 (b)(2 and 7)
17	F	2										ok	SRO	S	M?	10 CFR 55.41 (b)(10) but at an SRO level - responsibilities.
18	F	2				x						ok	SRO	U	Ň	10 CFR 55.41 (b)(10) but tests SRO responsibilities.
																 distractors a and d are opposites - makes this a 50/50 question. Suggest the following: a. may NOT be waived for personnel safety or ALARA purposes b. may NOT be waived for personnel safety but may be waived for ALARA purposes c. may be waived for personnel safety but may NOT be waived for ALARA purposes d. may be waived for personnel safety and ALARA purposes Change: Licensee made the above changes.

	1.	2.	3	. Psyc	homet	ric Flaw	'S	4.	Job Cont	tent Fla	aws	5. C	Other	5 6.	*	67.
Q#	LOK (F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
19	F	2										ok	SRO	E	N	10 CFR 55.43 (b)(4) Add "work" after "radiological" in stem - currently doesn't make sense.
																Change: Licensee accepted enhancement comment.
20	F	2										ok	SRO	S	N	10 CFR 55.41 (b)(10) but tests SRO responsibilities - key control
21	F	2										ok	SRO	s	В	10 CFR 55.41 (b)(10) but tests SRO responsibilities - accountability.
22	н	3					÷					ok	U-S	U	N	Question asks for the immediate actions to DC bus fault - operators expected to know these. Not SRO-only.
																Change: Licensee accepted comment. Licensee removed statement that bus D-1-A indicated 0 volts. This removal required the applicant to evaluate the conditions and direct actions (now considered at SRO-level)
23	F	2/3										ok	RO	s	N	
24	F	1/2										ok	U-S	υ	В	10 CFR 55.41 (b)(10) - RO immediate actions - Does not meet definition of SRO-only.
																Change: Licensee made this question a RO-only question.
25	F	2										ok	SRO	s	N	10 CFR 55.43 (b)(5)
26	F	1*										ok	RO	S	N	Normally, this would be considered low level - what is power supply - but recent modification makes this more important and Chief Examiner decided to use question.
27	H F	2										ok	RO	S	N	Applicant need only know bases for 3700 MWt - no analysis
28	н	3										ok	RO	s	N	
29	F	2										ok	RO	S	N	
30	н	3										ok	RO	s	N	
31	н	3										ok	RO	s	N	
32	н	3							ļ			ok	RO	s	N	
33	н	3										ok	RO	s	N	
34	н	2										ok	RO	S	N	Add "the" after "until" in distractor a

	1.	2.	3	. Psycl	homet	ric Flaw	'S	4.	Job Cont	ent Fl	aws	5. C	Other	5 6.	*	67.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
35	F	2										ok	RO	S	N	
36	н	2/3										ok	RO	s	N	
37	F	2										ok	RO	s	N	
38	F	3				х						ok	RO	U	N	Distractor a and c are not credible. Why would someone think that a high drywell pressure scram (RPS signal) would mitigate an ATWS?
																Change: Licensee rewrote distractors to mirror other RPS signals.
39	F	2	*									ok	RO	Е	N	Eliminate first sentence - training material which is not appropriate for an exam.
																Change: Licensee removed training information.
40	?	2										x	RO	U	N	K/A 295026EK1.01 deals with relationship between suppression pool high temperature and NPSH. Question as written deals with recognizing NPSH concerns - the stem info regarding suppression pool temperature, plant conditions is not needed to answer the question.
								ļ								LOK - currently is F - definition of cavitation
40N	н	2/3										ok	RO	s	N	
41	н	2										ok	RO	S	N	
42	н	1										ok	RO	U	N	LOD low - can increase by forcing steam table use. (Series of different pressures and temperatures instead of recognition that one temp is above 212 °F.
																Change: Licensee accepted comment. Licensee changed sets of conditions to require candidate to read graph instead of steam tables. Licensee explained that this was more operationally expected of ROs.
43	F	3										ok *	RÓ	S	N	K/A match is not obvious. After discussion, accepted question and K/A.
44	н	3										ok	RO	S	N	

Perry/January 2001 Exam

	1.	2.	3	. Psyc	hometi	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. O	ther	5 6.	*	67.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	Т/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
45	н	3				х						ok	SRO	U	N	10 CFR 55.43 (b)(5)
																Distractor b and c not credible as question is currently written. Cue is word "secured" - no reason to believe one system would be operating and one would be secured.
																Suggest changing initial conditions such that containment H2 is 8.2 (8.6 is highest on graph - initial is 8.7 - obvious that it is outside of band) and drywell H2 7.0 instead of 8.9 (applicant will go down different path if s/he uses 7.5 instead of 8.2 on the HDOL chart. This will then make distractor c credible.
																Change: Licensee accepted comment and changed initial conditions.
46	н	3										ok	RO	s	N	
47	н	4										ok	RO	S	N	Facility commented that this is an RO-level question.
48	F	2								·		ok	RO	s	N	
49	н	2/3										ok	RÖ	s	N	
50	н											x	SRO	U	N	10 CFR 55.43 (b)(2)
																K/A 295004AA2.03 deals with the relationship between battery voltage and a loss or complete loss of DC power. Question as written deals with TS applicability for battery voltages.
50N	н	3		1								ok	SRO	s	N	
51	н	2	*									ok	RO	S	N	Distractor c - change "Implement" to "implement" Stern is redundant. Just say reactor power is at 25 %.
																Change: Licensee accepted enhancement comment.
52	н	2	*								:	ok	RO	E	N	Distractor b not credible as it contradicts the stem (stem says level increased, distractor b states level decreased. Suggest taking out "but theinjection" as it is not needed.
											<u> </u>					Change: Licensee accepted enhancement comment.
53	н	2										ok	RO	s	Ν	Low 2

	1.	2.	3	. Psycl	homet	ric Flaw	'S	4.	Job Cont	tent Fla	aws	5. C	Other	5 6.	*	67.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
54	F											x	RO	υ	N	KA 295012AK2.02 deals with high drywell temperatur and drywell cooling. Question as written asks when drywell coolers start. Weak link because coolers do not start automatically on drywell temperature and this is distractor c.
54N	н	3										ok	RO	s	N	
55	н	3	x									ok	RO	E	N	Annunciator response procedure states that the alarm comes in at 93 $^\circ F;$ stem states temperature is 86 $^\circ F.$
																Change: Changed to 93 °F.
56	н	2/3										ok	s	s	N	10 CFR 55.43 (b)(2)
57	н	3										ok	RO	s	в	
58	F	2										ok	RO	s	N	
59	н	3										ok	RO	s	N	Verify system knowledge not memorization of a procedure step (supplemental actions)
																Confirmed with licensee - this is an acceptable question.
60	F	2										ok	RO	S	N	
61	н	2/3		*								ok	RO	E	м	Cue in distractor a - question asks for how "A" will respond; distractor states "B" response. Suggest putting "the" in from of "of" and taking out "train A" in stem.
62	F	3	1									ok	RO	S	N	
63	н	3										ok	RO	S	N	
64	F	2		x								ok	RO	U	N	distractor b and d mention withdraw - why would someone think that insert blocks would cause withdraw blocks? How is this plausible?
																Suggest system fault and gang misalignment.
64N	F	2	1									ok	RO	s	N	
65	н	4					Ī					ok	RO	s	N	
66	н	3										ok	RO	s	N	
67	н	2/3										ok	RO	s	в	

1

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. C	Other	5 6.	*	6 7.
Q#	LOK (F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
68	F	2	*									ok	RO	E	В	Teaching in stem. Suggest making stem a statement of fact - "HPCI automatically initiated due to receipt of BOTH low level and high drywell signals. HPCS initiation may/will be reset
		_														Change: Licensee accepted enhancement comment.
69	Н	3	*									ok	RO	Е	N	Change to F022C - Fo22A was used as an example in the student text. Also change order of distractors (B, C, A, D with answer C)
																Change: Licensee accepted enhancement comment.
70	Н	3										ok	RO	s	В	
71	н*	4										ok	RO	s	N	Expectation to have formula memorized?
72	н	з										ok	RO	s		
73														υ	M?	Series of T/F statements
73N	н	3										ok	RO	S	N	This is RO question number 26.
74	н	3										ok	RO	s	N	
75	F	3					[*	ok	RO	E	N	Change "not positive" to "negative" in distractor b.
								1								Change: Licensee accepted enhancement comment.
76	н	2										ok	RO	S	N	
77	Н											ok*	RO	S	N	? How does failed drywell instrument affect the answer? Licensee stated that candidate needs to determine that there is no effect. This meets K/A.
78	F	2										ok	RO	S	N	
79	н	2										ok	RO	S	N	
80	F	2										ok	RO	s	в	
81	н	2/3										ok	RO	S	N	
82	н	2										ok	RO	s	N	
83		1												U		Too easy. Only one distractor (the answer) contains the opposite RPS train.
83N	н	3										ok	RO	S	N	

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	tent Fla	aws	5. C	ther	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K/A	SRO Only	U/E/S	B/M/N	Explanation
84	F	2/3				*						ok	RO	E	N	Need to relook at distractor b - not credible. It states that the loss of seal flow decreases the possibility of seal failure - if this is true then having seal flow INCREASES the possibility for seal damagethen why have seal flow?
																Change: Difficult to find another distractor. Decided to keep this one.
85	F	2										ok	RO	s	N	
86	н	2/3		*								ok	RO	E	м	Distractor c only one with 2 items - one of the items is repeated in distractor b. Could cue. Suggest using another non-E31 signal for B and eliminating high differential flow from distractor c.
																Change: Licensee accepted enhancement comment.
87	н	2/3										ok	RÓ	s	м	
88	F	2										ok	RO	s	N	
89	н	3										ok	RO	E	N	Capitalize NOT in stem question.
				ł												Change: Underlined "not"
90	н	2										ok	RO	S	N	
91	н	3										ok	RO	S	м	
92	F	3										ok	RO	s	N	
93												x		U		Good question but doesn't meet K/A. K/A 272000K4.02 focuses on design interlocks for auto actions in the event of a release greater than pre\determined values - question deals with initiations (K4.03 or A2.16)
93N	н	3										ok	RO	s	N	
94												x	RO	U		KA 290003A4.03 deals with CRHVAC and damper positions. Question deals with initiation (A3.01 or A4.01)
94N	F	3										ok	RO	S	N	
95	H F	3										ok	RO	S	N	
96	F	2										ok	RO	S	N	

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. O	ther	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
97	Н	2		*								ok	RO	E	N	Parallel construction - change distractor a to read "the steam dryerwas removed Add "the" in front of all distractors. Eliminate "due to" in distractor d.
																Change: Licensee accepted enhancement comments and modified distractors to parallel construction.
98	F	2/3		*								ok	RO	E	В	Change distractor a to condensate booster pump "B" not "A" and add "hotwell pump C" to distractor b. This makes distractors more credible (common mistake of mixing buses.)
				ļ												Change: Licensee accepted enhancement comment.
99	F	2										ok	RO	s	N	
100	F	3	*									ok	RO	E	N	Modify note to read: NOTE: Selection of a duration less than or greater than the minimum design will be an INCORRECT response. This takes out the bias that 12 is incorrect. Although the lowest number is the correct number, this note should not influence those who know the answer. Change: Licensee accepted enhancement comment.
101	н	2/3					1	. 				ok	RO	s	N	
102	н	2		*								ok	RO	E	N	Move distractor a to distractor c position (order of length). Underline AND (like only)
																Change: Licensee accepted enhancement comment.
103	F	2										ok	RO	s	N	
104	F	2			*							ok	RO	S	N	This is a series of T/F but it is appropriate for this type of question - i.e. what is the definition of RCIC interlocks.
105	н	2/3										ok	RO	s	N	
106	н	2										ok	RO	Е	N	
107	F	2										ok	RO	S	N	
108	F	3										ok	RO	s	N	
109	F	3										ok	RO	S	в	

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. O	ther	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K⁄A	SRO Only	U/E/S	B/M/N	Explanation
110	н	2/3		*								ok	RO	E	N	Parallel construction (eliminates cue in distractor d) Change distractor d to read "The plant operator manually valves in the deluge system locally and opens the initiation valve to fill the charcoal filter plenum with water.
																Change: Licensee accepted enhancement comment.
111	н	2/3		·								ok	RO	E	N	
112	F	2										ok	RO	S	в	
113	F	2			*							ok	RO	S	N	This is a series of T/F but it is appropriate for this type of question - i.e. what is the definition of H2 igniters.
114	F	2			*							ok	RO	S	N	This is a series of T/F but it is appropriate for this type of question - i.e. what is the definition mode
115	н					x	x					ok	RO	U	N	Need to reword bolded comment - as written, distractor c and d are also correct in that, they contain all the required items (plus some additional ones. Need to state "complete and only those required - or minimal list of required
																Change: Licensee modified bolded statement. Only one answer remains valid.
116	F	2										ok	RO	s	N	
117	F	2/3										ok	RO	S	N	
118	F	2	*									ok	RO	E	N	Low 2
																Most of the stem information is not needed. Suggest deleting the "Given the followingMSIV closure" and start with "Which of the following"
				1												Change: Licensee accepted enhancement comment.
119	F	2										ok	RO	S	N	
120	н	2										ok	RO	s	м	low 2
121	н	2										ok	RO	s	м	
122	F	3										ok	RO	s	N	· · · · · · · · · · · · · · · · · · ·
123	н	2										ok	RO	s	в	

	1.	2.	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. O	ther	5 6.	*	6 7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	Т/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q≠ K/A	SRO Only	U/E/S	B/M/N	Explanation
124	Н	3		x								ok	U-R	U	N	Distractor d is too long - cues to answer since it is only distractor which references power.
																Is this expected RO knowledge?
																Change: Licensee agreed that this is a SRO-only level question and moved question to the SRO exam. Licensee changed distractor d and eliminated power reference.
125	F	3										ok	RO	S	N	
126	н	2	*									ok	SRO	E	N	Reword stem to request Unit Supervisor direction (after evaluating conditions.)
127	7 H 3 0k SRO S N															
	Instructions															
					[Re	fer to S	ection D	of ES	-401 and	Apper	ndix B fo	or addi	tional	informa	tion reg	arding each of the following concepts.]
1.	Enf	ter the l	evel of I	knowle	dge (L	OK) of (each qu	estion	as either	(F)un	damenta	al or (H	H)ighei	r cogniti	ve level	
2.	Ent	ter the l	evel of c	difficult	y (LOI	D) of ea	ch ques	tion us	ing a 1 -	5 (eas	y - diffic	cult) ra	ting so	ale (que	estions i	in the 2 - 4 range are acceptable).
3.	Ch	eck the	approp The ster The ster The ans More the One or r	riate bo m lack m or di wer ch an one more d	ox if a s suffic stracto noices distra listract	psychor cient foc ors cont are a co ctor is r cors is (a	metric fl cus to el ain cues blection not credi are) part	aw is id icit the s (i.e., of unr ble. ially co	dentified: correct a clues, sp elated tru prrect (e.	answei ecific o ue/falso g., if th	r (e.g., u determir e staten e applic	inclear hers, p hents. cant ca	r inteni hrasin n mak	t, more i g, lengt e unsta	nformat h, etc). ted assi	tion is needed, or too much needless information). umptions that are not contradicted by stem).
4.	 Check the appropriate box if a job content error is identified: The question is not linked to the job requirements (i.e., the question has a valid K/A but, as written, is not operational in content). The question requires the recall of knowledge that is too specific for the closed reference test mode (i.e., it is not required to be known from memory). The question contains data with an unrealistic level of accuracy or inconsistent units (e.g., panel meter in percent with question in gallons). The question requires reverse logic or application compared to the job requirements. 															
5.	5. Check the appropriate box if the sampled question does not match the approved K/A or an SRO-only question is not at the SRO level.															
6.	6. Based on the reviewer's judgment, is the question as written (U)nacceptable (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)atisfactory?															
67.	Fo	r any "L	I" rating	s, at a	minim	um, exp	plain hov	w the A	Appendix	B psy	chometr	ic attri	butes	are not	being m	net.
• ;	* Source of question: Bank/Modified/New. B-P means used on previous NRC exam, pre-validated.															

QUESTION 11

•

Which one of the following statements describes when Perry Technical Specification LCO 3.0.4 would allow a MODE change from MODE 2 to MODE 1?

- A. When the ACTION(S) of the LCO <u>not</u> met permit continued operation of the plant for 30 days.
 B. When the ACTION(S) of the LCO <u>not</u> met permit continued operation of the plant for an unlimited period of time.
- C. When compliance with the associated ACTION(S) of the LCO <u>not</u> met would place the plant back into MODE 2.
- D. When compliance with the associated ACTION(S) of the Operational Requirement (OR) not met would place the plant back into MODE 2.

ANSWER: B

		Level:		RO	SRO
		Tier#			3
E	an Dafamanan	Group	t		Cat 1
Examination Outline Cro	ss-kelerence	K/A#	· ·	GEN 2	1 22
			nco Poting		1.22
Proposed Question: See	e attached				
Proposed Answer: See	attached				
Explanation (Why the distract	ors are incorrect):				
A – the associated ACTION r of time.	nust permit continu	ied operati	on in the MODI	∃ for an ur	ilimited period
C / D – Mode change is not a exit that Applicability to comp does also apply to the ORM).	llowed if the Applic ly with the ACTION	ability to b I of the LC	e entered woul O or OR not in	d require t complianc	he plant to e. (LCO 3.0.4
Technical Reference(s): Tech	n Spec LCO 3.0.4 a	and	Reference At	ached:	_x_
Bases, ORM (PDB-R0001) S	Section 2.0		(Attach if not	previously	provided)
Proposed references to be pr	ovided to applican	ts during e	xamination: No	one	
Learning Objective (As availa	ıble): OT-3037-00	5-04 Obj [) OT-3037-000)-16 Obj [)
Question Source:	Bank # Modified Bank ≉ New	#	(Note ch	anges or a	attach parent)
Question History:	Previous NRC E Previous Quiz /	Exam Test			
Question Cognitive Level:	Memory or Fund Comprehension	lamental K or Analysi	nowledges	_X	
10 CFR Part 55 Content:	55.41 55.43X				
Comments (Why is it an uppe	er level question): I	N/A			

QUESTION 40

The following plant conditions exist:

- An ATWS is in progress
- MSIVs are isolated
- SRVs are being used to control reactor pressure

As Suppression Pool temperature increases, ECCS pump NPSH _____.

- A. <u>increases</u> resulting in the potential for ECCS pump cavitation.
- B. <u>increases</u> resulting in the potential for pump runout.
- C. <u>decreases</u> resulting in the potential for ECCS pump cavitation.
- D. <u>decreases</u> resulting in the potential for pump runout.

ANSWER: C

		l evel:		R	0	SRO
		Tier #				1
Examination Outling Corre	a Dafananaa	Group #	ŧ	2		1
Examination Outline Cros	s-Reference	K/A#		2	95026 EK	1.01
		Importa	nce Ratin	a 3	.0	3.4
Proposed Question: See	attached					
Proposed Answer: See a	ittached					
Explanation (Why the distracto	ors are incorrect):			,		
A / B – pump NPSH decreases	s as SP temp incre	eases.				
D there is no correlation both		and num				
Technical Reference(s): Supp Bases, GP Components Text	Pool Temperatur	e PEI	Reference (Attach in	ce Attach f not prev	ned: viously pro	X ovided)
Proposed references to be pro	ovided to applicant	ts during e	xaminatio	n: None		
Learning Objective (As availat	ole): OT-3303-003	3-02 Obj 3	, OT-3402	2-004-06	Obj B	· · · · · · · · · · · · · · · · · · ·
Question Source:	Bank # Modified Bank # New	#	(Nc	ote chang	ges or atta	ach parent)
Question History:	Previous NRC E Previous Quiz /	Exam Test				
Question Cognitive Level:	Memory or Fund Comprehension	lamental K or Analysi	inowledge s	(/	Ā)	
10 CFR Part 55 Content:	55.41X 55.43					
Comments (Why is it an uppe indications to determine the c temperature creating condition	r level question): F ause. Increasing S ns for pump cavita	Requires s Supp Pool ation.	tudent to a temperatu	analyze t ıre reduc	he abnorr es pump	nal suction

e . .

QUESTION 50

An inadvertent High Pressure Core Spray (HPCS) Pump start occurred.

Before the Control Room Operators could take any action for the inadvertent HPCS Pump start, a loss of DC Bus ED-1-C occurred.

Bus EH13 is being powered from the preferred off-site power source.

Which one of the following methods should be directed by the Unit Supervisor in order to shutdown the HPCS Pump?

А.	From the Control Room, take the HPCS PUMP, 1E22-C001, control switch to the STOP position.
В.	From the Control Room, take the PREFERRED SOURCE BREAKER, EH1303, control switch to the TRIP (open) position.
C.	Locally at HPCS PUMP BRKR EH1304 cubicle, depress the MANUAL TRIP pushbutton.
D.	Locally at HPCS PUMP BRKR EH1304 cubicle, take the test control switch to the TRIP (open) position.

ANSWER: C

······		Level:	<u> </u>		RO	SRO
		Tier #				1
	D (Group :	#			12
Examination Outline Cros	s-Reference	Gloup	H		205004 4	
		N/A#			295004 A	AZ.04
	·····		ance Ra	ating		3.3
Proposed Question: See Proposed Answer: See a Explanation (Why the distractor A – On a loss of DC control po switch.	attached ttached rs are incorrect): wer, the HPCS Pu	mp break	er will r	not open	using the c	ontrol room
B - On a loss of DC control por the control room switch.	wer, the Bus EH13	Preferred	d Sourc	e Breake	er will not op	ben using
D – The local Test Control Swi position.	tch only functions	when the	breake	r is racke	ed out to the	e TEST
Technical Reference(s): ONI- E12-1, SDM-R42	R42-3, SDM-R10,	ONI-	Refer	ence Atta	ached:) previously p	K rovided)
· · · · · · · · · · · · · · · · · · ·					ieriedely p	
Learning Objective (As availab 3036-006-R10 Obj B, OT-303	vided to applicants vie): OT-3552-001 36-004-E22A Obj	-00 Obj D K	, E, J (DT-3036	-006-R42 (Obj E, OT-
Question Source:	Bank # Modified Bank # New		(Note cha	anges or att	ach parent)
Question History:	Previous NRC Ex Previous Quiz /	xam Test				
Question Cognitive Level:	Memory or Funda Comprehension of	amental K or Analysi	(nowled s	lgeX	_(C)_	
10 CFR Part 55 Content:	55.41 55.43X					
Comments (Why is it an upper in order to determine the correct HPCS Pump.	level question): F	Requires s edure and	student I associ	to analyz iated me	ze the giver thod of sect	a conditions uring the

_

•. •

QUESTION 54

÷

A cold reactor startup is in progress. Drywell temperature is slowly increasing as reactor heatup and pressurization is being performed.

Which one of the following describes how the Drywell Cooling System (M13) responds during <u>normal</u> plant operation?

Assume the Drywell Cooling System is in normal operation.

Α.	The standby Lower Drywell Cooling Fan will automatically start when Reactor Vessel Support Skirt area temperature exceeds 120 °F.
B.	The Lower Drywell Cooler NCC Bypass Valve, P43-F365, will re- position to cause more cooling water to flow through the in-service Lower Drywell Air Handling Unit cooling coil.
C.	The Lower Drywell Cooler NCC Bypass Valve, P43-F365, will re- position to cause less cooling water to flow through the in-service Lower Drywell Air Handling Unit cooling coil.
D.	The Lower Drywell Cooler 3-Way NCC Supply Valve, P43-F025, will throttle open to provide additional cooling water flow through the inservice Lower Drywell Air Handling Unit cooling coil.

ANSWER: B

		Level:			RO	SRO
		Tier #			1	1
Examination Outline Cro	ss-Reference	Group	#		2	2
		K/A#			295012 A	1K2.02
		Importa	ance Rati	ng	3.6	3.7
Proposed Question: See	attached					
Proposed Answer: See	attached					
Explanation (Why the distract	ors are incorrect):					
A – There is no auto start feat low air flow)	ure associated with	n the stan	dby fan d	lue to hi	igh temper	ature (only
C – F365 will re-position to dir provide more cooling of the ai	ect more flow to th	e in-servio discharge	ce cooling	g coil (n HU	ot less flow	<i>w</i>) in order to
D – The 3-way valve does not selected to be in-service.	throttle. It provides	s full cooli	ng water	flow to	either coo	ling coil
Technical Reference(s): SDM	1-M13		Referen	nce Atta	ached:	<u>_X</u>
			(Attach	if not p	reviously j	provided)
Proposed references to be pro	ovided to applicant	s during e	xaminatio	on: Noi	ne	
Learning Objective (As availa	ble): OT-3036-004	-M13 Ob	j B, C an	d F		
Question Source:	Bank # Modified Bank # New		(N	lote cha	anges or at	ttach parent)
Question History:	Previous NRC E Previous Quiz /	xam Test				
Question Cognitive Level: * Original question was a Le totals.	Memory or Fund Comprehension evel 1 question, th	amental k or Analysi iis is now	(nowledg s r a Level	e _X 2 ques	_(C)_ stion whic	h affects
10 CFR Part 55 Content:	55.41X 55.43					
Comments (Why is it an uppe Drywell Cooling System to an	r level question): F increasing Drywel	Requires tl Il tempera	ne studer ture conc	nt to pre lition	edict the re	sponse of the

,

QUESTION 64

c :

•

When a control rod is selected, the Control Room Operator observes that the control rod has an "Insert Block" and "Insert Inhibit" light.

This means that the control rod **cannot** be INSERTED ______.

А.	since this might allow the LHGR or MCPR limit to be exceeded.
B.	since this would indicate a control rod block due to a system fault.
C.	since this might allow a control rod to have excessive rod worth.
D.	since this would indicate a control rod block due to a bypassed control rod position indicator.

ANSWER: C

	· · · · · · · · · · · · · · · · · · ·	Level			RO	SRO
		Tior #			2	2
	D C	Group t	#			
Examination Outline Cross	-Reference	Gloup #	7		201005	<u> </u>
		N/A#		atina	201000	AZ.03
Proposed Question: See	attached					
Proposed Answer: See at	tached	<u></u>				
Explanation (Why the distractor	s are incorrect):					11
A – the control rod cannot be in	serted but the rea	ison is no	t due t	to LHGR	or MCPR	limits.
B – An RC&IS 'system fault' wil in conjunction).	I cause an Insert I	Block ligh	t by its	self (but n	ot an Inse	ert Inhibit light
D – A control rod that has had i the RPC and will not cause eith	ts position indicati er an Insert Inhibi	ion bypas t or Inserl	sed in Block	RACS is	essential	ly invisible to
Technical Reference(s): SDM-C C11(RCIS)	C11(RCIS), SOI-		Refe	erence Att	ached: _	_X
	······				Jeviousiy	provided
Proposed references to be prov	vided to applicants	s during e			ne	
Learning Objective (As availabl	e): 01-3036-004	-C11(RCI	S) Ob	JB&C		
Question Source:	Bank # Modified Bank # New			(Note ch	anges or a	attach parent)
Question History:	Previous NRC Ex Previous Quiz /	xam Test				
Question Cognitive Level:	Memory or Funda Comprehension of	amental K or Analysi	(nowle s	edge	_X	
10 CFR Part 55 Content:	55.41X 55.43					
Comments (Why is it an upper	level question): N	/A				

QUESTION 73

During RCIC System operation, a RCIC turbine trip occurred.

The Supervising Operator attempted to reset the RCIC turbine by closing the RCIC TURBINE TRIP THRT V LATCH, 1E51-F510, and then taking the control switch to the OPEN position.

The following RCIC System valve position indications exist:

RCIC TRIP THROTTLE VALVE	GREEN light ON	RED light OFF
RCIC TURBINE TRIP THRT V LATCH	GREEN light OFF	RED light ON
RCIC TURBINE GOVERNOR VALVE	GREEN light OFF	RED light ON

Which one of the following currently describes the operation of the RCIC System?

- A. The RCIC System should be operating at a speed based on governor demand.
- B. The RCIC System is reset awaiting the re-opening of RCIC STEAM SHUTOFF VALVE, 1E51-F045.
- C. The RCIC System is still tripped awaiting the reset of the trip device linkage locally at the RCIC turbine,
- D. The RCIC System is still tripped awaiting the reset of the RCIC Division 1 and/or Division 2 isolation signals.

ANSWER: C

		_			
		Level:		RO	SRO
		Tier #		2	
Examination Outline Cross	ss-Reference	Group #	£	1	
Examination Outline Cro	55 RELET CHEC	K/A#		217000	K5.06
		Importa	nce Rating	2.7	
Proposed Question: See	attached				
Proposed Answer: See a	attached				
Explanation (Why the distracted	ors are incorrect):				
A / B – The RCIC System is s position.	till tripped as indic	ated by the	Trip Throttl	e Valve still i	in the Close
D – The RCIC System is still t being reset (not because of a	ripped but it is due Divisional isolatior	e to the me n signal).	chanical ove	erspeed trip of	device not
Technical Reference(s): SOI-	E51, SDM-E51		Reference	Attached:	_x
			(Attach if n	ot previously	v provided)
Proposed references to be pro	ovided to applicant	ts during e	xamination:	None	
Learning Objective (As availa	ble): OT-3036-003	-E51 Obj	D, F, K		
Question Source:	Bank # Modified Bank # New	#	(Note	changes or	attach parent)
Question History:	Previous NRC E Previous Quiz /	Exam Test			
Question Cognitive Level:	Memory or Fund Comprehension	lamental K or Analysi	nowledge s	_X_(C)_	
10 CFR Part 55 Content:	55.41 <u>X</u> 55.43 <u> </u>				
Comments (Why is it an uppe of the RCIC System based or	er level question): n given conditions.	Requires s	student to pr	edict the ope	erational status

پ د

QUESTION 83

The following plant conditions exist:

- The plant is operating at 100% reactor power
- Feedwater Level Control is on the Master Level Controller with Narrow Range Level Channel 'A' selected
- Narrow Range Level Channel 'A' has failed upscale

The reactor will scram on _____.

- A. low RPV water level; water level will be restored to approximately 200 inches in accordance with ONI-C71-1, Reactor Scram.
- B. low RPV water level; water level will be restored to 185 215 inches in accordance with PEI-B13, RPV Control (Non-ATWS).
- C. high RPV water level; water level will be restored to approximately 200 inches in accordance with ONI-C71-1, Reactor Scram.
- D. high RPV water level; water level will be restored to 185 215 inches in accordance with PEI-B13, RPV Control (Non-ATWS).

ANSWER: B

		Level:		RO	SRC
		Tier #		2	2
Examination Outline Cro	oss-Reference	Group	£	1	1
		K/A#		212000	A2.08
		Importa	nce Rating	4.1	4.2
Proposed Answer: See	attached	······			
Explanation (Why the distrac	tors are incorrect):				
A – PEI-B13 is the higher tier	r document that wi	II supercede	• ONI-C71-1.		
C / D - the reactor does not :	scram on high RP	V water leve	el (scrams on	low RPV w	ater level
			Deferre	0 +t	
Control (Non-ATWS) PELB	ases Document	RPV	Reference	Allached.	^_
		, , , , , , , , , , , , , , , , , , , 	(Attach if no	ot previously	/ providec
Proposed references to be p	rovided to applicar	nts during e	xamination:	None	ABCF
Proposed references to be p Learning Objective (As availa	rovided to applicar able): OT-3402-00	nts during e 05-01 Obj E	xamination: 3 OT-3402-0	None 05-02 Obj /	A,B,C,F
Proposed references to be p Learning Objective (As availa Question Source:	rovided to applicar able): OT-3402-00 Bank # Modified Bank New	nts during e	xamination: 3 OT-3402-0	None 05-02 Obj / changes or	A,B,C,F attach pa
Proposed references to be p Learning Objective (As availa Question Source: Question History:	rovided to applicar able): OT-3402-00 Bank # Modified Bank New Previous NRC Previous Quiz	nts during e 05-01 Obj E # Exam / Test	xamination: 3 OT-3402-0	None 05-02 Obj / changes or	A,B,C,F attach pa
Proposed references to be p Learning Objective (As availa Question Source: Question History: Question Cognitive Level:	rovided to applicar able): OT-3402-00 Bank # Modified Bank New Previous NRC Previous Quiz Memory or Fun Comprehensior	nts during e 05-01 Obj E # Exam / Test idamental K n or Analysi	xamination: 3 OT-3402-0 (Note	None 05-02 Obj / changes or (A)	A,B,C,F attach pa

•

QUESTION 93

The plant is in a refueling outage and the M14 Containment Vessel and Drywell Purge System (CVDWP) is operating in the Refuel mode. Containment Ventilation Exhaust Radiation Monitor D17-K609C is in alarm due to a Downscale indication.

An I&C Technician is troubleshooting D17-K609C when the following alarms are received in the Control Room:

- CNTMT & DW PURGE EXHAUST FAN A FLOW LOW
- CNTMT & DW PURGE EXHAUST FAN B FLOW LOW
- CNTMT PURGE SUPPLY FAN A FLOW LOW
- CNTMT PURGE SUPPLY FAN B FLOW LOW
- DW PURGE SUPPLY FAN A FLOW LOW
- DW PURGE SUPPLY FAN B FLOW LOW

Which one of the following conditions is the probable cause for the current status of the CVDWP System?

А.	Either Containment Ventilation Exhaust Radiation Monitor D17-K609A or D17-K609D is in an UPSCALE TRIP (HI-HI) condition due to a refueling accident in Containment.
B.	Containment Ventilation Exhaust Radiation Monitor D17-K609B is in an UPSCALE TRIP (HI-HI) condition due to a refueling accident in Containment.
С.	The I&C Technician inadvertently placed the MODE SWITCH for D17-K609D to the ZERO position.
D.	The I&C Technician inadvertently placed the MODE SWITCH for D17-K609A to the TRIP TEST position.

ANSWER: B

	· · · · · · · ·				
		Level:		RU	SRU
		Tier #		2	2
Examination Outline Cro	ss-Reference	Group	#	2	2
		K/A#		272000) K4.02
		Importa	ance Rating	3.7	4.1
Proposed Question: See	∍ attached				
Proposed Answer: See	attached				
Explanation (Why the distract	ors are incorrect):				
CV/DWP isolation domnars is	olation logic is an 'ir	hd outbd	' logic (either /		B and C)
CVDVVP Isolation dampers is	Jiation logic is all il	ibu-outbu	iogic (entrier P		D and O)
A – Channels A and C or Cha	annels C and D do n	not satisfy	the isolation lo	ogic.	
C – Channels C and D do not	satisfy the isolation	n logic.			
D – Channels A and C do not	satisfy the isolation				
Technical Reference(s): SDM	I-M14_SDM-D17A		Reference A	ttached:	х
			(Attach if not	nroviouok	
			(Attach if not	previousi	/ provided)
Proposed references to be pr	ovided to applicants	s during e	xamination: No	one	
Learning Objective (As availa	ble): OT-3036-003	-M14 Ob	j F, OT-3036-	004-D17A	Obj D
Question Source:	Bank # Modified Bank #		(Note cl	anges or	attach narent)
	New			langes of	allach parenty
		``````````````````````````````````````	<u>`</u>	<u>.</u>	<u></u>
Question History:	Previous NRC E	xam			
	Previous Quiz / 7	Test			
Question Cognitive Level:	Memory or Funda	amental K	nowledge		
Quoodon ooginato zoton	Comprehension of	or Analysi	s	X_(C)	
		•			
40 CED Det 55 Content					
TO CER Part 55 Content.	55 /3				
	·····				·
Comments (Why is it an uppe	er level question): R	equires s	tudent to analy	ze curren	t plant
conditions, and in conjunction	with knowledge of	Cont Ver	t Exhaust Rad	Monitor I	ogic and
CVDWP isolation damper log	ic, determine the re	ason for t	he response o	urrent sta	te of the
CVDWP System.			-		

-

٦

#### QUESTION 94

÷

Control Room HVAC and Emergency Recirculation (M25/26) Train 'A' has been manually shifted from the NORM mode to the EMERG RECIRC mode by placing CONT RM HVAC TRAIN A MODE SELECT, M25-S7, in the EMERG RECIRC position.

Assume <u>no</u> other operator actions were performed.

Which one of the following describes the current damper lineup for M25/26 Train 'A'?

						_
	HVAC A	HVAC A	EMG	HVAC A	HVAC A	
	OTBD SUPP	INBD SUPP	RCIRC	RETURN	EXHAUST	ļ
	DAMPER	DAMPER	DAMPER A	DAMPER	DAMPER	:
	F010A	F020B	F040A	F110A	F130A	
A.	Open	Open	Closed	Open	Closed	
В.	Open	Open	Closed	Closed	Open	
G	<u> </u>		0	Cleard	Classed	
С.	Closed	Closed	Open	Closed	Closed	
П	Closed	Open	Open	Closed	Closed	
υ.	Ciosed	Open	Open	Closed	010504	

ANSWER: D

		Lovoli		RO	SRC
		Level:		- 2	2
	D.f	Group #	t	2	2
Examination Outline Cro	ss-keierence	K/A#	·	29000	3 A4.03
		Importa	nce Rating	2.8	2.8
Proposed Question: See	e attached				
Proposed Answer: See	attached				
Explanation (Why the distract	tors are incorrect):				
A - this is the damper lineup	for the NORMAL m	ode.			
B - this is the damper lineup	for the SMOKE CLI	EAR mode	Э.		
C – Per SOI-M25/26, Section Operator. The question stem damper will be open.	5.5, this damper F stated that no othe	020B mus r operator	t be manual actions wer	lly closed by e performed	r the CR d, therefore
Technical Reference(s): SDM	1-M25/26, SOI-M28	5/26	Reference	Attached:	X
			(Attach if r	not previous	ly provided
Learning Objective (As availa Question Source:	able): OT-3036-002 Bank #	2-M26/26	Obj B & E		
	Modified Bank # New		(Note K	e changes o	r attach pa
Question History:	Previous NRC E Previous Quiz /	Test			
Question Cognitive Level:	Memory or Fund Comprehension	amental k or Analysi	Knowledge is	X	
10 CFR Part 55 Content:	55.41X 55.43				
10 CFR Part 55 Content:	55.41X_ 55.43 er level question) [.]				

· .