June 7, 1999
NEI Meeting

Biff Bradly
Lynette Hendricks

Mike Misner questions assumptions & operator action

3 pages of assumptions - can we give to NEI

Same as 1353 - seismic

Human error - dominates everything

No seismic data for plants

- Aging & equipment qualification of pool equipment

Mike Misner
Seismic
Site visit - only took negatives. Human Error
Seabrook - PRA
Get Releastic - 120 hrs
1353 - Seismic / slow drain down
Lower seismic, raised others up
Gary - previous meeting - qualitative

Q166

If used in past use it
No reason why we can't give assumptions
to industry tomorrow
Do realistic assumptions
at least do comparison
do best estimate
Get over 7day hangup - not war

Stability, Missing opportunity
Not consistent with what ~~staff~~ Commission
wanted
Don't agree with staff approach

Will respond quickly

Art Roan

Human error rates
1% is incredible for not adding
water to pool.

Oyster Creek
Good job prior to shutdown
Near term solution
First round of exemption were to
be submitted in June

Lynette

Lynette
Lack of criteria
Things

Things interim criteria can be done
We really need.

NMSS & burnup credit

Take comments as constructive

Technical team working with NEI ~~Team~~ technical team

Codified in guidance

NMSS - ISG - Interim Staff Guidance

SRP

Appendix J - interim guidance

Staff is not consistent in decommissioning

Can't pin NRC down

What are creditable accidents?
Probably is low enough to ignore

Ray Shadis

Public doesn't like NRC/NEI joint project without public

Discussion on Radiological sabotage missing needs to be addressed

Pete Atherton

~~Superi~~

Critically - Superfically / patronizing

Draft I&C Redundancy, Qualification

Criteria which speifies single failure

Containment - We don't have around SFP