

From: Stuart Richards *SR*
To: John Hannon *JH*
Date: Mon, Oct 25, 1999 3:39 PM
Subject: TWG Study Issues

After the NEI meeting in Portland, last week, Sam wanted to make sure that the impacts on operating units of removing the water from a SFP at a decommissioning site (for example, Millstone and SONGS) is being considered by the TWG. He said the issue came up at Dresden from the freezing event. This is without a zirc fire. Apparently the loss of water shielding can result in increased dose rates at the operating units.

Stu

CC: Diane Jackson, Gary Holahan, George Hubbard, Jo...

Q/106