

5/5/11

# **ACRS Briefing on Spent Fuel Pool Accident Risk for Decommissioning Plants**

01/10



**November 5, 1999**

**Diane Jackson, Technical Working Group Lead Engineer  
SPLB, DSSA**

# **Presentation Purpose**

---

- ◆ **Broad scope effort**
- ◆ **Following process**
- ◆ **Technical assessment progressing**
- ◆ **Addressing stakeholder concerns**
- ◆ **Results will be incorporated into rulemaking and interim exemption criteria**

# **Decommissioning Background**

---

- ◆ **Most NRC operating reactor regulations were not developed considering the transition from power operations to decommissioning**
- ◆ **Staff currently issues exemptions on EP and others on a case-by-case basis**
- ◆ **Commission directed staff to resolve this situation by issuing rules for decommissioning**
  - ◆ **Integrated**
  - ◆ **Risk-informed**
- ◆ **Staff formed the Technical Working Group (TWG) to study spent fuel pool (SFP) accident risk**

# **Technical Working Group (TWG) Product**

- ◆ **TWG output is to provide a technical basis on spent fuel pool (SFP) accident risk that will assist NRR:**
  - ◆ **Develop an integrated rulemaking**
  - ◆ **Provide guidance for interim exemption criteria during rulemaking activities**
  - ◆ **Identify areas of large uncertainty that may merit additional work**
- ◆ **Expectation: Generic study such that licensees would not be required to perform site-specific SFP analysis for reduction in regulation**

# **Technical Working Group (TWG) Study**

- ◆ **A comprehensive review of SFP accidents and associated risk at decommissioning plants did not exist**
- ◆ **Key areas of draft report:**
  - ◆ **Decay time estimation based on thermal hydraulic code analysis**
  - ◆ **Risk assessment**
- ◆ **Risk assessment used a broad set of initiating events:**

<b>Loss of SFP cooling</b>	<b>Tornado missiles</b>	<b>Seismic</b>
<b>Heavy load handling</b>	<b>Internal fire</b>	<b>Aircraft</b>
<b>Loss of SFP inventory</b>		

## **TWG Study (cont.)**

---

- ◆ **Issued draft in June**
  - ◆ **Stakeholder interest in study**
  - ◆ **TWG to gather feedback and additional information**
- ◆ **Staff held several public meetings - April, May, June, July (2-day workshop)**
- ◆ **Received comments and information from stakeholders (e.g., NEI, UCS, individuals) via meetings, telecons, and correspondence**
- ◆ **Major industry concern was that the risk analysis did not give sufficient credit for plant conditions and personnel actions**

# **Areas of Stakeholder Comment**

---

- ◆ **Probabilistic assessment:**
  - ◆ **Seismic events**
  - ◆ **Human reliability**
  - ◆ **Heavy loads**
- ◆ **Deterministic assessment:**
  - ◆ **Adiabatic spent fuel heatup calculation**
  - ◆ **Zirconium ignition temperature**
- ◆ **Criticality**
- ◆ **Safeguards**
- ◆ **Normal operations**
- ◆ **Concrete aging**
- ◆ **Others**

# **Human Reliability Analysis (HRA)**

---

**Issue: HRA values do not give sufficient credit for operator actions**

## **TWG Resolution/Actions:**

- ◆ **Issued draft HRA approach for long term events to identify conditions needed to support a claim of high human reliability**
- ◆ **Provided approach to two HR experts and the public for comment**
- ◆ **No technical comments from public to date**
- ◆ **Based on expert feedback, TWG is revising HRA approach and it will be included in the independent review & final assessment**



# **Heavy Loads**

---

**Issue: Heavy load risk assessment does not give sufficient credit for NUREG-0612 actions (Control of Heavy Loads) and uses upper bound values**

**NEI Actions: Proposed that all decommissioning plants meet NUREG-0612 Phase I and II actions (operating reactors are required to meet Phase I) and provided raw data on cask lifts**

## **TWG Resolution/Actions:**

- ◆ **Reassessed assuming NEI's proposal, improved statistical methods and new information**
- ◆ **Risk values from the reassessment have been included in the independent review**

# **Seismic Events**

---

**Issue: Unique pool characteristics may result in vulnerabilities above the nominal plant (outside scope of TWG assessment)**

**NEI Action: Action item at workshop to propose seismic checklist**

## **TWG Resolution/Actions:**

- ◆ **TWG initial review finds the NEI input is useful for seismic screening of SFPs**
- ◆ **NEI's proposed checklist is included in the independent review**
- ◆ **Additional interactions in the future expected**

# Criticality

---

**Issue: Draft study did not sufficiently evaluate potential for criticality**

- ◆ **Evaluated using deterministic, physics approach**

**TWG Resolution/Actions:**

- ◆ **Reassessing criticality using expanded scope of scenarios**

## **Other Activities**

---

- ◆ **Continuing work to finalize study**
  - ◆ **Additional technical work by NRC contractors**
  - ◆ **Independent, technical, quality review (ITQR)**
  - ◆ **Application of risk-informed principles**

# **Risk-informed Decision Making**

---

- ◆ **Conclusions from the technical study will be formulated using the risk-informed regulatory principles in RG 1.174:**
  - ◆ **Core damage frequency (CDF) & large early release frequency (LERF) goals**
  - ◆ **Defense in depth**
  - ◆ **Safety margins**
  - ◆ **Performance monitoring**
- ◆ **Based on all inputs, a realistic, risk-informed assessment will be developed**

## **TWG Product And Schedule**

---

**TWG is following its plan to finalize its assessment and address stakeholder concerns that will result in a solid technical basis for the development of rulemaking and interim exemption criteria**

- ◆ **Release draft report for public comment in early January 2000**
- ◆ **Release final report in early April 2000**

# BACKUP SLIDES

# **Thermal Hydraulic Assessment**

---

- ◆ **GSI-82 - Severe accidents in SFPs for operating plants**
- ◆ **Complete drain of the pool & heat up of the fuel and clad to the temperature of zirconium oxidation and subsequent ignition**
- ◆ **2 -3 years required to provide sufficient decay such that could not raise clad temperature to oxidation temperature**
- ◆ **Dependent on storage configuration and burnup**



# **Thermal Hydraulic Assessment**

---

- ◆ **Issue: Maximum clad temperature is too conservative (low) compared to zirconium ignition temperature**
- ◆ **Maximum temperature based on preventing temperature excursion due to “runaway” oxidation**
- ◆ **TWG Resolution/Actions:**
  - ◆ **Improve discussion in report to explain the zirconium oxidation reaction and structural limitations on temperature limit**

# **Adiabatic Spent Fuel Heatup Calculation**

## **Issue: Conservative calculation**

- ◆ **Calculated time for one fuel rod to heat up to temperature of zirconium ignition**
- ◆ **Conservative, simple vs. realistic, complex**

## **TWG Resolution/Actions:**

- ◆ **Calculation performed as generic approach of site-specific application**
- ◆ **Conservative assumptions in deterministic calculations can simplify analysis and save licensee and staff resources**
- ◆ **No current plans to use as a generic criterion**

# **Preliminary Risk Assessment**

---

- ◆ **Estimated the frequency of fuel uncovering using:**
  - ◆ **Broad range of initiating events**
  - ◆ **Information gathered on visits to decommissioning sites on system configurations and procedures**
  - ◆ **Amount of redundancy and diversity of SFP heat removal systems, SFP makeup systems, and their support systems is an important assumption**

## **Preliminary Risk Assessment (cont.)**

---

- ◆ **The frequency of fuel uncover is close but not equivalent to the frequency of zirconium fires in SFPs at decommissioned plants**
- ◆ **Personnel identification and response to adverse plant conditions influenced results**
  - ◆ **No automatically actuated systems**
- ◆ **TWG preliminary results identified several credible initiators for decommissioning plants**