

From: Goutam Bagchi *NRR*
To: Glenn Kelly *NRR*
Date: Wed, Jul 12, 2000 8:21 AM
Subject: Revision: Seismic Risk: Spent Fuel Pool Failures at 69 Sites

Glenn,

The distribution of the subject risk numbers is as follows:

All risk numbers are for spent fuel pool failure mat the screening level of 1.2 g peak spectral acceleration (0.5 g peak ground acceleration) per year.

34 sites: > 10E-6

9 sites: between 1x10E-6 and 1.25X10E-6

11 sites: between 1.3X10E-6 and 1.8X10E-6

7 sites: between 2.2X10E-6 and 2.8X10E-6

4 sites: between 4.1X10E-6 and 4.5X10E-6

4 sites: between 5.5 and 13.6X10E-6

Total = 69 sites

In the last batch of 4 sites with risk above 4.5X10E-6, only 3 sites are currently operating and they are Pilgrim, H. B. Robinson and Vogtle.

Thank you,
Goutam
301-415-3305

Thank you,
Goutam
301-415-3305

CC: Diane Jackson, George Hubbard, Jack Strosnider, ...

Q/203