



- THERMOCOUPLES PER PUMP MOTOR UNIT
- TE/A<sub>1</sub> THRUST BEARING, UPPER FACE
  - TE/A<sub>2</sub> THRUST BEARING, LOWER FACE
  - TE/C<sub>1</sub> UPPER GUIDE BEARING
  - TE/C<sub>2</sub> MOTOR WINDING 'A'
  - TE/E<sub>1</sub> MOTOR WINDING 'B'
  - TE/E<sub>2</sub> MOTOR WINDING 'C'
  - RTD/F<sub>1</sub> MOTOR WINDING 'A'
  - RTD/F<sub>2</sub> MOTOR WINDING 'B'
  - RTD/F<sub>3</sub> MOTOR WINDING 'C'
  - TE/G<sub>1</sub> LOWER GUIDE BEARING
  - TE/H<sub>1</sub> #2 SEAL CAVITY
  - TE/J<sub>1</sub> #1 SEAL CAVITY
  - TE/22 SEAL CAVITY COOLING WATER
  - TE/20 MOTOR BEARING COOLING WATER

- NOTES:
1. THIS DRAWING INCLUDES THE FOLLOWING LICENSE RENEWAL SYSTEMS:
    - RR - REACTOR RECIRCULATION
  2. THIS DRAWING IS BASED ON P&ID M-353 SHEET 3 REV 47.

THIS SHEET FOR UNIT 3 ONLY  
MECHANICAL

TABLE OF ADDITIONS & CHANGES			
NO	DATE	DESCRIPTION	BY
1		INITIAL ISSUE FOR LICENSE RENEWAL	

LICENSE RENEWAL DRAWING	
REACTOR RECIRCULATION PUMP SYS	
PEACH BOTTOM APS UNITS 2 & 3	
EJELON	
SHEET 3 OF	LR-M-353

D-51

LR-M-353 (SHT.3)