

Docket No. 50-293

NOV 17 1977

Boston Edison Company
ATTN: Mr. G. Carl Andognini
800 Boylston Street
Boston, Massachusetts 02199

Gentlemen:

Amendment No. 27 to Facility Operating License No. DPR-35 issued on October 17, 1977, included a replacement page 205A for the Technical Specifications for the facility. Through an oversight, page 205A was issued with a missing sentence in Section 3.11.A relating to operation with core flow less than 90% of rated core flow.

Please replace page 205A transmitted with Amendment No. 27 with the enclosed corrected page 205A.

Original signed by



Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Corrected page 205A for TS

cc: See next page

DISTRIBUTION

Docket
NRC PDR
Local PDR
ORB #2 Reading
VStello
KRGoller
TJCarter
DKDavis
RMDiggs
PO'Connor
Deisenhut
RBAer
ØELD
OI&E (5)
BScharf (10)
BJones (4)
JMcGough
BHarless
DRöss

CMiles, OPA
JRBuchanan
TBAbernahty
ACRS (16)



OFFICE >	ORB#2 <i>pwol</i>	ORB#2 <i>DKD</i>			
SURNAME >	PO'Connor:ah	DKDavis			
DATE >	11/17/77	11/17/77			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 17, 1977

Docket No. 50-293

Boston Edison Company
ATTN: Mr. G. Carl Andognini
800 Boylston Street
Boston, Massachusetts 02199

Gentlemen:

Amendment No. 27 to Facility Operating License No. DPR-35 issued on October 17, 1977, included a replacement page 205A for the Technical Specifications for the facility. Through an oversight, page 205A was issued with a missing sentence in Section 3.11.A relating to operation with core flow less than 90% of rated core flow.

Please replace page 205A transmitted with Amendment No. 27 with the enclosed corrected page 205A.

A handwritten signature in cursive script, appearing to read "Don K. Davis".

Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Corrected page 205A for TS

cc: See next page

Boston Edison Company

-2-

November 17, 1977

cc w/enclosure :

Mr. Paul J. McGuire
Pilgrim Station Acting Manager
Boston Edison Company
RFD #1, Rocky Hill Road
Plymouth, Massachusetts 02360

U. S. Environmental Protection Agency
Region I Office
ATTN: EIS COORDINATOR
JFK Federal Building
Boston, Massachusetts 02203

Anthony Z. Roisman, Esquire
Sheldon, Harmon & Roisman
1025 15th Street, N. W., 5th Floor
Washington, D. C. 20005

Henry Herrmann, Esquire
Massachusetts Wildlife Federation
151 Tremont Street
Boston, Massachusetts 02111

Plymouth Public Library
North Street
Plymouth, Massachusetts 02360

Massachusetts Department of Public Health
ATTN: Commissioner of Public Health
600 Washington Street
Boston, Massachusetts 02111

Water Quality & Environmental Commissioner
Department of Environmental Quality
Engineering
100 Cambridge Street
Boston, Massachusetts 02202

Mr. David F. Tarantino
Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, Massachusetts 02360

Chief, Energy Systems Analyses
Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, S. W.
Washington, D. C. 20460

3.11 REACTOR FUEL ASSEMBLYApplicability

The Limiting Conditions for Operation associated with the fuel rods apply to those parameters which monitor the fuel rod operating conditions.

Objective

The Objective of the Limiting Conditions for Operation is to assure the performance of the fuel rods.

SpecificationsA. Average Planar Linear Heat Generation Rate (APLHGR)

During power operation with both recirculation pumps operating, the APLHGR for each type of fuel as a function of average planar exposure shall not exceed the applicable limiting value shown in Figures

3.11-1 and 3.11-2. When core flow is less than 90% of rated core flow, the APLHGR shall not exceed 95% of the limiting value shown in Figure 3.11-1 and 3.11-2.

If at any time during operation it is determined by normal surveillance that the limiting value for APLHGR is being exceeded action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the APLHGR is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits.

4.11 REACTOR FUEL ASSEMBLYApplicability

The surveillance Requirements apply to the parameters which the fuel rod operating conditions.

Objective

The Objective of the Surveillance Requirements is to specify the type and frequency of surveillance to be applied to the fuel rods.

SpecificationsA. Average Planar Linear Heat Generation Rate (APLHGR)

The APLHGR for each type of fuel as a function of average planar exposure shall be determined daily during reactor operation at $\geq 25\%$ rated thermal power.