DISTRIBUTION: Docket File NRC PDR Docket No. 50-293 Docket No. 50-293 KEccleston OELD AEOD IE-2 ACRS-10 Gray File LSchneider DBrinkman RDiggs CMiles ASLAB HShaw TBarnhart-4 RBallard

APR 1 2 1982

Mr. A. Victor Morisi, Manager Nuclear Operations Support Department Boston Edison Company M/C Nuclear 800 Boylston Street Boston, Massachusetts 02199

APR **2 0 1**982 ne handelik bergebaar e

è.

Dear Mr. Morisi:

The Commission has issued the enclosed Amendment No. 60 to Facility Operating License No. DPR-35 for the Pilgrim Nuclear Power Station. This amendment consists of changes to the Technical Specifications in response to your application dated October 15, 1981.

These changes to the Technical Specifications pertain to inservice surveillance and operability requirements of hydraulic and mechnical snubbers in response to our letter of November 20, 1980 relating to snubber surveillance.

In reviewing your application, the BWR Standard Technical Specifications, NUREG-0123, Revision 3, served as the basis in assessing the acceptability of the proposed changes. The Standard Technical Specifications, pages 3/4 7-12 through 3/4 7-18, pertaining to snubbers (and the associated bases) are recognized by the staff as an acceptable implementation of the inservice surveillance and operability requirements pertaining to snubbers.

We have reviewed your submittal and find the proposed Technical Specification changes to be consistent with the BWR Standard Technical Specifications and therefore, conclude that these changes are acceptable.

We have evaluated the potential for environmental impact of plant operation in accordance with the enclosed amendment and have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level, and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR 51.5(d)(4) that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

The amendment does not involve significant new safety information of a type not considered by a previous Commission safety review of the facility. It does not involve a significant increase in the probability or conse-

OFFIC	:E <b>b</b>					 N
SURNA	8205040813 E	20412				 ••••••
DA	P		·····			 ·····
NRC FORM	318 (10-80) NRCM 0240		OFFICIAL	RECORD C	OPY	 USGPO: 1981-2335-960

## Mr. A. V. Morisi

quences of an accident, does not involve a significant decrease in a safety margin, and therefore does not involve a significant hazards consideration. We have also concluded that there is reasonable assurance that the health and safety of the public will not be endangered by this action.

A copy of the related Notice of Issuance is also enclosed.

Sincerely,

ORIGINAL SIGNED BY

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing

Enclosures:

- 1. Amendment No. 60 to DPR-35
- 2. Notice

cc w/enclosures: See next page

				-mon			
	ORB#2:DL	ORB#2:DL/KTE	ORAB:DL	C-ORB#2:DL	AD-OR-DL	OELD	
	SNorris	KEccleston	HShaw A	DVassallo	Thovak	5	
SURNAME P	3/3982	3/31/82:cb	3/31/82	3/3/82	BH5/82	4/9/82	
DATE	l					<u> </u>	L

OFFICIAL RECORD COPY

USGPO: 1981-335-960

Mr. A. Victor Morisi Boston Edison Company

#### cc:

`e ...

Mr. Richard D. Machon Pilgrim Station Manager Boston Edison Company RFD #1, Rocky Hill Road Plymouth, Massachusetts 02360

Resident Inspector c/o U.S. NRC P.O. Box 867 Plymouth, Massachusetts 02360

Henry Herrmann, Esquire Massachusetts Wildlife Federation 151 Tremont Street Boston, Massachusetts 02111

Plymouth Public Library North Street Plymouth, Massachusetts 02360

Massachusetts Department of Public Health ATTN: Commissioner of Public Health 600 Washington Street Boston, Massachusetts 02111

Water Quality & Environmental Commissioner Department of Environmental Quality Engineering 100 Cambridge Street Boston, Massachusetts 02202

Mr. David F. Tarantino Chairman, Board of Selectmen 11 Lincoln Street Plymouth, Massachusetts 02360

Ms. JoAnn Shotwell Office of the Attorney General Environmental Protection Division 1 Ashburton Place 19th Floor Boston, Massachusetts 02108 U. S. Environmental Protection Agency Region I Office Regional Radiation Representative JFK Federal Building Boston, Massachusetts 02203

Ronald C. Haynes Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

### BOSTON EDISON COMPANY

## DOCKET NO. 50-293

# PILGRIM NUCLEAR POWER STATION AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 60 License No. DPR-35

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Boston Edison Company (the licensee) dated October 15, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility Operating License No. DPR-35 is hereby amended to read as follows:
  - B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.60, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8205040815 820412 PDR ADOCK 05000293 P PDR 3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

1000

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: April 12, 1982

# ATTACHMENT TO LICENSE AMENDMENT NO. 60

# FACILITY OPERATING LICENSE NO. DPR-35

# DOCKET NO. 50-293

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment Number and contain a vertical line indicating the area of change.

Remove	Replace
137a	137a
137b	137b
137c	137c
137d	137d
137e	137e
_	137f
-	137g
_	137ĥ
-	137i
151a	151a
224	224

# LIMITING CONDITION FOR OPERATION

#### 3.6.I Shock Suppressors (Snubbers)

 During all modes of operation except Cold Shutdown and Refuel, all safetyrelated snubbers listed in Table 3.6.I(a) and 3.6.I(b) shall be operable except as noted in 3.6.I.2 through 3.6.I.3 below.

> An Inoperable Snubber is a properly fabricated, installed and sized snubber which cannot pass its functional test.

Upon determination that a snubber is either improperly fabricated, installed or sized, the corrective action will be as specified for an inoperable snubber in Section 3.6.I.2.

2. From and after the time that a snubber is determined to be inoperable, replace or repair the snubber during the next 72 hours, and initiate an engineering evaluation to determine if the components supported by the snubber(s) were adversely affected by the inoperability of the snubbers and to ensure that the supported component remains capable of meeting its intended function in the specific safety system involved.

> Further corrective action for this snubber, and all generically susceptible snubbers, shall be determined by an engineering evaluation

3. From and after the time a snubber is determined to be inoperable, improperly fabricated, improperly installed or improperly sized, if the requirements of Section(s) 3.6.I.1 and 3.6.I.2 cannot be met, then the affected safety system, or affected portions of that system, shall be declared inoperable, and the limiting condition for that system entered, as appropriate. SURVEILLANCE REQUIREMENT

4.6.I Shock Suppressors (Snubbers)

The following surveillance requirements apply to all hydraulic and mechanical snubbers listed in Tables 3.6.I(a) and 3.6.I(b).

The required visual inspection interval varies inversely with the observed cumulative number of inoperable snubbers found during an inspection. Inspections performed before that interval has elapsed may be used as a new reference point to determine the next inspection. However, the results of such early inspections performed before the original time interval has elapsed may not be used to lengthen the required interval.

Number of snubbers found inoperable during inspection or during inspection interval:

Inoperable Snubbers	Subsequent Visual Inspec- tion Interval
0	18 Months ± 25%
1	12 Months ± 25%
2	6 Months ± 25%
3.4	124 Days ± 25%
5,6,7	62 Days ± 25%
8 or more	31 Davs

The required inspection interval shall not be lengthened more than one step at a time.

Snubbers may be categorized in two groups, "accessible" or "inaccessible" based on their accessibility for inspection during reactor operation. These two groups may be inspected independently according to the above schedule.

- 1. Visual Inspection Acceptance Criteria
- A. Visual inspections shall verify:

	Southers they be added to or
4.	removed from per 10 CFR 50.59.
	safety related systems without
	prior License Amendment to
	Table 3.6.I(a) or 3.6.I(b)
	provided that a revision to
	the appropriate Table is in-
	cluded with the next license
	amendment request.

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

## 4.6.I Shock Suppressors (Snubbers)

- That there are no visible indications of damage or impaired operability.
- 2. Attachments to the foundation or support structure are such that the functional capability of the snubber is not suspect.
- B. Snubbers which <u>appear INOPER-ABLE</u> as a result of visual inspections may be determined OPERABLE for the purpose of establishing the next visual inspection interval provided that:
  - The cause of the rejection is clearly established and remedied for that particular snubber, and
  - 2. The affected snubber is functionally tested, when necessary, in the as found condition and determined OPERABLE per specifications 4.6.I.2.B., 4.6.I.2.C., as applicable.
  - 3. For any snubber determined inoperable per specification 4.6.I.2, clearly establish the cause of rejection and remedy the problem for that snubber, and any generically susceptible snubber.
- 2. <u>Functional Tests (Hydraulic</u> and Mechanical Snubbers)

A. Schedule

At least once per operating cycle (18 months), a representative sample (10% of the total of each type: hydraulic, mechanical) of snubbers in use in the plant shall be functionally tested, either in place or in a bench test. For each snubber that does not meet the functional test acceptance criteria of

IIMITING CONDITION FOR OPERATION	SURVEILLANCE REQUIREMENT
	4.6.I <u>Shock Suppressors (Snubbers)</u> Specification 4.6.I.2.B, or 4.6.I.2.C, as applicable, an additional 10% of that type of snubber shall be functionally tested.
• •	<ul> <li>B. General Snubber Functional Test Acceptance Criteria (Hydraulic and Mechanical)</li> <li>The general snubber functional test shall verify that:</li> </ul>
	<ol> <li>Activation (restrain- ing action) is achieved within the specified range of velocity or acceleration in both tension and compression.</li> </ol>
	2. Snubber release, or bleed- rate, as applicable, where required; is within the specified range in compression or tension. For snubbers specifi- cally required not to displace under contin- uous load, the ability of the snubber to with- stand load without dis- placement shall be veri-
	fied. C. Mechanical Snubbers Functional Test Acceptance Criteria
	The mechanical snubber functional test shall verify that:
· · · · · · · · · · · · · · · · · · ·	1. The force that initiates free movement of the snubber rod in either tension or compression is less than the specified maximum drag force. Drag force shall not have inc- reased more than 50% since the last functional test.
	3. <u>Snubber Service Life Monitoring</u>
	A. A record of the service file
Amendment No. 60	

ē, i

INTTINC CONDITION FOR OPERATION	SURVEILLANCE REQUIREMENT				
	4.6.I <u>Shock Suppressors (Snubbers)</u> of each snubber, the date at which the designated service life commences and the instal- lation and maintenance records on which the designated service				
	<ul> <li>life is based shall be maintained.</li> <li>B. At least once per cycle, the installation and maintenance records for each snubber listed in Tables 3.6.I(a) and 3.6.I(b) shall be reviewed to verify that the indicated service life has not been exceeded or will not be exceeded prior to the next scheduled snubber service life review. If the indicated service life</li> </ul>				
	will be exceeded prior to the next scheduled snubber service life review, the snubber service life shall be reevaluated, or the snubber shall be replaced or reconditioned so as to extend its service life beyond the date of the next scheduled service life review. This reevaluation, replacement or reconditioning shall be indicated in the records.				
	C. This Snubber Service Life Moni- toring Program shall become effective July 1, 1982.				
•					

137d

-			Table 3.6.I(a)			
		SAFETY RELATI	ED HYDRAULIC SHOCK SU	PRESSORS (SNUBBERS)	)	
Snubber No.	Location	Elevation	Snubber in High Radiation Area During Shutdown	Snubbers Especially Difficult to Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Nord Operation
SS-1-10-1 SS-1-10-2 SS-1-10-3 SS-1-10-4 SS-1-10-5 SS-1-10-6 SS-1-10-7 SS-1-10-7 SS-1-10-8 SS-1-10-9 SS-1-10-10	Main Steam Line Main Steam Line	42' 42' 42' 42' 42' 42' 42' 42' 42' 42'			X (Drywell) X (Drywell)	

42"

42'

41'

41'

44'

41'

44\*

52'

52'

52'

52'

24 '

24

24 \*

24

87'

901

42'

42'

42'

42'

15'

15'

**15** 

Х

х

Х

Х

Х

Х

Х

Main Steam Line

Main Steam Line

Feedwater Sys.

Feedwater Sys.

Feedwater Sys.

Feedwater Sys.

Feedwater Sys.

RHR System

RHR System

**RHR System** 

RHR System

RHR System

RHR System

RHR System

RHR System

RHR System

**RHR** System

Recir. System

Normal

X (Drywell)

Amendment No. 42 60

.\*

.•

SS-1-10-10

SS-1-10-11

SS-1-10-12

SS-6-10-6

SS-6-10-7

SS-6-10-8

SS-6-10-9

SS-6-10-10

SS-10-30-1

SS-10-20-2

SS-10-20-3

SS-10-20-4

SS-10-30-5

SS-10-30-6

SS-10-20-7

SS-10-20-8

SS-10-3-10

SS-10-3-9

SS-2-20-1

SS-2-20-2

SS-2-20-3

SS-2-20-4

SS-2-30-5

SS-2-30-6

SS-2-30-7

137e

Snubber No.	Location	Elevation.	Snubber in High Radiation Area During Shutdown	Snubbers Especially Difficult to Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Normal Operation
SS-2-30-8 SS-2-30-9 SS-2-30-10 SS-2-30-11 SS-2-30-12 SS-2-30-13 SS-2-30-14 SS-2-30-16 SS-2-20-19 SS-2-20-20 SS-2-20-21 SS-2-20-22 SS-2-20-22 SS-2-20-23 SS-2-20-24 SS-2-20-25 SS-2-50-26	Recir. System Recir. System	15' 11' 11' 27' 27' 27' 27' 27' 16' 16' 16' 17' 18' 16' 16' 16' 16'	X X X X X X X X X X X X X X X X X X X		X (Drywell) X (Drywell)	

Ł

ī

۱

Amendment No. 60

137f

	TABLE 3.6.1(a) SAFETY RELATED HYDRAULIC SHOCK SUPPRESSORS (SNUBBERS)									
Snubber No.	Location	Elevation	Snubber in High Radiation Area During Shutdown	Snubbers Especially Difficult to Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Normal Operation				
SS-6-10-1 SS-6-10-2 SS-6-10-3 SS-6-10-4 SS-6-10-5 SS-13-3-1 SS-13-3-2 SS-14-3-1 SS-14-3-2 SS-14-3-3 SS-14-3-4 SS-23-10-1 SS-23-10-2 SS-23-3-31 SS-23-10-34 SS-23-10-34 SS-23-10-35 SS-23-3-37 SS-10-3-43 SS-10-20-44 SS-30-3-45 SS-10-10-46	Feedwater System Feedwater System Feedwater System Feedwater System Redwater System RCIC Core Spray Core Spray Core Spray Core Spray U.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. H.P.C.I. RHR RHR RHR RBCCW RHR	42' 42' 42' 42' 42' 38' 38' 65' 65' 65' 42' 42' -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'09" -3'06" 83'5" 6"			X (Drywell) X (Drywell)	X H.P.C.I. Quadrant X RHR Pump Room X RHR Pump Room X Reactor Building X Torus Compartment				
H-3-1-1292	CRD System		1			l				

Modifications to this Table due to changes in high radiation areas should be submitted to the NRC as part of the next license amendment.

4

ŧ

MS-S-500M.S. Relief Line AMS-S-501M.S. Relief Line AMS-S-502M.S. Relief Line AMS-S-503M.S. Relief Line AMS-S-504M.S. Relief Line AMS-S-505M.S. Relief Line AMS-S-506M.S. Relief Line AMS-S-506M.S. Relief Line AMS-S-507M.S. Relief Line BMS-S-508M.S. Relief Line BMS-S-509M.S. Relief Line BMS-S-509M.S. Relief Line BMS-S-510M.S. Relief Line BMS-S-511M.S. Relief Line BMS-S-512M.S. Relief Line BMS-S-513M.S. Relief Line BMS-S-514M.S. Relief Line BMS-S-515M.S. Relief Line BMS-S-516M.S. Relief Line BMS-S-517M.S. Relief Line BMS-S-518M.S. Relief Line CMS-S-519M.S. Relief Line CMS-S-519 <td< th=""><th>Snubber No.</th><th>Location</th><th>Elevation</th><th>Snubber in High Radiation Area During Shutdown</th><th>Snubbers Especially Difficult to Remove</th><th>Snubbers Inaccessible During Normal Operation</th><th>Snubbers Accessible During Norm Operation</th></td<>	Snubber No.	Location	Elevation	Snubber in High Radiation Area During Shutdown	Snubbers Especially Difficult to Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Norm Operation
MS-S-505M.S. Relief Line AX (Drywell)MS-S-506M.S. Relief Line AX (Drywell)MS-S-507M.S. Relief Line BX (Drywell)MS-S-508M.S. Relief Line BX (Drywell)MS-S-509M.S. Relief Line BX (Drywell)MS-S-510M.S. Relief Line BX (Drywell)MS-S-511M.S. Relief Line BX (Drywell)MS-S-512M.S. Relief Line BX (Drywell)MS-S-513M.S. Relief Line BX (Drywell)MS-S-514M.S. Relief Line BX (Drywell)MS-S-515M.S. Relief Line BX (Drywell)MS-S-516M.S. Relief Line CX (Drywell)MS-S-517M.S. Relief Line CX (Drywell)MS-S-518M.S. Relief Line CX (Drywell)MS-S-519M.S. Relief Line CX (Drywell)MS-S-520M.S. Relief Line CX (Drywell)	MS-S-500 MS-S-501 MS-S-502 MS-S-503 MS-S-504	M.S. Relief M.S. Relief M.S. Relief M.S. Relief M.S. Relief	Line A Line A Line A Line A Line A			X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell)	
MS-S-509M.S. Relief Line BX (Drywell)MS-S-510M.S. Relief Line BX (Drywell)MS-S-511M.S. Relief Line BX (Drywell)MS-S-512M.S. Relief Line BX (Drywell)MS-S-513M.S. Relief Line BX (Drywell)MS-S-514M.S. Relief Line BX (Drywell)MS-S-515M.S. Relief Line BX (Drywell)MS-S-516M.S. Relief Line CX (Drywell)MS-S-517M.S. Relief Line CX (Drywell)MS-S-518M.S. Relief Line CX (Drywell)MS-S-519M.S. Relief Line CX (Drywell)MS-S-520M.S. Relief Line CX (Drywell)MS-S-520M.S. Relief Line CX (Drywell)	MS-S-505 MS-S-506 MS-S-507 MS-S-508	M.S. Relief M.S. Relief M.S. Relief	Line A Line A Line B			X (Drywell) X (Drywell) X (Drywell) X (Drywell)	
MS-S-515M.S. Relief Line BX (Drywell)MS-S-516M.S. Relief Line CX (Drywell)MS-S-517M.S. Relief Line CX (Drywell)MS-S-518M.S. Relief Line CX (Drywell)MS-S-519M.S. Relief Line CX (Drywell)MS-S-520M.S. Relief Line CX (Drywell)	MS-S-509 MS-S-510 MS-S-511 MS-S-512 MS-S-513 MS-S-514	M.S. Relief M.S. Relief M.S. Relief M.S. Relief M.S. Relief M.S. Relief	Line B Line B Line B Line B Line B Line B			X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell)	
	MS-S-515 MS-S-516 MS-S-517 MS-S-518 MS-S-519 MS-S-520	M.S. Relief M.S. Relief M.S. Relief M.S. Relief M.S. Relief M.S. Relief	Line B Line C Line C Line C Line C Line C			X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell)	
MS-S-521M.S. Relief Line CX (Drywell)MS-S-522M.S. Relief Line CX (Drywell)MS-S-523M.S. Relief Line CX (Drywell)MS-S-524M.S. Relief Line CX (Drywell)X (Drywell)X (Drywell)	MS-S-521 MS-S-522 MS-S-523 MS-S-524	M.S. Relief M.S. Relief M.S. Relief M.S. Relief	Line C Line C Line C Line C			X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell)	

Table 3.6.I(b)

# Amendment No.

60

Snubber No.	Location	Elevation	Snubber in High Radiation Area During Shutdown	Snubbers Especially Difficult to Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible . During Normal Operation
MS-S-525 MS-S-526 MS-S-527 MS-S-528 MS-S-529 MS-S-530 MS-S-531 MS-S-532 MS-S-533 MS-S-533	M.S. Relief Line M.S. Relief Line	D D D D D D D D D D D D D D D D			X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell) X (Drywell)	
	· .		•			
1371						

60

**BASES:** 

3.6.I & 4.6.I

#### SHOCK SUPPRESSORS (SNUBBERS)

Snubbers are designed to prevent unrestrained pipe motion under dynamic loads as might occur during an earthquake or severe transient, while allowing normal thermal motion during startup and shutdown. The consequence of an inoperable snubber is an increase in the probability of structural damage to piping as a result of a seismic or other event initiating dynamic loads. It is therefore required that all snubbers required to protect the primary coolant system and all other safety related systems or components be operable during reactor operation.

The visual inspection frequency is based on maintaining a constant level of snubber protection to systems. The cumulative number of inoperable snubbers detected during any inspection interval is the basis for establishment of the subsequent inspection interval and the existing inspection interval should remain in effect until its completion.

When the cause of the rejection of a snubber is clearly established and remedied for that snubber and verified by inservice functional testing, that snubber may be exempted from being counted as inoperable.

Generically susceptible snubbers are those which are of a specific make or model and have the same design features directly related to rejection of the snubber by visual inspection, and are exposed to the same environmental conditions such as temperature, radiation, and vibration.

When a snubber is found inoperable, an engineering evaluation is initiated, in addition to the determination of the snubber mode of failure, in order to determine if any safetyrelated component or system has been adversely affected by the inoperability of the snubber. Initiating this evaluation within 72 hours ensures that prompt corrective action will be afforded.

Hydraulic snubbers and mechanical snubbers may each be treated as a different entity for the above surveillance programs.

The service life of a snubber is evaluated via manufacturer input and information through consideration of the snubber service conditions and associated installation and maintenance records (newly installed snubber, seal replaced, spring replaced, in high radiation area, in high temperature area, etc...). The requirement to monitor the snubber service life is included to ensure that the snubbers periodically undergo a performance evaluation in view of their age and operating conditions. These records will provide statistical bases for future consideration of snubber service life. The requirements for the maintanance of records and the snubber service life review are not intended to affect plant operation. Due to the number and complexity of the relevant interacting factors necessary to develop a comprehensive Service Life Program, this program shall become effective July 1, 1982.

151a

### 3. Special Reports

Special reports shall be submitted as indicated in Table 6.9.1.

#### 6.10 RECORD RETENTION

- A. The following records shall be retained for at least five years:
  - 1. Records of facility operation covering time interval at each power level.
  - 2. Records of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safery.
  - 3. Reportable Occurrence Reports.
  - Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
  - 5. Records of reactor tests and experiments.
  - 6. Records of changes made to Operating Procedures.
  - 7. Records of radioactive shipments.
  - 8. Records of sealed source leak tests and results.
  - 9. Records of annual physical inventory of all source material of record.
- B. The following records shall be retained for the duration of the Operating License:
  - Record and drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
  - 2. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
  - 3. Records of facility radiation and contamination surveys.
  - 4. Records of radiation exposure for all individuals entering radiation control areas.
  - 5. Records of the service lives of all hydraulic and mechanical snubbers listed on Tables 3.6.I(a) and 3.6.I(b) including the date at which the service life commences and associated installation and maintenance records.

# UNITED STATES NUCLEAR REGULATORY COMMISSION DOCKET NO. 50-293 BOSTON EDISON COMPANY NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 60 to Facility Operating License No. DPR-35 issued to Boston Edison Company (the licensee) which revised the Technical Specifications for operation of the Pilgrim Nuclear Power Station (the facility) located near Plymouth, Massachusetts. The amendment is effective as of its date of issuance.

The amendment modifies the Technical Specifications pertaining to inservice surveillance and operability requirements of mechanical and hydraulic snubbers.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since it does not involve a significant hazards consideration.

The Commission has determined that the issuance of the amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of the amendment.

8205040816 82

For further details with respect to this action, see (1) the application for amendment dated October 15, 1981, (2) Amendment No. 60 to License No. DPR-35, and (3) the Commission's letter to the licensee dated April 12, 1982 . All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D. C. and at the Plymouth Public Library, North Street, Plymouth, Massachusetts 02360. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 12th day of April 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing