

AmerGen Energy Company, LLC
Oyster Creek
US Route 9 South
P.O. Box 388
Forked River, NJ 08731-0388

10 CFR 50.55a

July 2, 2001
2130-01-20134

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Oyster Creek Generating Station
Docket No. 50-219
Facility License No. DPR-16
Relief Request No. 26 Clarification

Reference: AmerGen letter No. 2130-01-20063 to USNRC dated April 11, 2001, "Relief Request No. 26"

AmerGen Energy Company, LLC (AmerGen) requested relief from one of the requirements contained in ASME Section XI in the referenced letter. The relief concerns Code Case N-546. The purpose of this letter is to clarify two aspects of the relief request.

The first item concerns visual test requirements. In the referenced letter we made reference to the 1986 Edition of the ASME Boiler and Pressure Vessel Code for visual eye examination requirements. In retrospect, we should have stated that the 1995 Edition of ASME Section XI, Paragraph IWA-2321 would be followed in accordance with the code case.

The second item concerns training and testing requirements. In the referenced letter we stated that, in accordance with the code case, examination personnel would "receive a minimum of four (4) hours of training on Section XI requirements." In addition to this initial training, we will include testing as part of the qualification maintenance process and conduct training and testing on a two to three year frequency.

A047

Oyster Creek Generating Station
2130-01-20063
Page 2 of 2

Should you have any questions or require any additional information please contact Mr. George B. Rombold at 610-765-5516.

Very truly yours,

 FOR R.D.
7/3/06

Ron J. DeGregorio
Vice President
Oyster Creek

c: H. J. Miller, Administrator, USNRC Region I
L. A. Dudes, USNRC Senior Resident Inspector, Oyster Creek
H. N. Pastis, USNRC Senior Project Manager, Oyster Creek
File No. 01042