February 18, 198

Docket No. 50-293

Mr. William D. Harrington Senior Vice President, Nuclear Boston Edison Company 800 Boylston Street Boston, Massachusetts 02199

Dear Mr. Harrington:

SUBJECT: RE-ISSUANCE OF TS SECTIONS 3.11.D AND 4.11.D

Re: Pilgrim Nuclear Generating Station

By letter dated December 2, 1985, Boston Edison identified the need to re-issue Sections 3.11.D and 4.11.D, "Power/Flow Relationship During Power Operation", which were inadvertently deleted from the Pilgrim Technical Specifications (TS) by the NRC during issuance of Amendment 42 to Operating License No. DPR-35.

We agree that Sections 3.11.D and 4.11.D should not have been deleted. Accordingly, we have corrected TS pages ii, 205B-1 and 205C-6 and enclose copies to be used in place of the pages provided in Amendment 42.

Thank you for calling this matter to our attention.

Sincerely,

ORIGINAL SIGNED BY

John A. Zwolinski, Director BWR Project Directorate #1 Division of BWR Licensing

Enclosure: As stated cc: See next page DISTRIBUTION Docket EJordan TBarnhart (4) NRC PDR BGrimes WJones Local PDR **JPartlow** PD#1 RDG PLeech RBernero CJamerson OELD ACRS (10) JZwolinski Pilgrim File DBL:PD#1 A DBL:PD#1 CJamerson PLeech:jg JZwolinski 0713186 2/14/86 1/15/86 8602280518 860218 PDR ADOCK 05000293 PDR

Mr. William D. Harrington Boston Edison Company

Pilgrim Nuclear Power Station

cc: Mr. Charles J. Mathis, Station Mgr. Boston Edison Company RFD #1, Rocky Hill Road Plymouth, Massachusetts 02360

Resident Inspector's Office U. S. Nuclear Regulatory Commission Post Office Box 867 Plymouth, Massachusetts 02360

Mr. David F. Tarantino Chairman, Board of Selectman 11 Lincoln Street Plymouth, Massachusetts 02360

Office of the Commissioner Massachusetts Department of Environmental Quality Engineering One Winter Street Boston, Massachusetts 02108

Office of the Attorney General 1 Ashburton Place 19th Floor Boston, Massachusetts 02108

Mr. Robert M. Hallisey, Director Radiation Control Program Massachusetts Department of Public Health 150 Tremont Street Boston, Massachusetts 02111

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. A. Victor Morisi Boston Edison Company 25 Braintree Hill Park Rockdale Street Braintree, Massachusetts 02184

		Surveillance	Page No.
3.7	CONTAINMENT SYSTEMS	4.7	152
	A. Primary Containment B. Standby Gas Treatment System C. Secondary Containment D. Primary Containment Isolation Valve	A B C Ss D	152 158 159 160
3.8	RADIOACTIVE MATERIALS	4.8	177
	 A. Liquid Effluents B. Airborne Effluents C. (Deleted) 	A B	1 77 179
	D. Environmental Monitoring Program E. Mechanical Vacuum Pump	D E	182 184
3.9	AUXILIARY ELECTRICAL SYSTEMS	4.9	ì 94
	A. Auxiliary Electrical EquipmentB. Operation with Inoperable Equipment	A B	194 195
3.10	CORE ALTERATIONS	4.10	202
	 A. Refueling Interlocks B. Core Monitoring C. Spent Fuel Pool Water Level 	A B C	202 202 203
3.11	REACTOR FUEL ASSEMBLY	4.11	205A
	 A. Average Planar Linear Heat Generation Rate (APLHGR) B. Linear Heat Generation Rate (LHGR) C. Minimum Critical Power Ratio (MCPR) D. Power/Flow Relationship 	A B C D	205A 205A–1 205B 205B–1
3.12	FIRE PROTECTION	4.12	206
	 A. Fire Detection Instrumentation B. Fire Suppression Water System C. Spray and/or Sprinkler Systems D. Halon System E. Fire Hose Stations F. Penetration Fire Barrier G. Dry Chemical Systems H. Yard Hydrants and Exterior 	A B C D E F G	206 206 206c 206d 206e 206e 206e-1
	HOSE HOUSES	H	2066-1
4.0	4 1 Sealed Source Contamination		206K
	4.1 Seared Source containmation4.2 Surveillance Requirements4.3 Reports4.4 Records Retention		206k 206k 2061 2061
8602 PDR	280527 860218 ADOCK 05000263		
Amend Corre	ment No. 84 cted February 18, 1986		ii

· H

LIM	TING CONDITIONS FOR OPERATION
	· · · · · · · · · · · · · · · · · · ·
D.	Power/Flow Relationship During Power Operation
	The power/flow relationship sha not exceed the limiting values shown in Figure 3.11-9. If at any time during power operation it is determined by normal

11 etermined by surveillance that the limiting value for the power-flow relationship is being exceeded. action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the power/flow relationship is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits.

SURVEILLANCE REQUIREMENTS

- N₁ = number of active control rods measured in the ith surveillance test.
- τ_i = average scram time to the 30% insertion position of all rods measured in the ith surveillance test.
- c) The adjusted analysis mean scram time (τ_B) is calculated as follows:

$$\tau_{B} = \mu + 1.65 \left[\frac{N_{+}}{n} \right]^{1/2} \sigma^{1/2}$$

Where:

- μ = mean of the distribution for average scram insertion time to the 30% position 0.945 sec.
- N₁ = total number of active control rod measured in specification 4.3.C.
 - σ = standard deviation of the distribution for average scram insertion time to the 30% position, 0.064 sec.
- D. <u>Power/Flow Relationship During</u> <u>Power Operation</u>

Compliance with the power/flow relationship in Section 3.11.D shall be determined daily during reactor operation.

Amendment No. 54 Corrected February 18, 1986 The K_f factors shown in Figure 3.11-8⁽⁴⁾ are conservative for the Pilgrim Unit 1 operation because the operating limit MCPR given in Specification 3.11C is greater than the original 1.20 operating limit MCPR used for the generic derivation of K_f .

4.11.C MINIMUM CRITICAL POWER RATIO (MCPR) - SURVEILLANCE REQUIREMENT

- At core thermal power levels less than or equal to 25%, the reactor will be operating at minimum recirculation pump speed and the moderator void content will be very small. For all designated control rod patterns which may be employed at this point, operating plant experience indicated that the resulting MCPR value is in excess of requirements by a considerable margin. With this low void content, any inadvertent core flow increase would only place operation in a more conservative mode relative to MCPR. During initial start-up testing of the plant, a MCPR evaluation will be made at 25% thermal power level with minimum recirculation pump speed. The MCPR margin will thus be demonstrated such that future MCPR evaluation below this power level will be shown to be unnecessary. The daily requirement for calculating MCPR above 25% rated thermal power is sufficient since power distribution shifts are very slow when there have not been significant power or control rod changes. The requirement for calculating MCPR when a limiting control rod pattern is approached ensures that MCPR will be known following a change in power or power shape (regardless of magnitude) that could place operation at a thermal limit.

3.11.D Power/Flow Relationship Bases

The power/flow curve is the locus of core thermal power as a function of flow from which the occurrence of abnormal operating transients will yield results within defined plant safety limits. Each transient and postulated accident applicable to operation of the plant was analyzed along the power/flow line. The analysis justifies the operating envelope bounded by the power/flow curve as long as other operating limits are satisfied. Operation under the power/flow line is designed to enable the direct ascension to full power within the design basis for the plant.

Amendment No. 42 Corrected February 18, 1986