

February 22, 1984

Docket No. 50-293

Mr. William D. Harrington
Senior Vice President, Nuclear
Boston Edison Company
800 Boylston Street
Boston, Massachusetts 02199

Dear Mr. Harrington:

On December 29, 1983, the Commission issued Amendment No. 73 to Facility Operating License No. DPR-35 for the Pilgrim Nuclear Power Station. This amendment consisted of a change in Section 2.2B on Page 22 of the Technical Specifications.

Subsequently, it was found that the symbol for "equal to or less than" had inadvertently been left off the 1085 psig limiting safety system setting for Section 2.2A on page 22 of your request dated April 5, 1983 and the page as well. This was not an intended change. Therefore, we are providing herewith a corrected page 22 for Amendment No. 73. We regret any inconvenience this error may have caused you.

Sincerely,

Original signed by/

Paul H. Leech, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut

OELD
ELJordan
JMTaylor
SNorris
PLeech

SECY
LJHarmon
TBarnhart (4)
WJones
DBrinkman

ACRS (10)
OPA, CMiles
RDiggs
Gray File
Extra - 5

DL:ORB#2
SNorris:ajs
02/24/84

DL:ORB#2
PLeech
02/22/84

DL:ORB#2
DVassallo
02/22/84

8403140272 840222
PDR ADDCK 05000293
P PDR

Mr. William D. Harrington
Boston Edison Company
Pilgrim Nuclear Power Station ,

cc:

Mr. Charles J. Mathis, Station Mgr.
Boston Edison Company
RFD #1, Rocky Hill Road
Plymouth, Massachusetts 02360

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Post Office Box 867
Plymouth, Massachusetts 02360

Henry Herrmann, Esquire
Massachusetts Wildlife Federation
151 Tremont Street
Boston, Massachusetts 02111

Water Quality and
Environmental Commissioner
Department of Environmental Quality
Engineering
100 Cambridge Street
Boston, Massachusetts 02202

Mr. David F. Tarantino
Chairman, Board of Selectman
11 Lincoln Street
Plymouth, Massachusetts 02360

Office of the Attorney General
1 Ashburton Place
19th Floor
Boston, Massachusetts 02108

U. S. Environmental Protection
Agency
Region I Office
Regional Radiation Representative
JFK Federal Building
Boston, Massachusetts 02203

Thomas A. Murley
Regional Administrator
Region I Office
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. A. Victor Morisi
Boston Edison Company
25 Braintree Hill Park
Rockdale Street
Braintree, Massachusetts 02184

Mr. Robert M. Hallisey, Director
Radiation Control Program
Massachusetts Department of Public Health
600 Washington Street, Room 770
Boston, Massachusetts 02111

1.2 SAFETY LIMIT

1.2 REACTOR COOLANT SYSTEM INTEGRITY

Applicability:

Applies to limits on reactor coolant system pressure.

Objective:

To establish a limit below which the integrity of the reactor coolant system is not threatened due to an overpressure condition.

Specification:

The reactor vessel dome pressure shall not exceed 1325 psig at any time when irradiated fuel is present in the reactor vessel.

2.2 LIMITING SAFETY SYSTEM SETTING

2.2 REACTOR COOLANT SYSTEM INTEGRITY

Applicability:

Applies to trip settings of the instruments and devices which are provided to prevent the reactor system safety limits from being exceeded.

Objective:

To define the level of the process variables at which automatic protective action is initiated to prevent the pressure safety limit from being exceeded.

Specification:

The limiting safety system settings shall be as specified below:

<u>Protective Action</u>	<u>Limiting Safety System Setting</u>
A. Scram on Reactor Vessel high pressure	≤ 1085 psig
B. Relief/Safety valve settings	Nominal setpoint will be selected between 1095 and 1115 psig. All valves shall be set at this nominal setpoint ± 11 psi.
C. Safety valve settings	$1240 \text{ psig} \pm 13 \text{ psi}$

B403140279 B40222
PDR ADQCK 05000293
P PDR