

December 6, 1994

Mr. Ted C. Feigenbaum
Senior Vice President
and Chief Nuclear Officer
North Atlantic Energy Service Corporation
Post Office Box 300
Seabrook, NH 03874

SUBJECT: CORRECTION TO AMENDMENT 33 TO FACILITY OPERATING LICENSE NPF-86
(TAC M87849)

Dear Mr. Feigenbaum:

On November 23, 1994, the Commission issued Amendment 33 to Facility Operating License NPF-86 for the Seabrook Station, Unit No. 1. It has been brought to my attention that revised page 2-2 as issued did not include revised Figure 2.1-1. Please substitute the enclosed corrected copy of Page 2-2. For convenience, overleaf page 2-1 is included.

Sincerely,

Original signed by:

Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-443
Serial No. SEA-94-028

Enclosure: Corrected Page 2-2, Figure 2.1-1 to Amendment 33

cc w/encl: See next page

DISTRIBUTION:

Docket File
PUBLIC
PDI-4 Plant
SVarga
JZwolinski
PMcKee
SNorris
ADe Agazio
OGC
GHill, IRM (2)
CGrimes, DOPS/OTSB
LLois
ACRS (4)
OPA
OC/LFDCB
JRogge, RGI

9412080227 941206
PDR ADCK 05000443
P PDR

NRC FILE CENTER COPY

DOCUMENT NAME: G:\DEAGAZIO\87849COR

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4				
NAME	SNorris	ADe Agazio:bf	PMcKee				
DATE	12/6/94	12/6/94	12/6/94	12/ /94	12/ /94		

OFFICIAL RECORD COPY

080052

DFC
cp

December 6, 1994

Mr. Ted C. Feigenbaum
Senior Vice President
and Chief Nuclear Officer
North Atlantic Energy Service Corporation
Post Office Box 300
Seabrook, NH 03874

SUBJECT: CORRECTION TO AMENDMENT 33 TO FACILITY OPERATING LICENSE NPF-86
(TAC M87849)

Dear Mr. Feigenbaum:

On November 23, 1994, the Commission issued Amendment 33 to Facility Operating License NPF-86 for the Seabrook Station, Unit No. 1. It has been brought to my attention that revised page 2-2 as issued did not include revised Figure 2.1-1. Please substitute the enclosed corrected copy of Page 2-2. For convenience, overleaf page 2-1 is included.

Sincerely,

Original signed by:

Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-443
Serial No. SEA-94-028

Enclosure: Corrected Page 2-2, Figure 2.1-1 to Amendment 33

cc w/encl: See next page

DISTRIBUTION:

Docket File
PUBLIC
PDI-4 Plant
SVarga
JZwolinski
PMcKee
SNorris
ADe Agazio
OGC
GHill, IRM (2)
CGrimes, DOPS/OTSB
LLois
ACRS (4)
OPA
OC/LFDCB
JRogge, RGI

DOCUMENT NAME: G:\DEAGAZIO\87849COR

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4				
NAME	SNorris	ADe Agazio:bf	PMcKee				
DATE	12/6/94	12/6/94	12/6/94	12/ /94	12/ /94		

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 6, 1994

Mr. Ted C. Feigenbaum
Senior Vice President
and Chief Nuclear Officer
North Atlantic Energy Service Corporation
Post Office Box 300
Seabrook, NH 03874

SUBJECT: CORRECTION TO AMENDMENT 33 TO FACILITY OPERATING LICENSE NPF-86
(TAC M87849)

Dear Mr. Feigenbaum:

On November 23, 1994, the Commission issued Amendment 33 to Facility Operating License NPF-86 for the Seabrook Station, Unit No. 1. It has been brought to my attention that revised page 2-2 as issued did not include revised Figure 2.1-1. Please substitute the enclosed corrected copy of Page 2-2. For convenience, overleaf page 2-1 is included.

Sincerely,

A handwritten signature in cursive script, reading "Albert W. De Agazio, Sr.".

Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-443
Serial No. SEA-94-028

Enclosure: Corrected Page 2-2, Figure 2.1-1 to Amendment 33

cc w/encl: See next page

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

REACTOR CORE

2.1.1 The combination of THERMAL POWER, pressurizer pressure, and the highest operating loop coolant temperature (T_{avg}) shall not exceed the limits shown in Figure 2.1-1 for four-loop operation.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the point defined by the combination of the highest operating loop average temperature and THERMAL POWER has exceeded the appropriate pressurizer pressure line, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.6.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2735 psig.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTION:

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.6.

MODES 3, 4, and 5:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.6.

9412080232 941206
PDR ADOCK 05000443
P PDR




FIGURE 2.1-1

REACTOR CORE SAFETY LIMIT - FOUR LOOPS IN OPERATION

Mr. Ted C. Feigenbaum
North Atlantic Energy Service Corporation

Seabrook Station, Unit No. 1

cc:

Thomas Dignan, Esq.
John A. Ritsher, Esq.
Ropes and Gray
One International Place
Boston, Massachusetts 02110-2624

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, Massachusetts 02108

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
Post Office Box 1149
Seabrook, New Hampshire 03874

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts 01913

Jane Spector
Federal Energy Regulatory Commission
825 North Capital Street, N.E.
Room 8105
Washington, DC 20426

Mr. Jack Dolan
Federal Emergency Management Agency
Region I
J.W. McCormack Post Office &
Courthouse Building, Room 442
Boston, Massachusetts 02109

Mr. T. L. Harpster
North Atlantic Energy Service
Corporation
Post Office Box 300
Seabrook, New Hampshire 03874

Mr. David Rodham, Director
Massachusetts Civil Defense Agency
400 Worcester Road
Post Office Box 1496
Framingham, Massachusetts 01701-0317
ATTN: James Muckerheide

Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Jeffrey Howard, Attorney General
G. Dana Bisbee, Deputy Attorney
General
Attorney General's Office
25 Capitol Street
Concord, New Hampshire 03301

Ms. L. M. Cuoco, Senior Nuclear Counsel
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Mr. Robert Sweeney
Bethesda Licensing Office
Suite 610
3 Metro Center
Bethesda, Maryland 20814

Mr. R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 128
Waterford, Connecticut 06385

Mr. George L. Iverson, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, New Hampshire 03301