

February , 1988

Docket No. 50-293

Mr. Ralph G. Bird  
Senior Vice President - Nuclear  
Boston Edison Company  
800 Boylston Street  
Boston, Massachusetts 02199

Dear Mr. Bird:

SUBJECT: CORRECTION TO AMENDMENT 109 TO FACILITY OPERATING LICENSE  
NO. DPR-35 (TAC#65523) PILGRIM NUCLEAR POWER STATION

By letter dated January 11, 1988, we issued a correction to page 109 issued with Amendment No. 109 indicating that a deletion bar was missing. However, due to an administrative error the deletion bar is incorrect. Section 4.5.E.1a was modified by Amendment 106 to include the ADS manual inhibit switch as a test requirement. Amendment 106 was approved and issued by the NRC on September 4, 1987.

We request that you disregard our correction letter of January 11, 1988. We have enclosed a corrected page 109 which includes the ADS manual inhibit switch as a test requirement in Section 4.5.E.1a as approved in Amendment 106.

Please substitute the enclosed corrected page 109 for the previous one provided with Amendment 109.

We regret any inconvenience resulting from this administrative error.

Sincerely,

5 | Original signed by:

Daniel G. McDonald, Project Manager  
Project Directorate I-3  
Division of Reactor Projects I/II

Enclosure:  
As Stated

cc: See next page

OFC	: PDI-3	: PDI-3	: DIR/PDI-3	:	:	:	:
NAME	: MRushbrook	: DMcDonald	: RWessman	:	:	:	:
DATE	: 02/11/88	: 02/16/88	: 02/16/88	:	:	:	:

OFFICIAL RECORD COPY

8802230371 880216  
PDR ADDCK 05000293  
PDR

LIMITING CONDITION FOR OPERATIONSURVEILLANCE REQUIREMENT3.5.D Reactor Core Isolation Cooling (RCIC) Subsystem (Cont'd)

2. From and after the date that the RCICS is made or found to be inoperable for any reason, continued reactor power operation is permissible only during the succeeding seven days provided that during such seven days the HPCIS is operable.
3. If the requirements of 3.5.D cannot be met, an orderly shutdown shall be initiated and the reactor pressure shall be reduced to or below 150 psig within 24 hours.

3.5.E Automatic Depressurization System (ADS)

1. The Automatic Depressurization Subsystem shall be operable whenever there is irradiated fuel in the reactor vessel and the reactor pressure is greater than 104 psig and prior to a startup from a Cold Condition, except as specified in 3.5.E.2 below.

4.5.D Reactor Core Isolation Cooling (RCIC) Subsystem (Cont'd)

- d. Flow Rate Once/3 months at 1000 psig
  - e. Flow Rate Once/operating at 150 psig cycle
- The RCIC pump shall deliver at least 400 gpm for a system head corresponding to a reactor pressure of 1000 to 150 psig.

2. When it is determined that the RCIC subsystem is inoperable, the HPCIS shall be demonstrated to be operable immediately and weekly thereafter.

4.5.E Automatic Depressurization System (ADS)

1. During each operating cycle the following tests shall be performed on the ADS:
  - a. A simulated automatic actuation test shall be performed prior to startup after each refueling outage. The ADS manual inhibit switch will be included in this test.
  - b. With the reactor at pressure, each relief valve shall be manually opened until a corresponding change in reactor pressure or main turbine bypass valve positions indicate that steam is flowing from the valve.
  - c. Perform a test from the alternate shutdown panel to verify that the relief valve solenoids actuate. Test shall be performed after each refueling outage prior to startup.

CORRECTION TO AMENDMENT 109

DISTRIBUTION:

Docket File  
NRC & Local PDRs  
PDI-3 R/F  
BBoger  
MRushbrook  
DMcDonald  
SVarga  
OGC  
DHagan  
EJordan  
JPartlow  
TBarnhart  
WJones  
EButcher  
ARCS (10)  
GPA/PA  
ARM/LFMB