

Item #6.

IG RESPONSE SENTENCE

According to the resident inspectors at Indian Point Unit 2, they initiated dialogue with Con Edison to discuss procedural actions within abnormal operating instruction on steam generator tube leak and compared those actions with industry standards. The inspectors wanted to be notified by Con Edison when primary to secondary leakage got to 5 gallons per day. The intention was to understand any further actions for which Con Edison may take to due an adverse trend.

NRC Resident Inspector - Pete Habighorst
WP file

A/25

ITEM # 55