

From: Alfred Lohmeier
To: David Lew, Michael Modes, Wayne Lanning
Date: Mon, Apr 3, 2000 3:36 PM
Subject: IP2 teleconf 4/3/2000 notes

Attached please find subject notes.

FILED 86 — A/56 (2)

MEMORANDUM

TO: W. Lanning
D. Lew
M.Modes

FROM: A. Lohmeier

SUBJECT: TELECONF 04/03/2000 RE IP2 S/G INSPECTION

1. The Latest inspection summary report indicates 99.08% of the eddy current inspections have been completed. As a result of the inspections, there have been found a total of 382 tubes considered pluggable. The largest portion of the pluggable tubes are Row 2 tubes (223 tubes)
2. In-situ pressure tests are being conducted on 11 tubes having flaws in the small radius U-bends (5), sludge pile (5), and tubesheet crevice (1). Of 5 U-bends in SG 24 treated, leakage reported on 3. In-situ tests on S/G 21, 22, and 23 yet to be conducted.
3. S/G 22 over 15% plugged - looking at derating.
4. S/G 21 and 24, 600 plugs drilled out and replugged with I 690 plugs.
5. Problem on some tubes getting probe into U=bend. Trying to get someone to provide a probe that can.
6. Root cause of failure to be determined by end of this week.
7. Licensee believes S/Gs will be wrapped up next week Emmet believes there remain some dangling issues. Emmet concerned about tube ovality.
8. Some UT done on 22 S/G to check indications, results due Wednesday.
9. Cass Dodd reviewing high f results.
10. Today discussed Emmet's interest in ovality and in-situ testing with Stephanie Coffin.
11. Teleconference tomorrow at 10 am.