

From: Leanne Harrison
To: Pete Eselgroth, Scott Barber
Date: Fri, May 12, 2000 3:38 PM
Subject: Today's S/G phone call

Here's what happened during today's 10am phone call between NRR (Emmett Murphy and George Wunder) and Con Ed (Baumstark, McCann, et. al.) with input from Westinghouse (onsite and in Pittsburgh).

Essentially nothing new - it was a recap of this week's events. 6 tubes plugged total in 3 s/gs. One was plugged in s/g no. 22 (414); four plugged in s/g no. 23 (370, 1162, 1264, and 453); and one plugged in s/g no. 24 (1087).

Westinghouse has completed all of their reviews not and now the licensee has brought in a third company - CORESTAR (sp?) to develop an independent plugging list based on their review of the raw data/ eddy current testing results. Then both plugging lists will be compared.

Westinghouse QA has initiated their root cause analysis (although very hesitant to say they believe that the lack of verification of the plug list by an independent reviewer using an independent process to develop the plugging list contributed to the human error that affected 4plugs. They are continuing their RCA to figure out why the last 2 tubes that were in-situ tested were not plugged.)

CORESTAR's review results are expected by the end of next week. They have over 250,000 documents to review.

ConEd believes that as a result of using the plus-point probe, they are actually detecting smaller flaw sizes.

Emmett Murphy told them that he doesn't have confidence the flaws are being picked out from the noise.

Mid next week: licensee to discuss the 17 topics from the meeting held at HQ last week.

CC: David Lew

ITEM 132

A194