

From: Wayne Schmidt
To: Diane Screnci, William Raymond
Date: Fri, Aug 18, 2000 3:06 PM
Subject: Re: IP2 SG inspection question

To this point Con Ed did not pull any tubes following the event. Don't know about the florida, but the feedwater needs to meet specifications and gerneally this would require much lower levels of elements than normal drinkning water. I think they do use city water as at least part of their makeup supply, but this would be demineralized prior to use. (strong teeth weak SG tubes?)

Any comments Bill?

①

A1163