

October 26, 1982

DMB 016

DISTRIBUTION

Docket File

PWagner
RIngram
Gray File+4
EBlackwood
Hornstein

Dockets Nos. 50-269, 50-270
and 50-287

NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
AEOD
EHarmon-2
ACRS-10
TBarnhart-12
LSchneider
OGC
OPA
DBrinkman
RDiggs
ASLAB

Mr. H. B. Tucker
Vice President - Nuclear Production
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

The Commission has issued the enclosed Amendment Nos. 114, 114, and 111 for Licenses Nos. DPR-38, DPR-47 and DPR-55 for the Oconee Nuclear Station, Units Nos. 1, 2 and 3. These amendments consist of changes to the Station's common Technical Specifications (TSs) in response to your request dated October 14, 1982, as telecopied to us. These amendments were authorized by telephone on October 14, 1982, and were confirmed by letter dated October 15, 1982.

These amendments revise the TSs to allow the pressurizer code safety valves on Oconee Unit 1 to be degraded from October 14, 1982, through October 29, 1982. These amendments were issued on an expedited basis to permit Unit 1 to continue operation based on our Safety Evaluation.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

APPROVED AND SIGNED BY

Philip C. Wagner, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. Amendment No. 114 to DPR-38
2. Amendment No. 114 to DPR-47
3. Amendment No. 111 to DPR-55
4. Safety Evaluation
5. Notice

cc/w/enclosures:

See next page

*See previous white for concurrences.

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL	AD:OR:DL	OELD		
SURNAME	RIngram;cf	PWagner*	JStolz*	Slainas	R. T. Dawson		
	10/18/82	10/18/82	10/18/82	10/18/82	10/22/82		

8211060644 821026
NF PDR ADCK 05000269
P PDR

OFFICIAL RECORD COPY

Dockets Nos. 50-269, 50-270
and 50-287

Mr. H. B. Tucker
Vice President - Nuclear Production
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

DISTRIBUTION
Docket File PWagner
NRC PDR RIngram
L PDR Gray File+4
ORB#4 Rdg EBlackwood
RDEisenhut HOrnstein
OELD
AEOD
EHarmon-2
ACRS-10
TBarnhart-12
LSchneider
OGC
OPA
DBrinkman
RDiggs
ASLAB

Dear Mr. Tucker:

The Commission has issued the enclosed Amendment Nos. , , and for Licenses Nos. DPR-38, DPR-47 and DPR-55 for the Oconee Nuclear Station, Units Nos. 1, 2 and 3. These amendments consist of changes to the Station's common Technical Specifications (TSs) in response to your request dated October 14, 1982, and telecopied to us. These amendments were authorized by telephone on October 14, 1982, and were confirmed by letter dated October 15, 1982.

These amendments revise the TSs to allow the pressurizer code safety valves on Oconee Unit 1 to be degraded from October 14, 1982, through October 29, 1982. These amendments were issued on an expedited basis to allow continued Unit 1 operation until Units 2 and/or 3 were returned to service and replacement valves were available.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Philip C. Wagner, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. Amendment No. to DPR-38
2. Amendment No. to DPR-47
3. Amendmdnt No. to DPR-55
4. Safety Evaluation
5. Notice

cc w/enclosures:
See next page

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL	AD:OR:DL	OELD		
SURNAME	PRIngram	PWagner;cf.	JS to J	GLAinas			
DATE	10/18/82	10/18/82	10/18/82	10/ /82	10/ /82		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DISTRIBUTION
Docket File
ORB#4 Rdg
RIngram

October 26, 1982

Docket No. 50-269, 50-270
and 50-287

Docketing and Service Section
Office of the Secretary of the Commission

SUBJECT: OCONEE NUCLEAR STATION, UNITS NOS. 1, 2 AND 3

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Other: Amendment Nos. 114, 114, 111.

Referenced documents have been provided PDR.

Division of Licensing, ORB#4
Office of Nuclear Reactor Regulation

Enclosure:
As Stated

OFFICE →	ORB#4:DI					
SURNAME →	RIngram,cf					
DATE →	10/28/82					

Duke Power Company

cc w/enclosure(s):

Mr. William L. Porter
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

Honorable James M. Phinney
County Supervisor of Oconee County
Walhalla, South Carolina 29621

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

William T. Orders
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Manager, LIS
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

J. Michael McGarry, III, Esq.
DeBevoise & Liberman
1200 17th Street, N.W.
Washington, D. C. 20036



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-269

OCONEE NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.114
License No. DPR-38


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duke Power Company (the licensee) dated October 14, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility Operating License No. DPR-38 is hereby amended to read as follows:

3.B Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.114 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment was effective October 14, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 26, 1982



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-270

OCONEE NUCLEAR STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 114
License No. DPR-47


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duke Power Company (the licensee) dated October 14, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility Operating License No. DPR-47 is hereby amended to read as follows:

3.B Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 114 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment was effective October 14, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 26, 1982



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-287

OCONEE NUCLEAR STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 111
License No. DPR-55


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duke Power Company (the licensee) dated October 14, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility Operating License No. DPR-55 is hereby amended to read as follows:

3.B Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 111 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment was effective October 14, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 26, 1982

ATTACHMENTS TO LICENSE AMENDMENTS

AMENDMENT NO. 114 TO DPR-38

AMENDMENT NO. 114 TO DPR-47

AMENDMENT NO. 111 TO DPR-55

DOCKETS NOS. 50-269, 50-270 AND 50-287

Replace page 3.1-1 of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by amendment numbers and contains vertical lines indicating the area of change.

3.1 REACTOR COOLANT SYSTEM

Applicability

Applies to the operating status of the reactor coolant system.

Objective

To specify those limiting conditions for operation of the reactor coolant system components which must be met to ensure safe reactor operation.

Specification

3.1.1 Operational Components

a. Reactor Coolant Pumps

1. Whenever the reactor is critical, single pump operation shall be prohibited, single-loop operation shall be restricted to testing, and other pump combinations permissible for given power levels shall be as shown in Table 2.3-1.
2. Except for test purposes and limited by Specification 2.3, power operation with one idle reactor coolant pump in each loop shall be restricted to 24 hours. If the reactor is not returned to an acceptable RC pump operating combination at the end of the 24-hour period, the reactor shall be in a hot shutdown condition within the next 12 hours.
3. The boron concentration in the reactor coolant system shall not be reduced unless at least one reactor coolant pump or one low pressure injection pump is circulating reactor coolant.

b. Steam Generator

1. One steam generator shall be operable whenever the reactor coolant average temperature is above 250°F.

c. Pressurizer Safety Valves

- *1. All pressurizer code safety valves shall be operable whenever the reactor is critical.
2. At least one pressurizer code safety valve shall be operable whenever all reactor coolant system openings are closed, except for hydrostatic tests in accordance with the ASME Section III Boiler and Pressure Vessel Code.

*The requirements of Specification 3.1.1.c.1 are waived for Unit 1 until 11:59pm, October 29, 1982.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 114 TO FACILITY OPERATING LICENSE NO. DPR-38

AMENDMENT NO. 114 TO FACILITY OPERATING LICENSE NO. DPR-47

AMENDMENT NO. 111 TO FACILITY OPERATING LICENSE NO. DPR-55

DUKE POWER COMPANY

OCONEE NUCLEAR STATION, UNITS NOS. 1, 2 AND 3

DOCKETS NOS. 50-269, 50-270 AND 50-287

Introduction

Duke Power Company (Duke or the licensee) informed the NRC staff of problems with the pressurizer code safety valves at the Oconee Nuclear Station on October 14, 1982. Following a number of telephone conversations on this subject, Duke submitted an amendment application via telecopy, which requests that the requirements for these valves be waived for Unit 1 until October 30, 1982 to allow time for the other Units (Units 2 and 3 were both shutdown) to return to operation and to obtain replacement valves. The problem with the valves occurs due to the positioning of the three, movable ring assemblies which control the lift setpoint and the blowdown capacity of the valve.

Following staff discussion and evaluation of the information provided by Duke in their October 14, 1982 application, it was decided that interim operation of Oconee Unit 1 was acceptable until 11:59pm on October 29, 1982. Our evaluation is presented below.

Duke was informed of our decision and given permission to continue operation of Oconee Unit 1 until 11:59pm, October 29 on October 14, 1982; this permission was confirmed by letter dated October 15, 1982.

Evaluation

The licensee has proposed to operate Unit 1 for the period October 14, 1982 to October 29, 1982 with the Reactor Coolant System (RCS) safety valves declared inoperable on the basis of the low probability of needing the safety valves and on an analysis of the limiting anticipated transients and accidents which demonstrates that the RCS pressure limit of 2750 psig would not be exceeded for these events.

The low probability of challenging the safety valves is based on a review of operating experience for Babcock & Wilcox (B&W) and Westinghouse PWR's. The estimated mean annual frequency for safety valve challenges is quoted as 4.8×10^{-5} . This value is consistent with the NRC staff's understanding of operating experience.

8211060662 821026
PDR ADOCK 05000269
PDR

The limiting events relative to overpressurization were reanalyzed by the licensee using the RELAP computer code and using the core physics parameters appropriate for the present time in core cycle. These analyses are summarized in the licensee's letter of October 14, 1982 and indicate that the peak RCS pressure would be less than 2750 psig. These analyses are consistent with the Final Safety Analysis Report (FSAR) analyses which indicate that little safety valve discharge would be required to protect against a design basis accident.

Therefore, we find that even in the unlikely event that the RCS safety valves are called upon within the October 14, 1982 to October 29, 1982 period, the RCS pressure limit would not be exceeded as a result of degraded valve performance. As a result of our review, we find that operation in the proposed mode is acceptable.

Environmental Consideration

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of an accident previously evaluated, do not create the possibility of an accident of a type different from any evaluated previously, and do not involve a significant reduction in a margin of safety, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: October 26, 1982

The following NRC personnel have contributed to this Safety Evaluation:
Philip Wagner, Gary Holahan.

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKETS NOS. 50-269, 50-270 AND 50-287DUKE POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendments Nos. 114, 114 and 111 to Facility Operating Licenses Nos. DPR-38, DPR-47 and DPR-55, respectively, issued to Duke Power Company, which revised the Technical Specifications (TSs) for operation of the Oconee Nuclear Station, Units Nos. 1, 2 and 3, located in Oconee County, South Carolina.

These amendments were authorized by telephone on October 14, 1982, and were confirmed by letter dated October 15, 1982; they were issued on an expedited basis to permit Unit 1 to continue operation based on the Commission's Safety Evaluation. These amendments change the TSs to allow the pressurizer code safety valves on Oconee Unit 1 to be degraded from October 14 through 29, 1982.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §1.5(d)(4) an environmental impact statement or negative declaration


-2-

and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated October 14, 1982, (2) the Commission's letter to the licensee dated October 15, 1982, (3) Amendments Nos. 114 , 114 , and 111 to Licenses Nos. DPR-38, DPR-47 and DPR-55, respectively, and (4) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Oconee County Library, 501 West Southbroad Street, Walhalla, South Carolina. A copy of items (2), (3) and (4) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 26th day of October 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing