

August 21, 1991

Docket Nos. 50-269, 50-270 and 50-287

DISTRIBUTION:

MEMORANDUM FOR: Sholly Coordinator

Docket File  
NRC & Local PDRs  
Sholly Coordinator  
PDII-3 R/F  
Oconee R/F  
LWiens  
LBerry

FROM: Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE  
OF ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSES  
(TACS 79876/79877/79878)

Duke Power Company, Docket Nos. 50-269, 50-270 and 50-287, Oconee Nuclear  
Station, Units 1, 2 and 3, Oconee County, South Carolina

Date of application for amendments: February 11, 1991

Brief description of amendments: The amendments revise the value for the  
containment free volume (CFV) currently specified in Technical Specification  
(TS) 5.2.1 and associated bases. The changes identify a CFV value based on the  
as-built drawings instead of the preliminary estimates made prior to the completion  
of the containment.

Date of issuance: August 21, 1991

Effective date: August 21, 1991

Amendment Nos.: 189, 189, 186

Facility Operating License Nos. DPR-38, DPR-47 and DPR-55. Amendments revised  
the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: May 1, 1991 (56 FR 20034)

The Commission's related evaluation of the amendments is contained in a Safety  
Evaluation dated August 21, 1991.

No significant hazards consideration comments received: No.

Local Public Document Room location: Oconee County Library, 501 West South  
Broad Street, Walhalla, South Carolina 29691

/s/

9109050046 910821  
PDR ADDCK 05000269  
P FOR

Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

*CP*  
*DFOL*  
*110*

LA:PDII-3  
LBerry  
7/10/91

PM:PDII-3  
LWiens  
7/17/91

D:PDII-3  
DMatthews  
8/20/91

**NRC FILE CENTER COPY**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

August 21, 1991

Docket Nos. 50-269, 50-270 and 50-287

MEMORANDUM FOR: Sholly Coordinator

FROM: Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE  
OF ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSES  
(TACS 79876/79877/79878)

Duke Power Company, Docket Nos. 50-269, 50-270 and 50-287, Oconee Nuclear  
Station, Units 1, 2 and 3, Oconee County, South Carolina

Date of application for amendments: February 11, 1991

Brief description of amendments: The amendments revise the value for the  
containment free volume (CFV) currently specified in Technical Specification  
(TS) 5.2.1 and associated bases. The changes identify a CFV value based on the  
as-built drawings instead of the preliminary estimates made prior to the completion  
of the containment.

Date of issuance: August 21, 1991

Effective date: August 21, 1991

Amendment Nos.: 189, 189, 186

Facility Operating License Nos. DPR-38, DPR-47 and DPR-55. Amendments revised  
the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: May 1, 1991 (56 FR 20034)

The Commission's related evaluation of the amendments is contained in a Safety  
Evaluation dated August 21, 1991.

No significant hazards consideration comments received: No.

Local Public Document Room location: Oconee County Library, 501 West South  
Broad Street, Walhalla, South Carolina 29691

A handwritten signature in black ink, appearing to read "L. A. Wiens".

Leonard A. Wiens, Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation