



July 12, 2001
NMP1L 1602

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
 Docket No. 50-220
 DPR-63

Subject: Monthly Operating Report for June 2001

Gentlemen:

Submitted herewith are the Operating Data Report, Unit Shutdowns, and a Narrative of Operating Experience for June 2001 for the Nine Mile Point Nuclear Station Unit 1. Submittal of this information complies with Section 6.9.1.c of the Unit 1 Technical Specifications.

Very truly yours,

A handwritten signature in dark ink, appearing to read "L. A. Hopkins".

L. A. Hopkins
Plant Manager – Unit 1

LAH/IAA/mlg
Attachments

cc: Mr. H. J. Miller, NRC Regional Administrator, Region I
 Mr. G. K. Hunegs, NRC Senior Resident Inspector
 Records Management

IE24

ATTACHMENT A
OPERATING DATA REPORT

DOCKET NO: 50-220
DATE: 7/3/01
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

OPERATING STATUS

Unit Name: Nine Mile Point Unit #1
Reporting Period: June 2001

1	Design Electrical Rating: (Net MWe)	613
2	Maximum Dependable Capacity: (Net MWe)	565

	This Month	Yr-to-Date	Cumulative
3 Critical Hours	720.0	3,170.4	192,730.4
4 Hours Generator On-Line	720.0	3,109.4	188,399.7
5 Unit Reserve Shutdown Hours	0.0	0.0	20.4
6 Net Electrical Energy Generated (MWH)	435,884.0	1,840,204.0	104,493,016.0

ATTACHMENT B

UNIT SHUTDOWNS REPORTING PERIOD – JUNE 2001

DOCKET NO: 50-220
UNIT NAME: NMP1
DATE: 7/3/01
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

NO.*	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASONS ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
						No shutdown occurred in June

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/License Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1. Manual
- 2. Manual Trip/Scram
- 3. Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

*NOTE: Sequential numbering used.

ATTACHMENT C

NARRATIVE OF OPERATING EXPERIENCE

DOCKET NO: 50-220

UNIT NAME: NMP1

DATE: 7/3/01

PREPARED BY: P. E. Netusil

TELEPHONE: (315) 349-7935

The unit operated during the month of June 2001 with a net electrical design capacity factor of 98.8%. There were no challenges to the electromatic relief valves or safety valves during the operating period.