



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37384-2000

July 13, 2001

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT - JUNE MONTHLY OPERATING REPORT

The enclosure provides the June Monthly Operating Report as required by Sequoyah Technical Specifications Section 6.9.1.10.

In accordance with NRC RIS 2001-05, only one paper copy of this document is being sent to the NRC Document Control Desk.

If you have any questions concerning this matter, please call me at (423) 843-7170 or J. D. Smith at (423) 843-6672.

Sincerely,

A handwritten signature in dark ink, appearing to read "Pedro Salas", written over a circular stamp or seal. The signature is written in a cursive, somewhat stylized manner.

Pedro Salas

Enclosure
cc: See page 2

IE24

U.S. Nuclear Regulatory Commission
Page 2
July 13, 2001

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5947

Ms. Barbara Lewis, Assistant Editor, Database
McGraw-Hill, Inc.
1200 G Street, NW, Suite 1100
Washington, D.C. 20005

(Via NRC Electronic Distribution)
Mr. R. W. Hernan, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37384-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

U.S. Nuclear Regulatory Commission
Page 2
July 13, 2001

JDS:JWP:SJM

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5947

Ms. Barbara Lewis, Assistant Editor, Database
McGraw-Hill, Inc.
1200 G Street, NW, Suite 1100
Washington, D.C. 20005

(Via NRC Electronic Distribution)
Mr. R. W. Hernan, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37384-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

D. K. Baker, BR 3H-C
J. L. Beasley, OPS 4A-SQN
M. J. Burzynski, BR 4X-C
C. C. Cross, LP 6A-C
M. E. Easter, Westinghouse, POB 2E-SQN
T. A. Keys, BR 6A-C
D. L. Koehl, POB 2B-SQN
D. C. Olcsvary, LP 6A-C
R. T. Purcell, OPS 4A-SQN
NSRB Support, LP 5M-C
J. A. Scalice, LP 6A-C
K. W. Singer, LP 6A-C
J. Valente, OPS 4A-SQN (Attn: T. J. Hollomon)
EDMS, WT 3B-K

I:\LICENSE\monthly operating report\MOR062001

ENCLOSURE

**TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT (SQN)**

MONTHLY OPERATING REPORT

JUNE 2001

UNIT 1

DOCKET NUMBER 50-327

LICENSE NUMBER DPR-77

UNIT 2

DOCKET NUMBER 50-328

LICENSE NUMBER DPR-79

OPERATING DATA REPORT

Docket No. 50-327
 Unit Name SQN Unit 1
 Date July 3, 2001
 Completed By T. J. Hollomon
 Telephone (423) 843-7528

Reporting Period

1. Design Electrical Rating (Net MWe): 1148
2. Maximum Dependable Capacity (MWe-Net) 1122

	Month	Yr-to-Date	Cumulative
3. Number of Hours Reactor was Critical	720.0	4,343	113,036.7
4. Hours Generator On-Line	720.0	4,343.0	111,134.0
5. Unit Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh)	812,030	4,970,662	120,282,237

Docket No. 50-328
 Unit Name SQN Unit 2
 Date July 3, 2001
 Completed By T. J. Hollomon
 Telephone (423) 843-7528

Reporting Period

1. Design Electrical Rating (Net MWe): 1148
2. Maximum Dependable Capacity (MWe-Net): 1117

	Month	Yr-to-Date	Cumulative
3. Number of Hours Reactor was Critical	720.0	4,343.0	117,089
4. Hours Generator On-Line	720.0	4,343.0	115,037.1
5. Unit Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Generated (MWh)	813,999	4,950,372	122,192,561

UNIT SHUTDOWNS

DOCKET NO: 50-327
UNIT NAME: SQN-1
DATE: July 3, 2001
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

REPORT PERIOD: JUNE 2001

No.	Date	Type F:Forced S:Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause and Corrective Action to Prevent Recurrence

Summary: Unit 1 operated at 100 percent power throughout the month of June with a capacity factor of 100.2 percent. No PORVs or safety valves were challenged in June.

¹ Reason:

A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H- Other (Explain)

² Method

1-Manual
 2-Manual Trip/Scram
 3-Automatic Trip/Scram
 4-ContinuationOutage
 5-Other (Explain)

UNIT SHUTDOWNS

DOCKET NO: 50-328
UNIT NAME: SQN-2
DATE: July 3, 2001
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

REPORT PERIOD: JUNE 2001

No.	Date	Type F:Forced S:Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause and Corrective Action to Prevent Recurrence

Summary: Unit 2 operated at 100 percent power throughout the month of June with a capacity factor of 100.9 percent. No PORVs or safety valves were challenged in June.

¹ Reason:

A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H- Other (Explain)

² Method

1-Manual
 2-Manual Trip/Scram
 3-Automatic Trip/Scram
 4-ContinuationOutage
 5-Other (Explain)