

July 11, 2001
PY-CEI/NRR-2581L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the June 2001 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Report. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Gregory A. Dunn
Manager - Regulatory Affairs

Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

IE24

OPERATING DATA REPORT

UNIT: Perry
DATE: 7/5/01

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: June 2001
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1266*
7. Maximum Dependable Capacity (Net MWe): 1241**

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>704.7</u>	<u>3,021.5</u>	<u>92,630.1</u>
9. Hours Generator On-Line	<u>677.6</u>	<u>2,869.1</u>	<u>90,231.3</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>802,067.0</u>	<u>3,094,085.0</u>	<u>101,915,042.0</u>

- *The New Design Electrical Rating is based on the 105% uprate which was completed April of 2001.
- ** The new MDC was effective April 1, 2001.

UNIT SHUTDOWNS REPORT MONTH – JUNE 2001

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 7/5/01
 CONTACT: T. Phelps
 TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence
01-6	5/21/01	F	42.4*	A	4	The unit shutdown due to circulating water pump impeller damage. Plant shutdown to repair all three impellers and motors for the circulating water system pumps.

* These are the hours off line for the month of June. The total duration of the outage is 298.08 hours.

SUMMARY: The Perry plant began the month shutdown. The unit was synchronized to the grid at 1824 on the 2nd of June. 100% power was achieved at 0658 on 6/14, when the third circulating water Pump became available for operation. The unit ended the month at full power.

- | | | |
|--|---|---|
| 1. TYPE:
F: Forced
S: Scheduled | 2. REASON:
A - Equipment Failure (explain)
B - Maintenance or Test
C - Refueling
D - Regulatory
E - Operating Training &
License Examination
F - Administrative
G - Operational Error (explain)
H - Other (explain) | 3. METHOD:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other |
|--|---|---|