Question No	1
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.1.01 Description Knowledge of conduct of operations requirements.
Quest	What are the minimum requirements for personnel within the "at the controls" area whenever fuel is in the reactor? A. One licensed individual (RO or SRO) B. One SRO C. One RO and one SRO
	D. Two licensed individuals (RO or SRO)
Answe	A CFR Sect 41.10 / 45.13
Higher Lev	□ RO 🗹 3.7 SRO 🗹 3.8
LP Number	LP Objective
0762-08	10.01
Operation	s and STA staffing requirements (SRO only)
Question So	New
Referen	SO-O-1, section 5.10.2.D.2
Attachme	none
Commen	

Question N	2
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.1.20 Description Ability to execute procedure steps.
Quest	<ul><li>Who must give permission for a temporary level of use downgrade for a procedure that is repeatedly performed by the same person on the same day?</li><li>A. The Operations Manager or an Operations Supervisor.</li><li>B. The Shift Manager.</li></ul>
	C. The Control Room Supervisor.
	D. The Shift Manager or the Control Room Supervisor.
Answe	D CFR Sect 41.10/43.5/45.12
Higher Lev	□ RO 🖌 4.3 SRO 🖌 4.2
LP Number	LP Objective
0762-01	02.00
STATE so Guide 1.3	me of the activities, covered by Standing Orders, which require written procedures per Regulatory 3.
Question So	New
Referen	SO-O-1 page 66
Attachme	None
Commen	

Question N	3	
System/Mc	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.1.25 Description Ability to obtain and interpret station reference materials such as graphs, monographs, and tables which contain performance data.	
Quest	<ul> <li>The reactor has tripped one hour ago due to a combination steam line break and tube rupture event. The operators completed EOP-00 and are now in EOP-20. The TSC and EOF have been manned. DG1 is carrying 2430KW and 395 amps and is the only available AC power source. The outside temperature is 100°F. The diesels are being cooled by a Glycol-water mixture. FW-10 is running and capable of providing 260 gpm. The TSC has recommended that FW-6 (250 HP) be used instead of FW-10 to minimize offsite release.</li> <li>Do you concur with the TSC recommendation?</li> <li>A. No, because the current draw for FW-6 would overload DG-1 by exceeding the DG-1 loading curve.</li> <li>B. No, because the starting current will exceed the rating on the diesel generator</li> <li>C. No, because FW-6 does not have adequate capacity to remove decay heat</li> <li>D. Yes. FW-6 is the better choice for this situation</li> </ul>	
Answe	A CEP Sect 41 10 / 43 5 / 45 12	
Answe		
Higher Lev	✓ RO ✓ 2.8 SRO ✓ 3.1	
LP Number	LP Objective	
0713-05	01.06	
Given TDB Figure III.26.A, be able to predict if diesel loading limits will be exceeded when loads are restarted following a loss of off-site power		
Question Se	Modified LR-EOP-20-RO 008	
Referen	TDB Figure 3.26.A	
Attachme	TDB Figure 3.26.A	
Commen	Reworded for clarification 6/12/01	

Question N	4	
System/Mo	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.1.33 Description Ability to recognize indications for system operating parameters which are entry-level conditions for technical specifications.	
Quest	In which one of the following situations, could a technical specification required system still be considered operable?	
	A. A required pump has a failed seal.	
	B. A required pump is in a room that is hotter than its qualification temperature.	
	C. A required instrument channel was tested using a voltmeter that was out of calibration.	
	D. A required instrument channel's surveillance test was not conducted before the drop dead date	
Answe	C CFR Sect 43.2/43.3/45.3	
Higher Lev	✓ RO ✓ 3.4 SRO ✓ 4.0	
LP Number	LP Objective	
0762-08	05.00	
Given a copy of Technical Specifications, APPLY the requirements to a given condition covered by an LCO.		
Question So	New	
Referen	SO-O-1 section 5.2	
Attachme	None	
Commen	NRC Comment - Is drop dead date defined? "Drop dead date" is used in standing order but is not defined. OK as is.	

Question N	u 5	
System/Mc	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.2.01 Description Ability to perform pre-startup procedures for the facility, including operating those controls associated with plant equipment that could affect reactivity.	
Quest	Which one of the following plant operations may be performed by the RO without permission of the Shift Manager or the Control Room Supervisor?	
	A. Emergency boration	
	B. Inserting group "N" rods	
	C. Adding water to maintain 100% power	
	D. Rinsing in an ion exchanger	
Answe	A CFR Sect 45.1	
Higher Lev	□ RO 🗹 3.7 SRO □ 3.6	
LP Number	LP Objective	
0717-03	01.00	
Use the Emergency Boration AOP to mitigate the consequences of an uncontrollable or unexplained positive reactivity addition.		
Question Se	New	
Referen	SO-O-1 5.14.2.B	
Attachme	None	
Commen		

Question N	6
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.2.07 Description Knowledge of the process for conducting tests or experiments not described in the safety analysis report.
Quest	Which one of the following situations would require NRC permission before conducting a proposed test?
	A. Any test not described in the USAR.
	B. Any test that makes tech spec required equipment inoperable during the test
	C. Any test which may increase the probability of an event analyzed in the USAR.
	D. Any test conducted by non-licensed personnel
Answe	C CFR Sect 43.3 / 45.13
Higher Lev	□ RO □ 2.0 SRO ✔ 3.2
LP Number	LP Objective
0751-04	01.00
STATE the that can b	e purpose of Title 10, Part 2 of the Code of Federal Regulations and DISCUSS the various actions e taken by the Nuclear Regulatory Commission in regards to violations of this part.
Question So	New
Referen	10 CFR 50.59
Attachme	None
Commen	

Question No	
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.2.17 Description Knowledge of the process for managing maintenance activities during power operations.
Quest	<ul> <li>According to standing Order M-101, who has the responsibility for performing a risk assessment for emergent maintenance activities when the Work Week Manager is unavailable?</li> <li>A. The Maintenance Rule Coordinator</li> <li>B. The Shift Manager</li> <li>C. The System Reliability Group Supervisor</li> <li>D. The Shift Technical Advisor</li> </ul>
Answe	D CFR Sect 43.5 / 45.13
Higher Lev	□ RO □ 2.3 SRO ✔ 3.5
LP Number	LP Objective
0762-01	01.00
STATE the	e major sections of the Standing Orders.
Question So	New
Referen	SO M-101 page 11
Attachme	None
Commen	

Question No	8
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.2.22 Description Knowledge of limiting conditions for operations and safety limits.
Quest	Which one of the following is a "Safety Limit" as described in the Fort Calhoun Station Technical Specifications?
	A. T-cold must not exceed 542F
	B. Peak Linear Heat Generation rate must not exceed 15.5 kw/ft
	C. RCS Pressure must not exceed 2750 psia
	D. Containment pressure must not exceed 60 psig
Answe	C CFR Sect 43.2/45.2
Higher Lev	□ RO 🗹 3.4 SRO 🗹 4.1
LP Number	LP Objective
0762-08	03.00
STATE the	e two (2) safety limits and the basis for each.
Question So	New
Referen	FCS Technical Specifications
Attachme	None
Commen	

Question Nu 9	
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.2.23DescriptionAbility to track limiting conditions for operations.
Quest	Which one of the following situations involving equipment required by technical specifications does NOT require that the equipment be logged as inoperable?
	A. The control room switch for a pump is placed in the Pull-To-Lock position but its breaker remains operable.
	B. An RPS channel is placed in bypass for less than 1 hour and restored to service during the same shift
	C. A fan is made inoperable as part of a planned surveillance test
	D. Instrument air is isolated to a fail closed air operated containment isolation valve during a calibration
Answe	D CFR Sect 43.2/45.13
Higher Lev	✓ RO 2.6 SRO ✓ 3.8
LP Number	LP Objective
0762-08	05.00
Given a co	opy of Technical Specifications, APPLY the requirements to a given condition covered by an LCO.
Question Se	New
Referen	SO-G-100 page 3
Attachme	None
Commen	

Question N	u 10		
System/Mo	d 000000 Stem		
Generic K	nowledges and Abilities		
KANo	2.2.24 Description Ability to analyze the affect of maintenance activities on LCO status.		
Quest	What is the minimum (underlined) level of testing required following electrical breaker preventive maintenance?		
	A. The breaker must be visually inspected.		
	B. The breaker must be operated in the electrical shop.		
	C. The breaker must be operated in the test position.		
	D. The breaker must be operated to power its load.		
DELETI	DELETED POST-EXAM CFR Sect 43.2 / 45.13		
Higher Lev	□ RO □ 2.6 SRO ✔ 3.8		
LP Number	LP Objective		
0762-08	05.00		
Given a co	opy of Technical Specifications, APPLY the requirements to a given condition covered by an LCO.		
Question So	New		
Referen	SO-O-1 page 13		
Attachme	None		
Commen	Underlined word minimum as a result of validation comment 6/17/01 QUESTION DELETED		

Question Nu 11		
System/Mo	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.3.02 Description Knowledge of facility ALARA program.	
Quest	<ul> <li>The RWP Surveillance and ALARA coordinator has determined that an ALARA job briefing is required for performance of a job in the RCA. Which one of the following restrictions apply until all affected workers attend an ALARA job briefing?</li> <li>A. The affected workers will not be issued TLDs</li> <li>B. The affected workers will not be allowed to sign the RWP</li> <li>C. The affected workers will not be allowed enter the RCA</li> <li>D. Work on the job may not begin</li> </ul>	
l		
Answe	B CFR Sect 41.12/43.4/45.9/45.10	
Higher Lev	□ RO 🗹 2.5 SRO 🗹 2.9	
LP Number	LP Objective	
1924-03B	01.00	
Given a copy of the Radiation Protection procedures, DEFINE the following types of controlled, contaminated, and radiation areas at Fort Calhoun Station and EXPLAIN the controls, posting requirements, access requirements, and limits for each		
Question So	Modified 1995 exam question 66	
Referen	RP-301	
Attachme	None	
Commen	Procedure change required change in correct answer. NRC Comment: C,D Also appear to be correct. C incorrect - Affected workers may enter RCA under a different RWP D incorrect - Work on the job may begin, just not with these workers OK to use as is.	

Question N	12	
System/Mc	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.3.03 Description Knowledge of SRO responsibilities for auxiliary systems that are outside the control room (e.g., waste disposal and handling systems).	
Quest	<ul> <li>What is the Shift Managers responsibility for pre-planned work in the switchyard per NOD-QP-36, "Control of Switchyard Activities at Fort Calhoun Station"?</li> <li>A. Determine if proposed work can be accomplished without adversely affecting plant operation.</li> <li>B. Inform the Security Shift Supervisor to provide an escort for the EOD personnel while they are in the switchyard</li> <li>C. Have the EOD personnel contact the Plant Manager for permission to enter the switchyard</li> <li>D. Provide an Operator to assist in switchyard activities</li> </ul>	
l		
Answe	A CFR Sect 43.4 / 45.10	
Higher Lev	□ RO □ 1.8 SRO ✔ 2.9	
LP Number	LP Objective	
0713-01	01.06e	
Given a copy of the procedure NOD-QP-36, Control of SWYD Activities at FCS, the student will be able to perform the following: Describe how access to the switchyard is obtained for scheduled and non-scheduled activities.		
Question Se	Modified 1997 exam question 87	
Referen	NOD-QP-36	
Attachme	None	
Commen		

Question N	13	
System/Mo	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.3.11 Description Ability to control radiation releases.	
Quest	<ul> <li>During the later part of cycle 19, condenser evacuation was routed to the auxiliary building stack, Why was that done?</li> <li>A. To provide filtering of radioactive noble gasses in case of a primary to secondary leak.</li> <li>B. To prevent an unmonitored release if RM-057 went offscale.</li> </ul>	
	C. To allow for modification of the normal condenser evacuation ducting	
	D. To improve condenser vacuum due to air in-leakage	
Answe	B CFR Sect 45.9 / 45.10	
Higher Lev	□ RO 🗹 2.7 SRO 🗌 3.2	
LP Number	LP Objective	
1950-04	03.01d	
Condenser Air Ejector Monitor (RM-057)		
Question So	New	
Referen	CE STM page 13	
Attachme	None	
Commen		

Question Nu 14		
System/Mo	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.4.08 Description Knowledge of how the event-based emergency/abnormal operating procedures are used in conjunction with the symptom-based EOPs.	
Quest	<ul> <li>You have entered EOP-06 due to a plant event. In EOP-06, there is a note that tells you to go to EOP-20, HR-4 if plant parameters reach certain values. It is your judgment that these plant parameters will reach these values. How do you handle this situation procedurally?</li> <li>A. Go to the section of EOP-20, HR-4 immediately to ensure the transition is not missed.</li> <li>B. Transition to EOP-20, Initiate HR-4 actions when plant parameters reach the specified values. Stay in EOP-20 after performing the steps of section HR-4</li> <li>C. Transition to EOP-20, Initiate HR-4 actions when plant parameters reach the specified values. Return to EOP-06 after the actions in EOP-20, HR-4 are complete.</li> <li>D. Ensure that all safety functions are satisfied in EOP-06 prior to transitioning to EOP-20, HR-4.</li> </ul>	
Answe	B         CFR Sect         41.10 / 43.5 / 45.13	
Higher Lev	✓ RO ✓ 3.0 SRO ✓ 3.7	
LP Number	LP Objective	
0718-10	01.00	
DEMONS Procedure	TRATE general knowledge about the structure, terminology and usage of the Emergency Operation es (EOP's).	
Question So	New	
Referen	OPD-04-09 EOP/AOP Users Guide page 18	
Attachme	None	
Commen	OPPD Comment - Wording for choices B and C should be changed to allow transition prior to plant parameters being reached. Choices B and C reworded (5-25-01)	

Question N	15
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.4.09 Description Knowledge of low power / shutdown implications in accident (e.g. LOCA or loss of RHR) mitigation strategies.
Quest	To avoid RCS pressurization on a loss of Shutdown Cooling, an opening at least as large asmust be available prior to removing the steam generators from service.         A. PORV nozzle         B. Both pressurizer safety valves         C. Pressurizer manway         D. Reactor vessel head
Answe	C CFR Sect 41.10 / 43.5 / 45.13
Higher Lev	□ RO 🗹 3.3 SRO ✔ 3.9
LP Number	LP Objective
0707-42	10.02
Decay hea	at removal
Question So	Bank I-7-07-42, 11.0 002
Referen	SO=O-21 page 5
Attachme	None
Commen	

Question N	u 16
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.4.10 Description Knowledge of annunciator response procedures.
г	
Quest	How are the Annunciator Response Procedures (ARPs) classified for level of use at FCS:
	A. Continuous use procedures
	B. Reference use procedures
	C. Information use procedures
	D. They are not classified for level of use
Answe	B CFR Sect 41.10 / 43.5 / 45.13
Higher Lev	□ RO 🗹 3.0 SRO □ 3.1
LP Number	LP Objective
0762-11	01.00
USE the A	RPs to diagnose plant problems.
Question So	New
Referen	SO G-7 5.5.9
Attachme	None
Commen	NRC Comment - Not discriminating enough for SRO. OK for RO Changed to RO Only question. New SRO only question added using same K/A (question 127)

Question N	u 17
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.4.16 Description Knowledge of EOP implementation hierarchy and coordination with other support procedures.
Quest	Which one of the following statements is true concerning the use of FCS Severe Accident Management Guideline's (SAMGs)?
	A. TSC personnel use the SAMGs to support the Control Room Operators in mitigating core damage events.
	B. EOF personnel use the SAMGs to support the Control Room Operators in mitigating core damage events.
	C. The Control Room Operators use the SAMGs along with the EOPs to mitigate core damage events
	D. The Control Room Operators transition from the EOPs to the SAMGs to mitigate core damage events
Answe	A CFR Sect 41.10 / 43.5 / 45.13
Higher Lev	□ RO 🗹 3.0 SRO 🗹 4.0
LP Number 1074-01	LP Objective 01.14
Question So	New
Referen	FCSSG-16 page 2
Attachme	None
Commen	

Question Nu 18	
System/Mo	d 000000 Stem
Generic K	nowledges and Abilities
KANo	2.4.25 Description Knowledge of fire protection procedures.
Quest	What is the Shift Managers specific responsibility in regards to Standing Order G-58, Control of Fire Protection System Impairments?
	A. He is responsible for overall operability of the fire protection systems and equipment.
	B. He is responsible for ensuring compensatory measures are established in accordance with Standing Order G-103.
	C. He is responsible for tracking and documenting fire protection LCOs.
	D. He is responsible for providing personnel to perform firewatch duties.
Answe	B CFR Sect 41.10 / 45.13
Higher Lev	□ RO 🗹 2.9 SRO ✔ 3.4
LP Number	LP Objective
0762-01	01.00
STATE th	e major sections of the Standing Orders.
Question So	Bank SRO-7-62-01,G-58-1.1 001
Referen	SO G-58 page 3
Attachme	None
Commen	OPPD Comment - Reword choice A to make it clearly incorrect. Choice A reworded (5-25-01) distractor describes responsibility of Fire Protection System Engineer

Question N	19	
System/Mc	d 000000 Stem	
Generic K	nowledges and Abilities	
KANo	2.4.37 Description Knowledge of the lines of authority during an emergency.	
Quest	<ul> <li>A General Emergency has been declared at Fort Calhoun Station. The TSC and EOF are both fully staffed and operational. The Shift Manager is in the Command and Control Position at this time. Which one of the following duties can the Shift Manager delegate to his CRS?</li> <li>A. Ensuring that the event is classified properly.</li> <li>B. Ensuring appropriate Protective Action Recommendations are provided to offsite officials</li> <li>C. Authorizing the issuance of Potassium lodide to OPPD emergency workers</li> <li>D. Authorizing deviations from Technical Specifications needed to mitigate the event.</li> </ul>	
Answe	D CFR Sect 45.13	
Higher Lev	□ RO □ 2.0 SRO ✔ 3.5	
LP Number		
Generic Objective - allows linking Task or KA to Lesson Plan		
Question Se	New	
Referen	EPIP-OSC-2 page 25	
Attachme	None	
Commen		

Question N	20		
System/Mo	d 000001 Stem Knowledge of the operational implications of the following concepts		
Continuou	Continuous Rod Withdrawal		
KANo	AK1.21 Description Integral rod worth		
Quest	The reactor is operating at 50% power at BOC when a rod withdrawal accident occurs. Rod banks move with designed overlap. The RO takes manual action to stop the rod withdrawal after the rods have moved 20 inches. Which one of the following rod position changes will produce the largest rate of power rise?		
	A. Group four from 30 inches to 50 inches withdrawn		
	B. Group four from 50 inches to 70 inches withdrawn		
	C. Group four from 70 inches to 90 inches withdrawn		
	D. Group four from 90 to 110 inches withdrawn.		
Answe	A CFR Sect 41.8 / 41.10 / 45.3		
Higher Lev	✓ RO ✓ 2.9 SRO ✓ 3.2		
LP Number	LP Objective		
0715-32	01.01		
EXPLAIN how the rate of reactivity addition affects the reactor power response.			
Question So	New		
Referen	TDB Figure II.B.2.a		
Attachme	TDB Figure II.B.2.a		
Commen			

Question Nu 21			
System/Mo	d 000003 Stem Knowledge of the operational implications of the following concepts		
Dropped (	Dropped Control Rod		
KANo	AK1.19 Description Differential rod worth		
Quest	<ul> <li>Fort Calhoun Station is operating at 100% power with rods all out and a burnup of 5000 MWD/MTU, when a group 4 CEA drops into the core. The secondary operator lowers turbine load and stabilizes the plant at 91% power with T-cold at its programmed value. What is the approximate average differential rod worth of the dropped CEA?</li> <li>A. 0.001% delta rho/inch</li> <li>B. 0.002% delta rho/inch</li> <li>C. 0.01% delta rho/inch</li> <li>D. 0.02% delta rho/inch</li> </ul>		
Answe	A CER Sect 41.8/41.10/45.3		
Higher Lev	✓ RO ✓ 2.8 SRO ✓ 2.9		
LP Number	LP Objective		
0715-32	02.03		
A CEA drop event			
Question So	New		
Referen	TDB Figure II.C.2		
Attachme	TDB Figure II.C.2		
Commen	[1.475% x 0.09] / 126 inches = .00105 % per inch		

Question Nu 22		
System/Mo	d 000003 Stem Knowledge of the interrelations between the Dropped Control Rod and the following:	
Dropped (	Control Rod	
KANo	AK2.03 Description Metroscope	
г		
Quest	One of the regulating CEAs dropped due to a clutch power failure. How will the SCEAPIS respond to this event?	
	A. The SCEAPIS will block withdrawal of all regulating rods if power is above 10-4% power.	
	B. The SCEAPIS will block withdrawal of all regulating rods if power is below 10-4% power.	
	C. The SCEAPIS will block withdrawal of all other rods in the dropped rod's group if power is above 10-4% power	
	D. The SCEAPIS will block withdrawal of all other rods in the dropped rod's group if power is below 10-4% power	
Answe	A CFR Sect 41.7 / 45.7	
Higher Lev	✓ RO ✓ 3.1* SRO ✓ 3.2*	
LP Number	LP Objective	
0712-26	01.08	
Identify and explain the interlocks that control operation of the CEDM.		
Question So	Modified 0712-26 1.8 001	
Referen	CRD STM page 16	
Attachme	None	
Commen		

Question N	23		
System/Mo	d 000007 Stem Ability to operate and monitor the following as they apply to a		
Reactor T	Reactor Trip		
KANo	EA1.05 Description Nuclear instrumentation		
Quest	<ul><li>A reactor trip has occurred, but 7 of the control rods failed to insert. Emergency Boration can not be established. Which one of the following will result in the EOP-20 Reactivity Control Safety Function being satisfied?</li><li>A. Startup rate is negative, RCS temperature is stable.</li></ul>		
	B. Startup rate is negative, Group "N" rods have been inserted.		
	C. Startup rate is zero, Wide Range NI channels read less than $1 \times 10(-5)$ % power		
	D. Startup rate is zero, Power Range NI channels read 0 % power		
Answe	C CFR Sect 41.7 / 45.5 / 45.6		
Higher Lev	✓ RO 4.0 SRO √ 4.1		
LP Number	LP Objective		
0715-28	01.16a		
Excore Ins	strumentation		
Question So	New		
Referen	EOP 20		
Attachme	None		
Commen	NRC Comment - Not SRO level question. Needs Link to 10CFR55.43. A may possibly be correct. Original Question replaced. (6/4/01) New question meets 10CFR55.43.5 Distractor D changed to ensure it is incorrect		

Question N	24
System/Mo	d 000007 Stem Ability to determine or interpret the following as they apply to a reactor trip:
Reactor T	ip
KANo	EA2.02 Description Proper actions to be taken if the automatic safety functions have not taken place
Quest	<ul><li>The reactor has been manually tripped following a sudden loss of instrument air pressure. According to AOP-17, which one of the following actions should be taken to prevent overfilling the steam generators?</li><li>A. Close FCV-1101 and FCV-1102 using the SPEC-200 controllers.</li></ul>
	<ul> <li>B. Close FCV-1101 and FCV-1102 using the Auxiliary controllers.</li> <li>C. Initiate SGIS</li> </ul>
	D. Trip all Main Feedwater Pumps
Answe	D CFR Sect 41.7 / 45.5 / 45.6
Higher Lev	✓ RO ✓ 4.3 SRO ✓ 4.6
LP Number	LP Objective
0711-11	02.05
EXPLAIN	the operation of the Feedwater Control System following a turbine trip.
Question So	New
Referen	AOP-17
Attachme	None
Commen	NRC Comment - State Manual or auto trip in stemis there an ABN for this? Changed to manually (5-25-01) Distractor C&D changed, New correct answer D to agree with AOP

Question N	u 25
System/Mo	d 000008 Stem
Pressurize	er Vapor Space Accident
KANo	2.4.31 Description Knowledge of annunciators alarms and indications, and use of the response instructions.
Quest	Which one of the instruments listed below allows identification of which PORV is leaking?
	A. Downstream temperature
	B. Downstream pressure
	C. Downstream flow (DP)
	D. Downstream noise
Answe	D CFR Sect 41.10 / 45.3
Higher Lev	RO 🗹 3.3 SRO 🗹 3.4
LP Number	LP Objective
0711-20	04.02h
Using the monitors f	applicable P&ID, IDENTIFY each of the following RCS Instrumentation Subsystems: Acoustic or the PORVs and safety valves
Question So	Bank 0711-20 5.2H 001 (reworded)
Referen	RCS & RR STM page 21
Attachme	None
Commen	OPPD Comment - replace "most reliable" Minor wording change to stem (5-25-01) Added (DP) in choice C to differentiate from "acoustic flow"

Question No	26		
System/Mo	d 000009 Stem Ability to determine or interpret the following as they apply to a		
Small Bre	small Break LOCA:		
KANo	EA2.19 Description Containment air cooler run indication		
Quest	Which one of the following signals directly (underlined) causes the face dampers to open and the bypass dampers to close on the Containment Cooling and Filtering units? A. VIAS B. CPHS C. SIAS D. CIAS		
Answe	A CFR Sect 43.5 / 45.13		
Higher Lev	□ RO 🖌 2.7 SRO 🖌 3.1		
LP Number	LP Objective		
0714-02	01.04		
Explain au	utomatic controls associated with the Containment Air Cooling and Filtering System.		
Question So	Bank 0714-02 1.4 001		
Referen	CBS&V STM page 22		
Attachme	None		
Commen	OPPD Comment - Add "Containment" to stem. Underline "directly" changes made (5-25- 01)		

Question Nu	27
System/Mo	d 000009 Stem Knowledge of the interrelations between the small break LOCA and the following:
Small Brea	ak LOCA
KANo	EK2.03 Description S/Gs
Quest	If the primary system pressure drops below the secondary pressure during a loss of coolant accident, it indicates that: A. The ECCS flow is inadequate to remove decay heat B. The Main steam isolation valves have been closed C. Reflux boiling is taking place
	D. The break flow is adequate to remove decay heat
Answe	D CFR Sect 41.7 / 45.7
Higher Lev	✓ RO ✓ 3.0 SRO ✓ 3.3*
LP Number	LP Objective
0715-23	01.02
EXPLAIN	how the decay heat removal capacity of the break affects plant response.
Question So	Bank 7-15-23, 1.2 002
Referen	SHB 0715-23 page 5
Attachme	None
Commen	

Question N	28
System/Mo	d 000011 Stem
Large Bre	ak LOCA
KANo	2.4.50 Description Ability to verify system alarm setpoints and operate controls identified in the alarm response manual.
Quest	Which one of the following conditions will cause a "HPSI Pump Off Normal" alarm?
	A. SI pump control switch in after close
	B. 69 permissive switch in after-close
	C. Corresponding Breaker in Operate
	D. SI pump control switch in pull-stop
Answe	D CFR Sect 45.3
Higher Lev	□ RO 🖌 3.3 SRO 🖌 3.3
LP Number	LP Objective
0712-14	02.06
Given a cu the require	urrent copy of the Annunciator Response Procedures, EXPLAIN the alarms associated with ESC and ed corrective actions.
Question So	Bank 0712-14 2.6 001
Referen	ECC STM page 12
Attachme	None
Commen	

Question No	29
System/Mo	d 000011 Stem Ability to determine or interpret the following as they apply to a
Large Bre	ak LOCA
KANo	EA2.05 Description Significance of charging pump operation
Quest	<ul> <li>What is the minimum number of charging pumps that would be required to provide adequate makeup flow to remove heat 24 hours after a large LOCA that occurred from full power?</li> <li>A. One charging pump</li> <li>B. Two charging pumps</li> <li>C. Three charging pumps</li> </ul>
	D. More than the flow from three charging pumps is required
Answe	D CFR Sect 43.5 / 45.13
Higher Lev	✓ RO ✓ 3.3 SRO ✓ 3.7*
LP Number	LP Objective
0707-42	03.07
RCS mak	eup flowrates for available success paths
Question So	New
Referen	AOP 19 page 3, CVCS STM page 22
Attachme	None
Commen	NRC Commnent - reference does not clearly support the answerdiscuss AOP-19 states that a minimum of 55 gpm is required to remove decay heat 24 hours after shutdown. The CVCS STM states that the capacity of the charging pumps is 40 gpm per pump, Therefore, at least two charging pumps are required.

Question N	30	
System/Mo	d 000015 Stem Ability to operate and / or monitor the following as they apply to the Reactor Coolant Pump Malfunctions (Loss of RC Flow):	
Reactor		
KANo	AA1.13 Description Reactor power level indicators	
Quest	What actions occur as a result of placing the zero power mode bypass switch on an RPS channel in "bypass" when the reactor power is less than 1 x 10-4% power? A. High power, TM/LP and low S/G pressure trips are bypassed.	
	B. High power and TM/LP trips are bypassed and delta-T power is blocked to the NI/delta-T power auctioneer.	
	C. Low flow, TM/LP and low S/G pressure trips are bypassed.	
	D. Low flow and TM/LP trips are bypassed and delta-T power is blocked to the NI/delta-T power auctioneer.	
Answe	D CFR Sect 41.7 / 45.5 / 45.6	
Higher Lev	□ RO 🗹 3.4* SRO ✔ 3.4*	
LP NumberLP Objective0712-2501.07b		
EXPLAIN	the reason(s) for each of the following trip unit bypasses: Low reactor coolant flow	
Question So	Bank 0712-25 1.7 B,D 001	
Referen	RP STM page 38	
Attachme	None	
Commen		

Question No	J 31
System/Mo	d 000017 Stem Ability to determine and interpret the following as they apply to the Reactor Coolant Pump Malfunctions (Loss of RC Flow):
KANo	AA2.10       Description         When to secure RCPs on loss of cooling or seal injection
Quest	The following plant conditions exist: The reactor is at 100% power RCS pressure is 2100 psia RCP seal leakoff flow is 1 gpm per pump VCT pressure is 50 psia. RC-3A pressure above lower seal is 110 psia RC-3A pressure above middle seal is 80 psia Which one of the following is correct about the condition of RC-3A's seals? A. The lower seal has failed B. The upper seal has failed C. The lower and middle seals have failed
	D. The upper and middle seals have failed
Answe	D CFR Sect 43.5 / 45.13
Higher Lev	✓ RO ✓ 3.7 SRO ✓ 3.7
LP Number 0711-20 EXPLAIN	LP Objective 01.07d the operation of the RCP seal package.
Question So	New
Referen	RC STM pages 18-20
Attachme	None
Commen	NRC Comment - add "full pressure" seals in stemwhere does 1.73 gpm come from? OPPD Comment - Question has backwards logic and should be modified. Question rewritten 6/12/01

Question N	32
System/Mo	d 000024 Stem
Emergeno	y Boration
KANo	2.4.49 Description Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.
Quest	As per AOP-03, Emergency Boration should continue until:
	A. Adequate shutdown margin has been established PER OP-ST-RX-0008 "Shutdown Margin Verification During Hot Shutdown, Cold Shutdown or Refueling."
	B. Both "CONC BORIC ACID TANK CH-11 A/R LEVEL LO-LO" alarms on (CB-1,2,3;A2) have been received.
	C. The VCT level reaches the high level alarm setpoint of 91.2%.
	D. Two or more Wide Range Nuclear Instrumentation channels indicate less than 10-4% power.
Answe	A CFR Sect 41.10/43.2/45.6
Higher Lev	□ RO 🗹 4.0 SRO 🗹 4.0
LP Number	LP Objective
0717-03	01.05
Given the	caution statements and/or notes listed in this AOP, explain the reason for each.
Question So	Bank 0717-03 1.5 001
Referen	AOP-03 page 6
Attachme	None
Commen	NRC Comment - change B to more technical? Gal boric acid injected from BATs to RCS. Change C to "low IvI" vice high. OPPD Comment - AOP-3 says RE-ST-RX-0008 Reference changed, OK as is otherwise

Question N	33
System/Mo	d 000026 Stem
Loss of Co	omponent Cooling Water
KANo	2.1.23 Description Ability to perform specific system and integrated plant procedures during all modes of plant operation.
Quest	In accordance with OI-CC-1, what action is taken to prevent check valve damage when rotating running CCW pumps?
	A. The oncoming pump's discharge valve is closed prior to starting the pump.
	B. The offgoing pump's discharge valve is closed prior to stopping the pump
	C. The oncoming pump's discharge valve is throttled to 2 turns open prior to starting the pump.
	D. The offgoing pump's discharge valve is throttled to 2 turns open prior to stopping the pump.
Answe	B CFR Sect 45.2/45.6
Higher Lev	□ RO 🗹 3.9 SRO 🗹 4.0
LP Number	LP Objective
0711-06	02.03
EXPLAIN	how check valve slam is minimized when stopping a CCW pump.
Question So	Modified 071106 2.3 002 Stem and distractors changed
Referen	OI-CC-1
Attachme	None
Commen	NRC Comment - Not responsive to K/A as writtenRevise Q to diagnose a leak out of CCW, then ask for system auto actions expected. OPPD Comment - Are distractors A&C plausible? Replaced question with one from bank. Distractors changed.

Question N	u <u>34</u>
System/Mc	d 000026 Stem Ability to determine and interpret the following as they apply to the Loss of Component Cooling Water:
Loss of C	omponent Cooling Water
KANo	AA2.06 Description The length of time after the loss of CCW flow to a component before that component may be damaged
Quest	Thirty minutes into a small break LOCA, CCW cooling is lost to the HPSI pumps. CCW remains available to all other required components. Which one of the following actions should be taken?
	A. The HPSI pumps should be allowed to continue operating
	B. The HPSI pumps should be shutdown until CCW can be restored
	C. The HPSI pumps should be shutdown until either CCW can be restored or Raw Water backup can be established
	D. The HPSI pumps should be shutdown until they can be inspected. They are no longer needed for this event.
Answe	A CFR Sect 43.5 / 45.13
Higher Lev	✓ RO ✓ 2.8* SRO ✓ 3.1*
LP Number 0717-11	LP Objective 01.02
Describe affected a	how the plant responds to a Loss of Component Cooling Water in terms of how specific equipment is nd how it affects overall plant operation and reliability.
Question Se	New
Referen	EA-FC-91-014 as referenced in LP 0711-22 page 31
Attachme	None
Commen	Engineering analysis shows HPSI pumps can run without cooling water. OPPD Comment - Remove "either CCW can be restored or" from C This is already a choice in B

Question N	35	
System/Mo	d 000027 Stem Knowledge of the operational implications of the following concepts	
Pressuriz	er Pressure Control System Mal	
KANo	AK1.02 Description Expansion of liquids as temperature increases	
Quest	A PORV opened as a result of a pressurizer control system malfunction. The breaker for the PORV block valve tripped while trying to isolate the PORV. As a result of the failures, a PPLS signal was received, RCS subcooling was lost and pressurizer level increased to 100%. The breaker was then reclosed for the PORV block valve.	
	EOP-03 contains a caution concerning isolation of a PORV if the pressurizer is water solid. What action should be taken prior to isolating the PORV?	
	A. Reactor vessel level must be verified to be above 43%.	
	B. Pressurizer level must be lowered below 60%.	
	C. 20°F subcooling must be restored.	
	D. A reactor cooldown must be commenced.	
Answe	D CFR Sect 41.8 / 41.10 / 45.3	
Higher Lev	✓ RO 2.8 SRO ✓ 3.1	
LP NumberLP Objective0715-2301.01		
EXPLAIN	the response of primary system parameters.	
Question So	New	
Referen	LP 0715-23 page 21	
Attachme		
Commen	NRC Comment - not SRO Onlysystem level question suggent tie in to procedure in stem to make 55.43 item	
	Question rewritten 6/12/01	

Question N	36
System/Mo	d 000029 Stem
Anticipate	d Transient Without Scram (AT
KANo	2.4.31 Description Knowledge of annunciators alarms and indications, and use of the response instructions.
Quest	<ul> <li>To allow steam generators to be drained during an outage, OI-RC-4 installs jumpers across the interposing relay contacts to keep the M coils energized. What affect do these jumpers have on RPS operation.</li> <li>A. All automatic trips except for diverse scram will be bypassed. The reactor can still be tripped manually from the RPS cabinets.</li> <li>B. All automatic trips including diverse scram will be bypassed. The reactor can still be tripped manually from CB-4.</li> </ul>
	<ul><li>C. All automatic and manual trips will be bypassed, including diverse scram.</li><li>D. Only the low steam generator level trips will be bypassed. All other automatic, diverse and manual trips will be operational.</li></ul>
Answe	A CFR Sect 41.10 / 45.3
Higher Lev	□ RO 🗹 3.3 SRO ✔ 3.4
LP Number 0712-25 Given a si reactor trip	LP Objective 01.16a mplified diagram of the RPS trip paths, EXPLAIN how the "M" coil contacts are: Opened to initiate a
Question So	Bank 0712-25 1.13 001
Referen	RP STM pages 25-27
Attachme	None
Commen	NRC Comment - typo in choice D fixed (5-25-01)
Question N	37
-------------	--
System/Mo	d 000029 Stem Knowledge of the operational implications of the following concepts
Anticipate	d Transient Without Scram (AT
KANo	EK1.02 Description Definition of reactivity
Quest	The plant is operating at full power near the end of an operating cycle when a loss of feedwater ATWS event occurs. Which one of the following reactivity mechanisms adds positive reactivity during this event?
	A. Fuel temperature coefficient
	B. Moderator temperature coefficient
	C. Void coefficient
	D. Boron concentration change
Answe	A CFR Sect 41.8 / 41.10 / 45.3
Higher Lev	✓ RO ✓ 2.6 SRO ✓ 2.8
LP Number	LP Objective
0715-17	01.06
EXPLAIN	the primary and the secondary plant response to a loss of feedwater ATWS.
Question So	New
Referen	LP 0715-17 page 10
Attachme	None
Commen	NRC Comment - verify the answer is independent of time of life OPPD Comment - Do we need to give a power level so they know MTC is negative EOC and power condition added to stem (5-25-01)

Question N	38		
System/Mo	d 000032 Stem Ability to determine and interpret the following as they apply to the		
Loss of So	Loss of Source Range Nuclear Instrumentation:		
KANo	AA2.08 Description Testing required if power lost, then restored		
F			
Quest	With the plant at 100% power, an I&C technician discovers that the results of his recently completed surveillance test administratively renders A, B and C wide range channels inoperable. Select the one statement that describes the best course of action.		
	A. Trip the reactor, GO TO EOP-00, Standard post Trip Actions		
	B. Place the Reactor in a hot shutdown condition within 12 hours		
	C. Place the #2 trip unit on one channel in bypass and one channel in trip within one hour		
	D. Log the surveillance test result in the control room log and continue steady state operation		
Answe	D CFR Sect 43.5 / 45.13		
Higher Lev	✓ RO 2.2 SRO ✓ 3.1		
LP Number	LP Objective		
0717-15	01.04		
Describe the operator actions to a loss of flux indications.			
Question So	Bank 0717-15 1.4 001		
Referen	FCS Technical Specification 2.15		
Attachme	None		
Commen	Channel D provides a signal to AI-212 NRC Comment - answer appears incomplete		

Question N	39		
System/Mo	d 000033 Stem Ability to determine and interpret the following as they apply to the		
Loss of In	Loss of Intermediate Range Nuclear Instrumentation:		
KANo	AA2.01 Description Equivalency between source-range, intermediate-range, and power-range channel readings		
Quest	The NI source range indicators provides indication at flux levels approximately 2 decades below that of the wide range indicators, even though they share detectors. In addition to an extra detector per channel, what design feature provides this additional range? A. The "Source Range" meter uses a "Campbelling" (MSV) Circuit		
	B. The "Source Range" meter uses a more sensitive discriminator setting.		
	C. The "Source Range" uses a higher detector voltage.		
	D. The "Source Range" uses an extra detector per channel with no other differences.		
Answe	B CFR Sect 43.5 / 45.13		
Higher Lev	✓ RO ✓ 3.0 SRO ✓ 3.5		
LP Number	LP Objective		
0712-18	01.00		
Explain the basic principles of design and operation used in WR Nuclear Instrumentation System detectors at FCS.			
Question So	New		
Referen	NI STM pages 7-8		
Attachme	None		
Commen	OPPD Comment - move "extra detector per channel" to stem Change made (5-25-01)		

Question No	40		
System/Mo	d 000036 Stem Knowledge of the reasons for the following responses as they apply to the Fuel Handling Incidents:		
Fuel Hand	Fuel Handling Incidents		
KANo	AK3.01 Description Different inputs that will cause a reactor building evacuation		
Quest	<ul> <li>According to AOP-08, which one of the following would be an indication of a fuel handling accident in containment requiring evacuation of non-essential personnel?</li> <li>A. High Containment Temperature</li> <li>B. Auto start of containment cooling and filtering units, VA-3A and VA-3B</li> <li>C. VA-66 transferring to "filter" mode</li> <li>D. A Ventilation Isolation Actuation Signal (VIAS)</li> </ul>		
Anowo	D CED Sect 41.5 / 41.10 / 45.6 / 45.12		
AIISWe	D CFR Sect 41.37 41.107 43.07 43.13		
Higher Lev	□ RO 🖌 3.1 SRO □ 3.7		
LP Number	LP Objective		
0717-08	01.04		
Describe t	he entry conditions for this AOP.		
Question So	New		
Referen	AOP-08 page 4		
Attachme	None		
Commen			

Question N	u 41		
System/Mc	d 000038 Stem Ability to operate and monitor the following as they apply to a SGTR:		
Steam Ge	Steam Generator Tube Rupture		
KANo	EA1.14 Description AFW pump control and flow indicators		
Quest	A steam generator tube rupture has occurred in RC-2B. The Turbine Driven AFW Pump, FW-10, is being used to provide feedwater flow. What action is taken to prevent a radioactive release via the FW-10 steam exhaust?		
	P. VCV 1045P is alread to isolate steam from PC 2P		
	C. FW-1121A is opened to divert FW-10 exhaust to the stack.		
	D. FW-10 can not be used during a steam generator tube rupture		
Answe	B CFR Sect 41.7 / 45.5 / 45.6		
Higher Lev	□ RO 🗹 4.1 SRO 🗹 3.9		
LP Number	LP Objective		
0715-33	01.03		
EXPLAIN rupture ev	the pathways for the transport of radioactivity to the environment during a steam generator tube ent.		
Question Se	New		
Referen	EOP-04 page 19		
Attachme	None		
Commen	NRC Comment - not SRO ONLY need diagnosis and selection of procedures		

Question N	u 42		
System/Mc	d 000038 Stem Ability to determine or interpret the following as they apply to a		
Steam Ge	Steam Generator Tube Rupture		
KANo	EA2.14 Description Magnitude of atmospheric radioactive release if cooldown must be completed using steam dumps or if atmospheric reliefs lift		
Quest	The plant has been shutdown due to significant failed fuel and primary to secondary leaks in both steam generators. Which one of the following steaming paths should be used for the cooldown to monitor offsite radiation releases.		
	A. MS-291 and MS-292		
	B. HCV-1040		
	C. PCV-910 and TCV-909's with Condenser Evacuation in normal alignment		
	D. PCV-910 and TCV-909's with Condenser Evacuation aligned to the AB stack		
Answe	D CFR Sect 43.5 / 45.13		
Higher Lev	✓ RO 3.3* SRO ✓ 4.6		
LP Number	LP Objective		
0715-33	01.03		
EXPLAIN the pathways for the transport of radioactivity to the environment during a steam generator tube rupture event.			
Question Se	New		
Referen	CE STM page 13		
Attachme	None		
Commen	NRC Comment - not SRO Only. OK to use after discussion		

Question N	u 43
System/Mo	d 000040 Stem Ability to operate and / or monitor the following as they apply to the Steam Line Rupture:
Steam Lir	ne Rupture
KANo	AA1.22 Description Load sequencer status lights
Quest	Following a steam line break in containment, which one of the following loads could start before its sequencer timer times out? A. AC-3A B, AC-10B C. FW-4C D. FW-6
Answe	D CFR Sect 41.7 / 45.5 / 45.6
Higher Lev	□ RO 🖌 3.0* SRO 🖌 3.0*
LP Number	LP Objective
0712-14	01.05
EXPLAIN	the functions performed by each Engineered Safeguards Control Signal.
Question Se	Bank 0712-14 1.5 009 stem reworded
Referen	ES&C STM page 41
Attachme	None
Commen	reworded stem to clarify what is meant by "retains autostart feature" following exam validation comment

Question N	44
System/Mo	d 000040 Stem Knowledge of the reasons for the following responses as they apply to the Steam Line Rupture:
Steam Lin	e Rupture
KANo	AK3.06 Description Containment temperature and pressure considerations
Quest	<ul> <li>Which one of the following will cause the peak containment pressure to be higher during a steam line break in containment?</li> <li>A. Providing AFW flow to the ruptured steam generator</li> <li>B. Providing AFW flow to the good steam generator</li> <li>C. Opening the MSIV bypass valve from the ruptured steam generator</li> </ul>
Answe	A CFR Sect 41.5 / 41.10 / 45.6 / 45.13
Higher Lev	✓ RO ✓ 3.4 SRO □ 3.9
LP Number	LP Objective
0715-20	01.03
EXPLAIN	the response of containment parameters.
Question So	New
Referen	LP 0715-20 page 14
Attachme	None
Commen	

Question Nu 45		
System/Mod 000054 Stem		
Loss of M	ain Feedwater	
KANo	2.2.25 Description Knowledge of bases in technical specifications for limiting conditions for operations and safety limits.	
Quest		
Quest	What is the basis for the technical specification requirement that the Emergency Feedwater Storage Tank have at least 55,000 gallons of water in it?	
	A. This is the amount of water required to remove decay heat for eight hours	
	B. This is the amount of water required to remove decay heat for 24 hours	
	C. This is the amount of water required to cooldown the RCS to Shutdown cooling entry conditions	
	D. The is the amount of water required to ensure adequate NPSH for operation of the Aux. Feedwater pumps.	
Answe	A CFR Sect 43.2	
Higher Lev	□ RO □ 2.5 SRO ✔ 3.7	
LP Number	LP Objective	
0711-01	01.05	
Given a copy of the Technical Specifications, INTERPRET the requirements for the AFW System.		
Question So	New	
Referen	Technical Specification 2,5	
Attachme	None	
Commen		

Question N	46
System/Mo	d 000054 Stem Ability to operate and / or monitor the following as they apply to the Loss of Main Feedwater (MFW):
Loss of M	ain Feedwater
KANo	AA1.02 Description Manual startup of electric and steam-driven AFW pumps
Quest	A DC powered oil pump is provided on FW-10, Turbine-Driven Auxiliary Feedwater Pump.
	Choose the statement below that correctly describes the functions] of this pump.
	A. The DC pump will provide bearing lubrication for the turbine in the event that the main oil pump trips
	B. The DC pump provides oil to operate the governor system until the main oil pump develops pressure
	C. The DC pump will provide bearing lubrication until the main oil pump develops pressure
	D. The DC pump will provide oil to BOTH the bearing and the governor system until the main oil pump develops pressure
Answe	B CFR Sect 41.7 / 45.5 / 45.6
Higher Lev	□ RO 🖌 4.4 SRO 🖌 4.4
LP Number	LP Objective
0711-01	01.08
EXPLAIN	the operation of the Control Oil System for the steam driven AFW pump (FW-10).
Question So	Bank 0711-01 002
Referen	AFW STM page 8
Attachme	None
Commen	

Question N	47
System/Mc	d 000055 Stem
Station BI	ackout
KANo	2.1.32 Description Ability to explain and apply all system limits and precautions.
Quest	<ul> <li>The following plant conditions exist:</li> <li>ALL offsite and onsite power was lost at 0600 hours</li> <li>At 0800 hours the new operating crew realized the failure of the previous crew to minimize DC</li> <li>bus loads as per steps 15.1b and 22 of EOP-07, "Station Blackout."</li> <li>ALL other steps had been performed</li> <li>Estimates are that onsite power will be restored between 1600 and 2000 hours.</li> <li>No estimate is available for return of offsite power.</li> <li>Which ONE of the following will be the consequence of a failure of either crew to perform step 15.1b (minimize DC bus loads) of EOP-07, "Station Blackout?"</li> <li>A. 120 VAC could be lost prior to 1400 hours.</li> <li>B. Loss of DC control power to all 4.16 KV switchgear could be lost prior to 0900 hours.</li> <li>C. 125 VDC could be lost prior to 0900 hours.</li> <li>D. No adverse affects should be seen prior to onsite power being available.</li> </ul>
Answe	A CFR Sect 41.10/43.2/45.12
Higher Lev	✓ RO 3.4 SRO ✓ 3.8
LP Number 0718-17	LP Objective 02.03
GIVEN a (	copy of Attachment 6, EXPLAIN the steps necessary to minimize DC loads.
Question Se	Bank 0718-17 2.3 002
Referen	ED STM page 16
Attachme	None
Commen	NRC Comment - ensure all answers could not be argued as correct

Question N	48
System/Mo	d 000056 Stem
Loss of Ot	f-Site Power
KANo	2.1.30 Description Ability to locate and operate components, including local controls.
Quest	Which of the following group of lockout relays must be reset prior to establishing 345 KV backfeed per Attachment 21, Energizing Buses 1A1 and 1A2 from Off-Site Power.
	A. 86-1/T1A-4, 86-2/T1A-4,86-1/T1A-3, 86-2/T1A-3
	B. 86-2/SVG1, 86-1/SVG1, 86/2-BF4, 86/2-BF5
	C. 86/161 and 86X/FT161
	D. 86/1A22, 86/1A42, 86/1A21 and 86/1A41
Answe	B CFR Sect 41.7/45.7
Higher Lev	✓ RO ✓ 3.9 SRO ✓ 3.4
LP Number	LP Objective
0718-12	02.04
GIVEN a c power.	copy of Attachment 21, EXPLAIN the steps necessary to energize a non-vital 4160 V bus from off-site
Question So	Bank 0718-12 2.4 001
Referen	EOP/AOP attachment 21
Attachme	None
Commen	NRC Comment - from memory, no handouts discuss OPPD Comment - too detailed? Would use procedure. Suggested resolution - Leave as is, question requires candidates to differentiate between 345 KV and 161 KV lockouts. Should be counted as Higher level question (change made -
	5-25-01)

Question Nu 49	
System/Mo	d 000056 Stem Ability to determine and interpret the following as they apply to the Loss of Offsite Power:
Loss of Of	f-Site Power
KANo	AA2.56 Description RCS T-ave
- Г	
Quest	All offsite power was lost one hour ago, causing a trip from extended full power operations, and has not been regained.
	Which ONE of the following is an indication of inadequate core cooling in this condition?
	A. Core delta-T is 65°F
	B. RCS subcooling is 28°F
	C. RCS hot and cold leg temperatures are decreasing
	D. CETs indicate 545°F and RCS hot leg temperature indicates 539°F
Answe	A CFR Sect 43.5 / 45.13
Higher Lev	✓ RO 3.6* SRO ✓ 3.7
LP Number	LP Objective
0718-12	03.01
STATE fro	om memory the four indications used to verify the development of Subcooled Natural Circulation.
Question So	Bank 0718-12 3.1 002
Referen	SHB 0715-16 pages13-14
Attachme	None
Commen	

Question Nu 50		
System/Mo	d 000057 Stem Ability to operate and / or monitor the following as they apply to the	
Loss of Vi	tal AC Electrical Instrument Bu	
KANo	AA1.04 Description RWST and VCT valves	
Quest	The plant was operating at 100% steady state power when the reactor tripped due to a loss of power to bus 1A3. All control room actions for Emergency Boration were taken. Assuming bus 1A3 remains deenergized, which one of the following local operations would result in emergency	
	boration flow?	
	A. Opening HCV-258	
	B. Opening HCV-265	
	C. Opening HCV-268	
	D. Opening LCV-218-3	
Answe	C CFR Sect 41.7/45.5/45.6	
Higher Lev	✓ RO ☑ 3.5 SRO ☑ 3.6	
LP Number		
0717-03	01.00	
Use the Emergency Boration AOP to mitigate the consequences of an uncontrollable or unexplained positive reactivity addition.		
Question So	New	
Referen	CVCS STM pages 36 and 37	
Attachme	None	
Commen	VCT pressure will prevent gravity feed with no power to close LCV-218-2	

Question No	51	
System/Mo	d 000057 Stem Ability to determine and interpret the following as they apply to the Loss of Vital AC Instrument Bus:	
KANo	AA2.16 Description Normal and abnormal PZR level for various modes of plant operation	
Quest	AOP-16 states that Pressurizer Level Controller "Y" becomes inoperable when Instrument bus "B" is lost.	
	Assume that the plant is operating at 100% power with LT-101X failed and channel "Y" selected as the control channel when a loss of Instrument Bus "B" occurred. How would you direct the Reactor Operator to maintain pressurezer level in that situation?	
	A. Place the selector switch to channel "X" and manually control indicated level at 60% on LI-106.	
	B. Place the selector switch to channel "X" and manually control indicated level at 38% on LI-106.	
	C. Place the selector switch to channel "X" and manually control indicated level at 48% on LI-106.	
	D. Place the selector switch to channel "X" and manually control indicated level at 31% on LI-106.	
Answe	B CFR Sect 43.5 / 45.13	
Higher Lev	✓ RO 3.0 SRO ✓ 3.1	
LP Number	LP Objective	
0717-16	01.02	
Describe how the plant responds to a loss of instrument bus power in terms of how specific equipment is affected and how it affects overall plant operation and reliability.		
Question So	New	
Referen	RCS&RR STM pages 10-11	
Attachme	TDB-III-2	
Commen	NRC Comment - Possibly not SRO ONLY. Is this in a procedure other than STMs? Possible reword question to use TDB figure for LI-106	
	Question reworded 6/12/01	

Question N	52
System/Mo	d O00058 Stem Ability to determine and interpret the following as they apply to the Loss of DC Power:
Loss of D	C Power
KANo	AA2.01 Description That a loss of dc power has occurred; verification that substitute power sources have come on line
г	
Quest	An EOP-20 event has occurred involving a loss of DC bus# 1. DC bus #2 is being powered by a battery charger. What other condition must be met before the MVA-DC safety function is satisfied?
	A. DC bus #1 must be reenergized
	B. DC loads must be minimized
	C. Instrument buses associated with DC bus #1 must be powered
	D. Switchgear DC control power must be supplied by DC bus #2
Answe	D CFR Sect 43.5 / 45.13
Higher Lev	✓ RO 3.7 SRO ✓ 4.1
LP Number	LP Objective
0718-18	01.06
EXPLAIN priority wit	how the Resource Assessment Trees are used in terms of Safety Function priority and success path hin each tree.
Question So	New
Referen	EOP-20 page 141
Attachme	None
Commen	Validator comment - should word switchgear be removed because more than just switchgear control power is transferred. Resolution - leave as written, EOP-20 just talks about switchgear DC control power in safety function criteria

Question No	53		
System/Mo	d 000058 Stem Knowledge of the reasons for the following responses as they apply to the Loss of DC Power:		
Loss of D	Loss of DC Power		
KANo	AK3.01 Description Use of dc control power by D/Gs		
Quest	The reactor tripped due to a loss of offsite power. A fault occurred on DC bus#1. What DC control power Emergency MTS buttons must be operated before FW-6 can be used to supply water to the steam generators? A. The 1A1-1A3 and the D1 Emergency Source pushbuttons		
	B. The 1A1-1A3 and the D2 Emergency Source pushbuttons		
	C. The 1A2-1A4 and the D1 Emergency Source pushbuttons		
	D. The 1A2-1A4 and the D2 Emergency Source pushbuttons		
Answe	A CFR Sect 41.5 / 41.10 / 45.6 / 45.1		
Higher Lev	✓ RO ✓ 3.4* SRO ✓ 3.7		
LP Number	LP Objective		
0718-18	01.05		
Given the each succ	Resource Assessment Trees, basically DESCRIBE the Method, Path and Acceptance Criteria for cess path.		
Question So	New		
Referen	ED-STM page 80		
Attachme	None		
Commen	FW-6 is powered from bus 1A3, which is powered by DG#1. Both normally receive control power from DC bus #1.		

Question No	54
System/Mo	d Stem Knowledge of the operational implications of the following concepts as they, apply to Accidental Liquid Radwaste Release:
Accidenta	I Liquid Radwaste Release
KANo	AK1.01 Description Types of radiation, their units of intensity and the location of the sources of radiation in a nuclear power plant
Quest	Which one of the following operations may cause significant changes in radiation levels outside the RCA when operating with damaged fuel at FCS?
	A. Recirculating a monitor tank
	B. Transferring water between Waste Holdup Tanks
	C. Placing a gas decay tank in service
	D. Transferring a spent resin filled HIC to a shipping cask
Answe	D CFR Sect 41.8 / 41.10 / 45.3
Higher Lev	□ RO 🗹 2.7 SRO 🗹 3.1
LP Number	LP Objective
0711-32	01.00
When give Liquid Sys	en specific plant conditions, apply operating principles to predict response of the Waste Disposal tem (WDLS).
Question So	New
Referen	Recent plant history
Attachme	None
Commen	During the last cycle, we ensured Admin building was empty during HIC transfer due to radiological concerns. Distractor D reworded due to validation comment that HIC must contain something

Question N	u 55
System/Mo	d 000061 Stem Knowledge of the interrelations between the Area Radiation
Area Radi	ation Monitoring (ARM) System
KANo	AK2.01 Description Detectors at each ARM system location
Quest	How will the area radiation monitors at Fort Calhoun Station respond to a small drop in detector voltage?
	A. The detector output will remain steady
	B. The detector output will be lower
	C. The detector output will be higher
	D. The detector output will spike than return to normal
Answe	A CFR Sect 41.7 / 45.7
Higher Lev	✓ RO ✓ 2.5* SRO ✓ 2.6*
LP Number	LP Objective
0712-03	03.01
LIST the t	wo basic types of monitors used at Fort Calhoun Station.
Question So	Bank 0712-03 3.1 001
Referen	RM STM page 36
Attachme	None
Commen	Ion chambers are used in area monitors.

Question Nu 56		
System/Mod 000067 Stem		
Plant Fire	on Site	
KANo	2.1.32 Description Ability to explain and apply all system limits and precautions.	
Quest	The plant is operating at 80% power when a fire breaks out in the turbine building in the vicinity of the main Generator. Attempts to extinguish the fire are unsuccessful. What actions should be taken by the CRS?	
	A. Initiate an AOP-05 shutdown, Direct isolation of hydrogen to the generator and supplying CO2 to the generator.	
	B. Initiate an AOP-05 shutdown, Direct isolation of hydrogen to the generator and venting the generator to the turbine building roof.	
	C. Enter AOP-06, Direct tripping of the Reactor, isolation of hydrogen to the generator and supplying CO2 to the generator.	
	D. Enter AOP-06, Direct tripping of the Reactor, isolation of hydrogen to the generator and venting the generator to the turbine building roof.	
DELETED F	CFR Sect 41.10 / 43.2 / 45.12	
Higher Lev	✓ RO 3.4 SRO ✓ 3.8	
LP NumberLP Objective0717-0601.03		
Describe the major recovery actions of this AOP.		
Question So	New	
Referen	AOP-06 pages 13-15	
Attachme	None	
Commen	NRC Comment - not SRO Only, from memory OK? Reworded to diagnose AOP-06 entry and direct RO and plant operator actions (5-25-01)	

Question N	57
System/Mo	d 000067 Stem Ability to determine and interpret the following as they apply to the Plant Fire on Site:
Plant Fire	on Site
KANo	AA2.16 Description Vital equipment and control systems to be maintained and operated during a fire
Quest	<ul> <li>A fire in the Upper Electrical Penetration Room poses a dual threat to safe plant shutdown due to the fact that Alternate Shutdown Panels are located in this area and</li> <li>A. A fire in this area could easily spread into the Diesel Generator Rooms.</li> </ul>
	B. A fire in this area could prevent a reactor trip as many of the RPS logic components are located in this room.
	C. A fire in this area could cause control problems, as most of the Instrument and Control Loops for Containment pass through this room.
	D. A fire in this area could easily spread into the Containment through Containment Penetrations in the room.
Answe	C CFR Sect 43.5 / 45.13
Higher Lev	✓ RO ✓ 3.3 SRO ✓ 4.0
LP Number 0717-06	LP Objective 01.02c
Describe	now the plant may respond to a fire in the following locations: Upper Electrical Penetration Room.
Question So	Bank 0717-06 1.2 001
Referen	AOP-06 pages 56-61
Attachme	None
Commen	NRC comment - B Correct? Choice B reworded (6/4/01)

Question N	u 58	
System/Mo	d 000068 Stem	
Control R	Control Room Evacuation	
KANo	2.4.31 Description Knowledge of annunciators alarms and indications, and use of the response instructions.	
Quest	<ul> <li>The following conditions exist: The control room has been evacuated. A plant cooldown must be conducted from the Alternate Shutdown Panel. Which one of the following describes the actions necessary to avoid PPLS during this cooldown?</li> <li>A. PPLS must be blocked as part of the process of evacuating the control room.</li> <li>B. PPLS will not auto initiate with control at the Alternate Shutdown Panel.</li> <li>C. All affected equipment must be placed in Pull-to-Lock locally at their breaker panels.</li> <li>D. The control power fuses of all affected equipment are removed from their breakers cabinets.</li> </ul>	
Answe	C CFR Sect 41.10 / 45.3	
Higher Lev	✓ RO ✓ 3.3 SRO ✓ 3.4	
LP Number 0717-06	LP Objective 01.02	
Describe how the plant may respond to a fire in the following locations.		
Question S	Bank 1995 NRC exam question 40	
Referen	AOP-06 pages 71 and 79, for example	
Attachme	None	
Commen	OPPD comment - is there a reference for this	

Question N	J 59
System/Mo	d 000068 Stem Knowledge of the reasons for the following responses as they apply to the Control Room Evacuation:
Control Ro	pom Evacuation
KANo	AK3.07 Description Maintenance of S/G level, using AFW flow control valves
Quest	Remote shutdown panel operation is taking place due to control room evacuation. Which one of the following actions will occur when the transfer switches on AI-179 are taken to local if S/G levels decrease to the AFAS low level setpoint? A. AFAS will open valves HCV-1107A, HCV-1107B, HCV-1108A, HCV-1108B and FW-10 will auto start
	B. AFAS will open HCV-1107A and HCV-1108A. HCV-1107B and HCV-1108B can be throttled. FW-10 will auto start
	C. AFAS signals to HCV-1107A, HCV1107B, HCV-1108A, HCV-1108B and FW-10 are blocked
	D. AFAS will open valves HCV-1107A, HCV-1107B, HCV-1108A and HCV-1108B. FW-10 will not start automatically
Answe	C CFR Sect 41.5 / 41.10 / 45.6 / 45.13
Higher Lev	✓ RO ✓ 4.0 SRO ✓ 4.3
LP Number	LP Objective
0712-01	01.05
EXPLAIN and 43/R0	the operation of the auxiliary relays (43X/RC2A and 43X/RC-2B) and transfer switches (43/RC-2A C-2B) on AI-179.
Question So	Bank 0712-01 1.5 002 slight rewording
Referen	ASP STM page 8
Attachme	None
Commen	Must realize AFAS is blocked in remote and the effect of that block

Question N	60
System/Mo	d 000069 Stem
Loss of Co	ontainment Integrity
KANo	2.4.50 Description Ability to verify system alarm setpoints and operate controls identified in the alarm response manual.
Quest	<ul> <li>When annunciator window CB-1/2/3, A4, E3, "Personnel Air Lock Door Open" is in alarm, it informs the control room operator that:</li> <li>A. The outer PAL door is open or ajar</li> <li>B. The Inner PAL door is open or ajar</li> <li>C. Both of the PAL doors are open or ajar</li> <li>D. Either of the PAL doors are open or ajar</li> </ul>
Answe	D CFR Sect 45.3
Higher Lev	□ RO 🗹 3.3 SRO 🗹 3.3
LP Number	LP Objective
0717-12	01.04
Describe t	he entry conditions for this AOP.
Question So	New
Referen	ARP CB-1/2/3, A4 window E3
Attachme	None
Commen	

Question Nu 61		
System/Mo	d 000074 Stem Ability to operate and monitor the following as they apply to a	
Inadequat	e Core Cooling	
KANo	EA1.21 Description Condensate storage tank level gauge	
Quest	An instrument air line blockage occurs that results in a loss of instrument air to Condensate Makeup valve, LCV-1190, and Condensate Dump valve LCV-1193. Assuming no operator actions were taken, how would Condensate Storage Tank level respond over the next six hours?	
	A. Condensate Storage Tank level would steadily lower.	
	B. Condensate Storage Tank level would steadily rise.	
	C. Condensate Storage Tank level would steadily lower for approximately 4 hours, then begin to lower at a faster rate.	
	D. Condensate Storage Tank level would steadily rise for approximately 4 hours, then begin to rise at a faster rate.	
Δηςιώρ	C CEP Sect 417/455/456	
7 mowe		
Higher Lev	✓ RO ✓ 3.7 SRO ✓ 3.7	
LP Number	LP Objective	
0711-04	01.05	
Explain the principles of normal operation of the Condensate System as they apply to flowpaths, major operating parameters and operation of all major control devices.		
Question So	New	
Referen	CFW STM pages 46 and 47	
Attachme	None	
Commen	Nitrogen backup will supply LCV-1190 for approximately 4 hours, it will then open fully Fixed typo in C/D, "then" not "than"	

Question Nu 62			
System/Mc	d 001000 Stem Ability to manually operate and/or monitor in the control room:		
Control R	Control Rod Drive System		
KANo	A4.10 Description Determination of an ECP		
Quest	In the FCS ECP procedure, a correction may be needed to compensate for changes in the B-10 fraction of the boric acid. Which one of the following situations would be most likely to require such a correction?		
	A. A startup following a shutdown due to multiple dropped rods		
	B. A startup following a shutdown to replace a RCP seal package		
	C. A startup following a shutdown to repair a condenser tube leak		
	D. A startup following a tech spec required shutdown due to D/G inoperability		
Answe	B CFR Sect		
Higher Lev	✓ RO ✓ 3.5 SRO ✓ 3.9		
LP NumberLP Objective0705-0904.02			
LIST the factors affecting critical position or boron concentration including:			
Question Se	o New		
Referen	FCS Rx Theory page 94		
Attachme	None		
Commen	GFE type question but does address sampled K/A NRC Comment GFE/Non descriminationg. Use graphs, ask graphs, ask how ECP is affected (quantitative) Replaced question with new question (5-28-01) Replaced with still another new question (6/12/01) ECP procedure states such a correction may be required following large volume changes such as going to mid-loop (which is required to change a BCP seal package.)		

Question Nu 63		
System/Mo	d 001000 Stem Knowledge of the following operational implications as they apply to the CRDS:	
Control Ro	od Drive System	
KANo	K5.38 Description Definition of xenon transient; causes; effects on reactivity	
~ · [		
Quest	The plant is shutting down for a refueling outage following an extended full power run. Reactor power is to be held at approximately 2% to perform turbine overspeed testing. Which one of the following approaches would allow the best reactivity control during this evolution?	
	A. Ensure that control rods remain as far out as possible during the shutdown. Use wide range nuclear instrumentation to monitor reactor power.	
	B. Ensure that control rods are adequately inserted into the core during the shutdown. Use wide range nuclear instrumentation to monitor reactor power.	
	C. Ensure that control rods remain as far out as possible during the shutdown. Use delta-T instrumentation to monitor reactor power.	
	D. Ensure that control rods are adequately inserted into the core during the shutdown. Use delta- T instrumentation to monitor reactor power.	
Δηςιώρ	B CEP Sect 415/457	
Answe		
Higher Lev	✓ RO ✓ 3.5 SRO ✓ 4.1	
LP Number	LP Objective	
0705-09	01.18	
	the Xenon worth after a trip curve including:	
Question So New		
Referen	OPD-4-19, "Reactivity Management" , page 7	
Attachme	None	
Commen	Rods must be inserted to be able to counter xenon buildup. Dilution will have minimal effect at EOC. Delta T power may not respond at low power.	

Question N	64		
System/Mo	d 002000 Stem Ability to predict and/or monitor changes in parameters (to prevent		
Reactor C	Reactor Coolant System including:		
KANo	A1.12 Description Radioactivity level when vending CRDS		
Quest	<ul> <li>An operator, who has previously received a TEDE of 720 mrem for the current year, was in containment during RCS venting. During this venting operation, the radioactive gas concentration in containment was estimated to be 15 times the Derived Airborne Concentration. The radiation in the area was 20 mr/hr.The operator was in containment for 2 hours with no respiratory equipment.</li> <li>What contribution to his TEDE did the operator receive during this evolution and how does his annual dose compare to FCS administrative limits?.</li> <li>A. The operator received an additional TEDE of 70 mrem for this evolution and is within the FCS annual administrative limits.</li> <li>B. The operator received an additional TEDE of 70 mrem for this evolution and has exceeded the FCS annual administrative limits.</li> <li>C. The operator received an additional TEDE of 115 mrem for this evolution and is within the FCS annual administrative limits.</li> <li>D. The operator received an additional TEDE of 115 mrem for this evolution and has exceeded the FCS annual administrative limits.</li> </ul>		
Answe	C CFR Sect 41.5/45.7		
Higher Lev	✓ RO ✓ 2.9 SRO ✓ 3.3		
LP Number       LP Objective         1924-03B       03.00         EXPLAIN the federal and OPPD limits and guidelines for exposures.			
Question So New			
Referen 10 CFR 20			
Attachme	None		
Commen	NRC Comment - GFE as written, ask action to take if limits exceeded. OPPD Comment - RP not covered in GFE. May reselect new K/A and use this as part of Operating exam		

Question changed 6/4/01 to incorporate FCS annual administrative limits

Question N	65	
System/Mo	d 002000 Stem Ability to monitor automatic operation of the RCS, including:	
Reactor C	oolant System	
KANo	A3.01 Description Reactor coolant leak detection system	
Quest	Which one of the following is an indication that Reactor Vessel head O-rings are leaking?	
	A. High pressure sensed between the O-rings	
	B. High temperature sensed between the O-rings	
	C. High level in a standpipe that collects O-ring leakage	
	D. High flow in a line that directs O-ring leakage to the RCDT	
Answe	A CFR Sect 41.7 / 45.5	
Higher Lev	□ RO 🗹 3.7 SRO □ 3.9	
LP Number	LP Objective	
0711-20	01.03	
EXPLAIN the basic functions of the RCS components.		
Question So	Bank 0711-20 1.3 001	
Referen	RCS STM	
Attachme	None	
Commen	Answer can be deduced from application of basic heat transfer. Heat losses become greater at higher system temperatures. With a constant heat input, heatup rate will decrease as temperature rises.NRC Comment - GFE Can reselect K/A Reselected K/A from same system, use reworded bank question (6/12/01)	

Question N	66		
System/Mo	d 003000 Stem		
Reactor C	Reactor Coolant Pump System		
KANo	2.4.31 Description Knowledge of annunciators alarms and indications, and use of the response instructions.		
Quest	<ul> <li>Annunciator CB-1/2/3, A6, "Reactor Coolant Pump RC-3A Vibration Hi" is in alarm. What action, if any, must be taken to reset the high vibration alarm once the vibration is below the alarm setpoint?</li> <li>A. The alarm will automatically reset.</li> <li>B. The alarm can be manually reset at CB-1/2/3.</li> <li>C. The alarm can be reset at the AI-270 display.</li> </ul>		
	D. The alarm can be reset at a ERF computer terminal.		
Answe	C CFR Sect 41.10 / 45.3		
Higher Lev	□ RO 🗹 3.3 SRO □ 3.4		
LP Number	LP Objective		
0711-20	04.02e		
Using the applicable P&ID, IDENTIFY each of the following RCS Instrumentation Subsystems: RC pump instrumentation			
Question So	New		
Referen	RC STM page 22		
Attachme	None		
Commen	NRC Comment - Move common elements to stem, revise answers OPPD Comment - Same comment as NRC Question reworded (5/28/01)		

Question N	67	
System/Mo	d 003000 Stem Ability to predict and/or monitor changes in parameters (to prevent	
Reactor C	oolant Pump System controls including:	
KANo	A1.06 Description PZR spray flow	
Quest	Pressurizer spray flow is provided from the discharge of Reactor Coolant Pumps	
	A. RC-3A & RC-3B	
	B. RC-3A & RC-3C	
	C. RC-3B & RC-3C	
	D. RC-3B & RC-3D	
Answe	B CFR Sect 41.5 / 45.5	
Higher Lev	□ RO 🗹 2.9 SRO 🗹 3.1	
LP Number	LP Objective	
0711-20 01.03		
EXPLAIN the basic functions of the RCS components.		
Question So	NEW	
Referen	RC STM page 43	
Attachme	None	
Commen		

Question No	68	
System/Mo	d 004000 Stem Knowledge of the physical connections and/or cause-effect relationships between the CVCS and the following systems:	
Chemical	and Volume Control System	
KANo	K1.17 Description PZR	
Quest	Plant controls are aligned as follows:	
	Channel X is selected as the controlling pressurizer level channel, the controller is in CASCADE CH-1A control switch is in the PULL-TO-LOCK position CH-1B is running and the control switch is in the AFTER START position CH-1C is stopped and the control switch is in the AFTER STOP position Charging pumps mode select switch is in the CH-1A, CH-1B position	
	What Charging Pumps will be running if LT-101X fails high?	
	A. No charging pumps will be running	
	B. Only CH-1B will be running	
	C. Only CH-1C will be running	
	D. CH-1B and CH-1C will be running	
Answe	B CFR Sect 41.2 to 41.9 / 45.7 to 45.8	
Higher Lev	✓ RO ✓ 3.4 SRO ✓ 3.4	
LP Number LP Objective 0711-02 01.03		
EXPLAIN the automatic and manual controls associated with the charging pumps and boric acid pumps.		
Question So Modified 0711-02 1.4 002		
Referen	CVCS STM pgs 24-25	
Attachme	None	
Commen	NRC Comment - C not credible, replace with CH 1C only Change made (5-31-01)	

Question Nu 69		
System/Mo	d 004000 Stem Knowledge of the effect of a loss or malfunction on the following CVCS components:	
Chemical	and Volume Control System	
KANo	K6.09 Description Purpose of VCT divert valve	
Quest	The plant is operating at 100% power. The following plant conditions exist:	
	One charging pump is operating. 40 gpm charging flow is indicated Indicated letdown flow is 36 gpm VCT level as shown on the lever recorder is lowering Pressurizer pressure and level and RCS temperatures are steady on all indicators Containment and Aux Building sump levels are steady	
	Which one of the following could cause these indications?	
	A. There is a leak in the RCS piping	
	B. There is a leak in the charging line	
	C. VCT level switch, LCS-218, has failed high	
	D. VCT pressure transmitter, PT-220, has failed high	
Answe	C CFR Sect 41.7 / 45.7	
Higher Lev	✓ RO ✓ 2.8 SRO ✓ 3.1	
LP Number	LP Objective	
0711-02	01.02	
EXPLAIN, the manual and automatic functions of control valves in the CVCS.		
Question So     New		
Referen	CVCS STM pages 20 and 21	
Attachme	None	
Commen		

Question N	70	
System/Mo	d 006000 Stem Ability to (a) predict the impacts of the following malfunctions or	
Emergeno	cy Core Cooling System procedures to correct, control, or mitigate the consequences of	
KANo	A2.10 Description Low boron concentration in SIS.	
Quest	<ul> <li>Which one of the following accidents could potentially have more severe consequences if the boron concentration in the SIRWT was below the Technical Specification Limit?</li> <li>A. A steam generator tube rupture</li> <li>B. A steam line break</li> <li>C. A loss of feedwater</li> <li>D. A loss of coolant accident</li> </ul>	
Answe	B CER Sect 41.5/45.5	
Higher Lev	✓ RO ✓ 3.4 SRO ✓ 3.9	
LP Number	LP Objective	
0715-20	03.05	
EXPLAIN how the steam line break is used in determining the basis for Technical Specification requirements.		
Question So	New	
Referen	SHB 0715-20 page 13	
Attachme	None	
Commen		

Question Nu 71			
System/Mo	d 006000 Stem Knowledge of the effect that a loss or malfunction of the ECCS will have on the following:		
Emergend	y Core Cooling System		
KANo	K3.01 Description RCS		
Quest	<ul> <li>A loss of coolant accident has occurred. All three HPSI pumps have failed to start. All other equipment operates as designed. Which one of the following LOCA events will result in significant fuel damage (beyond the 10 CFR 50.46, ECCS acceptance criteria) without operator action?</li> <li>A. A 1-inch diameter cold leg break</li> <li>B. A 8-inch diameter hot leg break</li> <li>C. A Double-ended cold leg break</li> <li>D. A Double-ended hot leg break</li> </ul>		
Answe	A CFR Sect 41.7/45.6		
Higher Lev	✓ RO ✓ 4.1 SRO ☐ 4.2		
LP Number LP Objective 0715-23 02.04			
EXPLAIN the operator actions required to mitigate a Loss of Coolant Accident.			
Question So	New		
Referen	SHB 0715-23 page 21		
Attachme	None		
Commen			
Question No	72		
-------------	---	--	--
System/Mo	d 008000 Stem		
Compone	Component Cooling Water System		
KANo	2.4.49 Description Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.		
Quest	Component cooling water to the Reactor Coolant Pumps will be isolated:		
	A. Following any CIAS signal		
	B. Following a CIAS with CCW pump discharge pressure less than 40 psig for 30 seconds.		
	C. Following a SIAS with CCW discharge pressure less than 60 psig for 15 seconds		
	D. Following any SIAS with RCP cooling flow less than 33 gpm for 15 seconds		
Answe	B CFR Sect 41.10 / 43.2 / 45.6		
Higher Lev	□ RO 🖌 4.0 SRO 🖌 4.0		
LP Number	LP Objective		
0711-06	01.05		
EXPLAIN	the response of the CCW System to signals from the Engineered Safeguards Control System.		
Question So	Modified 0711-06 1.5 005		
Referen	CCW STM page 29		
Attachme	None		
Commen	Position of these valves is checked as standard post trip action.		

Question N	73
System/Mo	d 010000 Stem Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the PZR PCS
Pressuriz	er Pressure Control System controls including:
KANo	A1.05 Description Pressure effect on level
Quest	<ul> <li>Which one of the following is an indication of void formation in the RCS during natural circulation cooling?</li> <li>A. Pressurizer level lowering rapidly when directing charging flow to pressurizer auxiliary spray.</li> <li>B. Pressurizer level rising rapidly when directing charging flow to pressurizer auxiliary spray.</li> <li>C. Pressurizer level lowering rapidly when directing charging flow to the RCS loops.</li> </ul>
	D. Pressurizer level rising rapidly when directing charging flow to the RCS loops.
Answe	B CFR Sect 41.5 / 45.5
Higher Lev	✓ RO ✓ 2.8 SRO ✓ 2.9
LP Number	LP Objective
0715-16	02.06
EXPLAIN to void for	how RCS voids can form during natural circulation and how the operators can recognize and respond mation.
Question So	Modified 0711-20 3.7D 002
Referen	LP 0711-20 page 17
Attachme	None
Commen	

Question N	74
System/Mo	d 010000 Stem Knowledge of bus power supplies to the following:
Pressuriz	er Pressure Control System
KANo	K2.04 Description Indicator for code safety position
Quest	How can you determine if you have lost power to the acoustic monitor for safety valve, RC-142? A. All of the lights on the RC-142 module behind CB-1/2/3 will be off
	B. The "RC-142 Hi Flow" alarm on CB-1/2/3, A4 will come in
	C. The "RC-142 Loss of Indication" alarm on CB-1/2/3, A4 will come in
	D. The ERF computer "Loss of RC-142 Instrument Power" alarm will come in
Answe	A CFR Sect 41.7
Higher Lev	□ RO 🗹 2.7* SRO 🗹 2.9*
LP Number	LP Objective
0711-20	04.02h
Using the monitors f	applicable P&ID, IDENTIFY each of the following RCS Instrumentation Subsystems: Acoustic or the PORVs and safety valves
Question So	New
Referen	RC STM page 45
Attachme	None
Commen	

Question No	75	
System/Mo	d 011000 Stem Knowledge of the effect of a loss or malfunction on the following will	
Pressurizer Level Control System		
KANo	K6.03 Description Relationship between PZR level and PZR heater control circuit	
Quest	<ul> <li>The plant is operating at steady state 100% power. Channels 101X and 103Y are selected as the controlling channels. How will the actual pressurizer parameters respond if LT-101Y fails low and no operator action is taken?</li> <li>A. Pressurizer level will remain constant and pressure will rise</li> <li>B. Pressurizer level will remain constant and pressure will lower</li> <li>C. Pressurizer level and pressure will rise</li> </ul>	
	D. Pressurizer level and pressure will lower	
Answe	B CFR Sect 41.7 / 45.7	
Higher Lev	✓ RO ✓ 2.9 SRO □ 3.3	
LP Number	LP Objective	
0711-20	04.04	
EXPLAIN the interlocks and control functions associated with RCS Instrumentation.		
Question So	New	
Referen	RCS&RR STM page 20	
Attachme	None	
Commen	NRC Comment - What does level do in A/B? Could give indication/ask cause. A/B changed 6/4/01	

Question N	Question Nu 76		
System/Mo	d 012000 Stem Ability to predict and/or monitor Changes in parameters (to prevent exceeding design limits) associated with operating the RPS controls		
Reactor P	Reactor Protection System including:		
KANo	A1.01 Description Trip setpoint adjustment		
Quest	The reactor is stable at 12% power. The turbine has just tripped due to an overspeed test, when a steam dump valve fails wide open causing a power increase. Which one of the following will occur?		
	A. Power will rise and stabilize below 15% power.		
	B. The reactor will trip when power exceeds 15%.		
	C. The reactor will trip when power exceeds 19.1%.		
	D. Power will rise and stablize above 19.1% power.		
Answe	B CFR Sect 41.5 / 45.5		
Higher Lev	✓ RO ✓ 2.9* SRO □ 3.4*		
LP Number	LP Objective		
0712-25	0712-25 01.09		
STATE the NSSS parameters and points that enable, disable and/or permit the following RPS trip functions:			
Question So	Modified 0712-25 1.0 001		
Referen	RP STM pages 20-21		
Attachme	None		
Commen	NRC Comment - Why give that the reactor trips? Give conditions, ask what occurs. OPPD Comment - Change stem to when will the reactor trip? Question reworded 6/4/01		

Question N	Question Nu 77		
System/Mo	d 012000 Stem Ability to monitor automatic operation of the RPS, including:		
Reactor P	Reactor Protection System		
KANo	A3.05 Description Single and multiple channel trip indicators		
Quest	The bistables for channel "A" trip units 1, 9 and 12 have been placed in the "tripped" condition. None of the trips are bypassed. Which one of the following instrument failures will result in a reactor trip?		
	A. "A" channel NIS power range input to the RCS fails high		
	B. "B" channel pressurizer pressure input to the RCS fails low		
	C. "C" channel cold leg temperature input to the RCS fails high		
	D. "D" channel RCS flow input to the RCS fails low		
Answe	B CFR Sect 41.7/45.5		
Higher Lev	✓ RO ✓ 3.6 SRO 3.7		
LP Number	LP Objective		
0712-19	0712-19 01.12		
Explain th de-energi	e difference in the resultant coincidence if one channel in a 2 of 4 logic configuration is bypassed or zed.		
Question So	Bank 1997 FCS NRC exam question 7		
Referen	RP STM pages 9-10		
Attachme	None		
Commen	OPPD Comment - no correct answer Choices B and C changed 6/14/01. B is now correct answer.		

Question N	78
System/Mo	d 013000 Stem
Engineere	d Safety Features Actuation Sy
KANo	2.1.02 Description Knowledge of operator responsibilities during all modes of plant operation.
Quest	According to OPD 4-11, "Policy for When and by What Authority it is Appropriate to Bypass Engineered Safeguards", what are the restrictions on bypassing Engineered Safeguards during EOP events?
	<ul> <li>A. Engineered Safeguards may not be bypassed unless specifically directed by procedure.</li> <li>B. Engineered Safeguards may not be bypassed unless the Operators have control of the</li> </ul>
	process to be bypassed.
	C. Engineered Safeguards may not be bypassed unless authorized by the Shift Technical Advisor
	D. Only one train of Engineered Safeguards may be bypassed at a time.
Answe	B CFR Sect 41.10 / 45.13
Higher Lev	□ RO 🗹 3.0 SRO ✔ 4.0
LP Number	LP Objective
Question So	New
Referen	OPD 4-11
Attachme	None
Commen	NRC Comment - Not responsive to the K/A, non-discriminating Change K/A to match question or replace Replaced with new question 6/12/01

Question N	79	
System/Mo	d 013000 Stem Knowledge of the operational implications of the following concepts	
Engineere	as they apply to the ESFAG.	
KANo	K5.02 Description Safety system logic and reliability	
Quest	<ul> <li>345KV backfeed has been terminated in preparation for plant startup. Under these conditions, what points in the electrical distribution system are being monitored for initiation of OPLS?</li> <li>A. The secondary of transformers T1A-1, T1A-2, T1A-3 and T1A-4</li> <li>B. Bus 1A3, Bus 1A4, and the secondary of transformers T1A-1 and T1A-2</li> <li>C. Bus 1A3, Bus 1A4, and the secondary of transformers T1A-3 and T1A-4</li> <li>D. Bus 1A3, Bus 1A4, and the secondary of transformers T1A-1, T1A-2, T1A-3 and T1A-4</li> </ul>	
Δηςιώρ	C CER Sect 41 5 / 45 7	
Higher Lev	✓ RO ☑ 2.9 SRO ☑ 3.3	
LP Number	LP Objective	
0712-14	01.04	
EXPLAIN how each prime and backup actuation signal is developed.		
Question So	Bank 0712-14	
Referen	ESC STM pages 37-39	
Attachme	None	
Commen	NRC Comment - From memory?	

Question N	80	
System/Mo	d 015000 Stem Ability to (a) predict the impacts of the following malfunctions or	
Nuclear Ir	operations on the NIS; and (b based on those predictions, use           Nuclear Instrumentation System         procedures to correct, control, or mitigate the consequences of	
KANo	A2.03 Description Xenon oscillations	
Quest	A xenon oscillation could best be identified and controlled by trending and is most likely to diverge at the of a cycle. A. ASI, beginning B. ASI, end C. NI-Delta T power mismatch, beginning D. NI-Delta T power mismatch, end	
Answe	B CFR Sect 41.5 / 43.5 / 45.3 / 45.5	
Higher Lev	□ RO 🗹 3.2 SRO ✔ 3.5*	
LP Number	LP Objective	
0705-09	02.01	
STATE th	e reasons for limits on axial power distribution.	
Question So	New	
Referen	FCS Reactor Theory page 101	
Attachme	None	
Commen		

Question Nu 81		
System/Mo	d 015000 Stem Knowledge of the effect that a loss or malfunction of the NIS will have on the following:	
Nuclear Ir	strumentation System	
KANo	K3.01 Description RPS	
. Г		
Quest	The plant is operating at 50% power with the trip units associated with the channel A Power Range NI Safety Drawer in bypass. Which one of the following describes the effect deenergizing another power range safety drawer?	
	A. The reactor will trip	
	B. The Reactor will trip only if the second drawer is channel C	
	C. No trip will occur and the trip logic becomes 1 of 2	
	D. No trip will occur and the trip logic becomes 2 of 2	
Answe	C CFR Sect 41.7 / 45.6	
Higher Lev	✓ RO ✓ 3.9 SRO ✓ 4.3	
LP Number	LP Objective	
0712-19	01.12	
Explain th de-energi	e difference in the resultant coincidence if one channel in a 2 of 4 logic configuration is bypassed or zed.	
Question So	Bank 0712-19 1.12 002	
Referen	RP STM page 37	
Attachme	None	
Commen	OPPD Comment - ensure wording indicates that only the NI drwers are deenergized. Stem wording changed 6/4/01	

Question N	82	
System/Mo	d 016000 Stem	
Non-Nucle	ear Instrumentation System	
KANo	2.2.22 Description Knowledge of limiting conditions for operations and safety limits.	
Quest	After a calibration check of some instrument channels, it was determined that the plant is operating with the following plant conditions:	
	T-cold = 552F Power = 105% PZR Pressure = 2010 psia	
	Which one of the following statements is true?	
	A. The plant may continue to operate. The channels need to be recalibrated within eight hours.	
	B. The plant must be shutdown within one hour and remain in hot shutdown until the channels are recalibrated.	
	C. The plant must be shutdown within eight hours and this event reported to the SARC chairperson within 24 hours.	
	D. The plant must be shutdown within one hour and this event reported to the SARC chairperson within 24 hours.	
Answe	D CFR Sect 43.2 / 45.2	
Higher Lev	✓ RO 3.4 SRO ✓ 4.1	
LP Number	LP Objective	
0762-08	10.02	
Immediate action for a Safety Limit violation		
Question So	0/62-08 3.0 001	
Referen	Tech Spec section 5.7.1	
Attachme	COLR Figure one	
Commen		

Question Nu 83		
System/Mo	d 016000 Stem Knowledge of the effect that a loss or malfunction of the NNIS will have on the following:	
Non-Nucle	ear Instrumentation System	
KANo	K3.10 Description CCS	
Quest	Which one of the following failures will result in automatic closure of containment cooler inlet and outlet valves to cooling coil VA-1A, HCV-400A/C, with a CIAS signal present?	
	A. CCW pump discharge pressure switches, PCS-412 and PCS-413, fail low.	
	B. CCW flow from coil VA-1A, FC-416A, fails low	
	C. CCW return temperature from coil VA-1A fails high	
	D. Containment cooling fan, VA-3A, trips.	
Answe	B CFR Sect 41.7 / 45.6	
Higher Lev	✓ RO 3.0* SRO ✓ 3.2*	
LP Number	LP Objective	
0711-06	01.05	
EXPLAIN	the response of the CCW System to signals from the Engineered Safeguards Control System.	
Question So	Modified 0762-08 3.0 001	
Referen	CCW STM page 34	
Attachme	None	
Commen		

Question Nu 84			
System/Mo	d 017000 Stem Ability to monitor automatic operation of the ITM system including:		
In-Core Te	In-Core Temperature Monitor System		
KANo	A3.02 Description Measurement of in-core thermocouple temperatures at panel outside control room		
Quest	Representative Core Exit Thermocouple temperature is and can be read when the ERF computer is not working.		
	A. The highest reading CET temperature for a designated group of CETs, on CB-1/2/3		
	B. The highest reading CET temperature for a designated group of CETs, on the QSPDS		
	C. The average CET temperature for a designated group of CETs excluding invalid CETs, on CB- 1/2/3		
	D. The average CET temperature for a designated group of CETs excluding invalid CETs, on the QSPDS		
Answe	D CFR Sect 41.7 / 45.5		
Higher Lev	□ RO ✔ 3.4* SRO ✔ 3.1*		
LP NumberLP Objective0753-0201.03			
STATE the function of each major component of the QSPDS System.			
Question So	New		
Referen	QSPDS vendor manual		
Attachme	None		
Commen			

Question No	85	
System/Mo	d 017000 Stem Knowledge of the operational implications of the following concepts as they apply to the ITM system:	
In-Core Te		
KANo	K5.03 Description Indication of superheating	
F		
Quest	Following a loss of coolant accident, the ECCS system has fully actuated. The RCS pressure is 50 psia, Core Exit Thermocouples are reading between 275F and 285F, hot leg temperatures are reading between 520F and 540F and RVLMS = 28% The hot leg RTDs indicate:	
	A. The hot leg RTD's are indicating subcooled temperatures because the core is covered	
	B. The hot leg RTD's are indicating saturation temperature because the core is covered.	
	C. The hot leg RTDs are indicating superheated temperatures because the core in uncovered.	
	D. The bet leg PTDs are indicating superbasted temperatures because the pipe wells are	
	uncovered.	
L		
Answe	D CFR Sect 41.5 / 45.7	
Higher Lev	✓ RO ✓ 3.7 SRO ✓ 4.1	
LP Number	LP Objective	
0715-28	01.16	
EXPLAIN how the following instruments respond and can be affected by a degraded core event:		
Question So	New	
Referen	SHB 0715-23 page 7	
Attachme	Steam Tables	
Commen		

Question N	. 86	
System/Mo	d 022000 Stem Ability to (a) predict the impacts of the following malfunctions or operations on the CCS: and (b) based on those predictions, use	
Containm	Containment Cooling System procedures to correct, control, or mitigate the consequences of	
KANo	A2.01 Description Fan motor over-current	
Quest	An overcurrent condition has occurred for the motor for fan VA-3A. How will the fan respond?	
	A. The fan will continue to run unless manually tripped by the operator.	
	B. The fan will trip unless a PPLS or CPHS actuation signal is present	
	C. The fan will trip unless a CSAS actuation signal is present	
	D. The fan will trip regardless of any ESF actuation signals.	
Answe	D CFR Sect 41.5 / 43.5 / 45.3 / 45.13	
Higher Lev	✓ RO ✓ 2.5 SRO □ 2.7	
LP Number 0714-02	LP Objective 01.04	
Explain a	utomatic controls associated with the Containment Air Cooling and Filtering System.	
Question Se	New	
Referen	CBS&V STM pages 23-24	
Attachme	None	
Commen		

Question N	87	
System/Mo	d 022000 Stem Knowledge of CCS design feature(s) and/or interlock(s) which	
Containm	ent Cooling System	
KANo	K4.03 Description Automatic containment isolation	
Quest	A loss of coolant accident has occurred. Containment pressure is 25 psia. All systems are operating as designed. Which one of the following containment cooling systems will have CCW isolated to it?	
	A. Containment cooling units.	
	B. Containment cooling and filtering units	
	C. Detector well cooling	
	D. CEDM cooling.	
Answe	C CFR Sect 41.7	
Higher Lev	✓ RO ✓ 3.6* SRO ☐ 4.0	
LP Number	LP Objective	
0714-05	01.07	
Explain the principles of emergency operation of the Detector Well Cooling System in terms of flow paths, major parameters (temperature, pressure, flow, etc.), alarms and control devices.		
Question So	New	
Referen	CCW STM page 35	
Attachme	None	
Commen		

Question N	. 88
System/Mo	d 026000 Stem Knowledge of CSS design feature(s) and/or interlock(s) which
Containm	ent Spray System
KANo	K4.09 Description Prevention of path for escape of radioactivity from containment to the outside (interlock on RWST isolation after swapover)
Quest	The RO reports that the following plant conditions exist following a loss of coolant accident:
	<ul> <li>RCS Pressure = 700 psia</li> <li>Containment Pressure = 8 psig</li> <li>RAS has occurred</li> <li>HPSI and Containment Spray pumps are operating</li> <li>LPSI pumps are not running</li> <li>HCV-385 and HCV-386 are open</li> <li>LCV-383-1 and LCV-383-2 are closed</li> <li>HCV-383-3 and HCV-383-4 are open</li> <li>Which of the following statements is true:</li> <li>A. All systems are operating as designed.</li> <li>B. Action must be taken to prevent damage to the HPSI and/or Containment Spray Pumps</li> <li>C. Action must be taken to provide more ECCS flow</li> <li>D. Action must be taken to isolate a radiation release path</li> </ul>
Answe	D CFR Sect 41.7
Higher Lev	✓ RO 3.7* SRO ✓ 4.1*
LP Number	LP Objective
0711-22	01.08c
Explain ov Actuation	verall system response to actuation of automatic engineered safeguards signals: Recirculation Signal (RAS).
Question So	New
Referen	ECC STM page 26
Attachme	None

Commen

Question N	. 89
System/Mo	d 034000 Stem Ability to manually operate and/or monitor in the control room:
Fuel Hand	Iling Equipment System
KANo	A4.02 Description Neutron levels
Quest	During refueling operations, a new fuel assembly was inserted into the core. The following counts were recorded prior to insertion of the assembly: (Channels A, B & C are connected to scaler-timers
	A = 262 B = 290 C = 308 D = 228
	After insertion of the assembly, the following counts were observed:
	A = 270 B = 0 C = 312 D = 232
	Can the next fuel assembly be inserted into the core?
	A. Yes, only two channels of counts are required to proceed
	B. Yes, but only with written permission from the Reactor Engineer
	C. No, the bundle should be withdrawn to observe the affect on countrate
	D. No, since the base counts were taken on three channels, a new base count should be taken on two channels
Answe	A CFR Sect 41.7 / 45.5 to 45.8
Higher Lev	✓ RO ✓ 3.5 SRO ✓ 3.9
LP Number	LP Objective
0711-13	03.00
List the re	sponsibilities of the Control Room during a refueling.
Question So	Bank RQL LR-OP-11-RO 001 counts changed
Referen	TS 2.8.1(2)
Attachme	None

Commen

Question N	u 90
System/Mo	d 034000 Stem Knowledge of the effect of a loss or malfunction on the following will
Fuel Hand	ling Equipment System
KANo	K6.02 Description Radiation monitoring systems
Quest	Core reload is in progress
	Which one of the following situations would require immediate suspension and not allow further fuel handling activities as per Technical Specifications until the situation is remedied.
	A. The running Low Pressure safety Injection pump is stopped for 22 minutes to allow inserting a fuel bundle near the loop 2 hot leg
	B. RM-052 and RM-062 become inoperable
	C. All of the Aux building supply fans become inoperable
	D. RM-091A and RM-091B become inoperable
Answe	B CFR Sect 41.7/45.7
Higher Lev	✓ RO 2.6 SRO ✓ 3.3
LP Number	LP Objective
0711-13	02.01
Discuss tl	ne prerequisites and precautions associated with fuel handling equipment and the refueling machine.
Question So	Modified 0711-13 2.1 002
Referen	TS 2.8.2(3), 2.8.3(5) and bases
Attachme	None
Commen	NRC Comment - B correct? Answer not supported by ref. OPPD comment - B is the correct answer. Answer changed to B (5-28-01)

Question Nu	91	
System/Mo	d 035000 Stem Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the S/GS controls including:	
KANo	A1.01 Description S/G wide and narrow range level during startup, shutdown, and normal operations	
Quest	Choose the statement below that best describes the response of the Feedwater Regulating System to a High Steam Generator Level Condition (85% Narrow Range) A. FIC 1101/1102 controller will remain in AUTO and the signal from the Level Control Block	
	<ul> <li>(FRV Demand) is interrupted by contact opening causing the FRV to close.</li> <li>B. FIC 1101/1102 controller is shifted to MANUAL and the signal from the Level Control Block (FRV Demand) is interrupted by contact opening causing the FRV to close.</li> <li>C. FIC 1101/1102 controller will remain in AUTO and the signal from the Level Control Block (FRV Demand) is grounded causing the FRV to close.</li> </ul>	
	D. FIC 1101/1102 controller is shifted to MANUAL and the signal from the Level Control Block (FRV Demand) is grounded causing the FRV to close.	
Answe	B CFR Sect 41.5 / 45.5	
Higher Lev	□ RO ✔ 3.6 SRO ✔ 3.8	
LP NumberLP Objective0711-1102.04		
EXPLAIN	"tracking" as it applies to the Feedwater Control System.	
Question So Bank 0711-11 2.4 002 corrected		
Referen	F&C STM page 38	
Attachme	None	
Commen	NRC Comment - A/C not credible. Edit to "remain in auto" (wasn't controller in auto already?) Not responsive to KA. Ask system not component level question. Distractors A/C changed 6/4/01	

Question Nu 92		
System/Mo	d 035000 Stem Knowledge of S/GS design feature(s) and/or interlock(s) which	
Steam Ge	nerator System	
KANo	K4.02 Description S/G level indication	
Quest	As Control Room Operator you are controlling S/G Level using LIC 903Y/906Y, in MANUAL Mode, via the Feedwater Bypass Valves HCV-1105/1106. The setpoint knob was originally set for 65% as a level setpoint. On monitoring S/G Level you notice a "large" positive deviation indicated on the deviation meter.	
	A. Turn the setpoint knob to a higher setpoint which will bring the level back to 65%	
	B. Turn the setpoint knob to a lower setpoint which will bring the level back to 65%	
	C. Move the MANUAL control in small increments to the right [open valve] and restore the deviation to zero in small steps	
	D. Move the MANUAL control in small increments to the left [close valve] and restore the deviation to zero in small steps	
DELETED P	OST-EXAM CFR Sect 41.7	
Higher Lev	□ RO 🗹 3.2 SRO □ 3.5	
LP Number	LP Objective	
0711-11	02.04	
EXPLAIN	"tracking" as it applies to the Feedwater Control System.	
Question So	Bank 0711-11 2.4 003	
Referen	&C STM pages 34-35	
Attachme	None	
Commen	NRC Comment - A,B not responsive to the question Add "positive deviation" to the stem. Change distractors C&D 6/4/01	

Question Nu	93		
System/Mo	d 039000 Stem Ability to manually operate and/or monitor in the control room:		
Main and	Main and Reheat Steam System		
KANo	A4.01 Description Main steam supply. valves		
Quest	What would be the result if the 74 degrees open limit switch failed during opening of a Main Steam Isolation Valve? A. The MSIV would reclose		
	B. An Asymmetric steam generator trip signal would be generated		
	C. A Turbine trip signal would be generated		
	D. The MSIV would take longer than usual to open		
Answe	D CFR Sect 41.7 / 45.5 to 45.8		
Higher Lev	✓ RO ✓ 2.9* SRO ✓ 2.8*		
LP Number	LP Objective		
0711-17	01.04		
EXPLAIN associated	the indications, automatic actions, operating logic, alarm setpoints, interlocks and permissives I with the Main Steam Instrumentation System.		
Question Sc	New		
Referen	MS&SG STM page 22		
Attachme	None		
Commen			

Question N	94		
System/Mo	d 039000 Stem Knowledge of MRSS design feature(s) and/or interlock(s) which		
Main and	Main and Reheat Steam System		
KANo	K4.06 Description Prevent reverse steam flow on steam line break		
Quest	Which one of the following steam line break locations will result in the greatest RCS cooldown (lowest RCS temperature) if both MSIVs fail in the open position?		
	A. On the "A" steam line, in containment, upstream of the flow restrictor.		
	B. On the "B" steam line, in containment, just inside of the containment wall.		
	C. On the "A" steam line, in room 81, just outside of the containment wall.		
	D. On the "B" steam line, downstream of room 81, just outside the control room door.		
Answe	D CFR Sect 41.7		
Higher Lev	✓ RO ✓ 3.3 SRO 3.6		
LP Number			
0715-20	02.03		
EXPLAIN Removal F	the automatic actions that would be taken by Fort Calhoun systems to mitigate an Excessive Heat		
Question So	New		
Referen	SHB 0715-20 page 11		
Attachme	None		
Commen	Check valves will only allow one S/G to blowdown for choices A, B and C. They will both blowdown for choice D. NRC Comment - modify stem - greatest initial cooldown rate OPPD Comment - A may also be correct if reworded as NRC suggests Added (lowest RCS temperature) to stem to differentiate from cooldown rate.		

Question N	u 95	
System/Mo	d 041000 Stem	
Steam Du	mp System and Turbine Bypas	
KANo	2.4.49 Description Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.	
Quest	<ul> <li>Which one of the following situations requires taking manual control of the condenser steam dump and bypass valves (TCV-909's and PCV-910) to maintain RCS T-cold at approximately 532 degrees F following a reactor trip?</li> <li>A. A loss of instrument air pressure.</li> </ul>	
	B. A loss of condenser vacuum	
	C. A loss of all Reactor Coolant Pumps	
	D.A loss of all Main Feedwater pumps	
Answe	C CFR Sect 41.10/43.2/45.6	
Higher Lev	✓ RO ✓ 4.0 SRO ✓ 4.0	
LP Number	LP Objective	
0715-16	02.03	
EXPLAIN the operator actions required to monitor and maintain subcooled natural circulation.		
Question So	New	
Referen	SHB 0715-16 page 11	
Attachme	None	
Commen	Steam dump and bypass valves will open due to the rise in RCS average temperature as natural circulation is developing.	

Question N	96
System/Mo	d 041000 Stem Knowledge of the operational implications of the following concepts
Steam Du	mp System and Turbine Bypas
KANo	K5.04 Description Basis for plant cooldown rates
г	
Quest	The Technical Specification Minimum Boltup temperature limitation of 82F is designed to prevent brittle fracture of:
	A. The Reactor Vessel beltline welds
	B. The Reactor Vessel flange
	C. The Reactor Vessel cold leg nozzles
	D. The Reactor Vessel hot leg nozzles
Answe	B CFR Sect 41.5 / 45.7
Higher Lev	□ RO □ 2.4 SRO ☑ 3.1
LP Number	LP Objective
0711-20	02.02
EXPLAIN	the basis for the RCS heatup and cooldown curves and STATE the limits.
Question So	New
Referen	Tech Spec basis 2.1.2
Attachme	None
Commen	Although not referenced to section 43, the basis for Tech Spec cooldown rates is SRO level.
	NRC Comment - better if mode of failure not asked. Replace C,D with other components.
	Question changed (5-28-01)

Question N	97
System/Mc	d 045000 Stem
Main Turb	ine Generator System
KANo	2.4.49 Description Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.
Quest	Which of the following actions should be taken first if both automatic and manual Main Turbine trip fails?
	A. Open the generator output breakers
	B Open the exciter field breaker
	C. Close the MSIVs
	D. Trip the EHC pumps.
Answe	D CFR Sect 41.10 / 43.2 / 45.6
Higher Lev	□ RO 🖌 4.0 SRO 🖌 4.0
LP Number	LP Objective
0718-10	01.11
GIVEN a s conditions included.	set of plant conditions and a copy of EOP-00, DETERMINE the appropriate response to the plant B. Both the corrective actions required and any other EOP's referred to by the procedure must be
Question Se	New
Referen	EOP-00 page 6
Attachme	None
Commen	Choice D is preferred to choice C because it allows use of condenser dump and bypass valves. OPPD Comment- Change to which action should be taken first to eliminate possible argument for C
	Question changed (5-28-01)

Question No	J 98
System/Mo	d 045000 Stem Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating the MT/G
KANo	A1.06 Description Expected response of secondary plant parameters following T/G trip
Quest	Which one of the following statements describes the response of the Feedwater Regulating System to a Turbine Trip?
	A. The FIC (SPEC 200) rampdown function generates an 8% output to the Feedwater Regulating Valve (FRV) and the FRV closes to 8% of full open which corresponds to 5% of full power flow.
	B. The FIC (SPEC 200) rampdown function generates an 5% output to the Feedwater Regulating Valve (FRV) and the FRV closes to 5% of full open which corresponds to 8% of full power flow.
	C. The FIC (SPEC 200) rampdown function interrupts the output of the Flow Control Block and the FRV closes to 8% of full open which corresponds to 5% of full power flow.
	D. The FIC (SPEC 200) rampdown function interrupts the output of the Flow Control Block and the FRV closes to 5% of full open which corresponds to 8% of full power flow.
Answe	A CFR Sect 41.5 / 45.5
Higher Lev	□ RO 🗹 3.3 SRO 🗌 3.7
LP Number	LP Objective
0711-11	02.05
EXPLAIN	the operation of the Feedwater Control System following a turbine trip.
Question So	Bank 0711-11 2.5 001 choices reordered
Referen	F&C STM pages 37 and 38
Attachme	None
Commen	

Question N	99
System/Mo	d 055000 Stem
Condense	er Air Removal System
KANo	2.1.30 Description Ability to locate and operate components, including local controls.
Quest	<ul><li>The standby vacuum pump started on lowering vacuum. What action, if any, is required to stop the standby vacuum pump once proper vacuum is restored?</li><li>A. The standby vacuum pump will shut off automatically once vacuum is restored.</li><li>B. The standby vacuum pump can be stopped using the local pushbutton. But it will not automatically restart unless it is shutdown from the control room.</li></ul>
	<ul><li>C. The standby pump can be stopped using the control room switch, but must be locally reset before autostart capability is restored.</li><li>D. The standby pump can be stopped using either the control room switch or the local pushbutton. It will autostart if needed.</li></ul>
Answe	D CFR Sect 41.7 / 45.7
Higher Lev	□ RO 🗹 3.9 SRO 🗹 3.4
LP Number       LP Objective         0711-05       01.02         EXPLAIN the operation of controllers located in the Control Room associated with the Condenser Air Removal System.	
Question So	Modified 0711-05 1.2 002
Referen	CE STM pages 4-5
Attachme	Non
Commen	

Question N	100
System/Mo	d 055000 Stem Knowledge of the physical connections and/or cause-effect
Condense	r Air Removal System
KANo	K1.06 Description PRM system
Quest	What radionuclide is responsible for the high sensitivity of RM-057 in detecting primary to secondary leakage? A. N-16 B. I-131 C. Xe-133 D. U-238
Answe	C CFR Sect 41.2 to 41.9 / 45.7 to 45.8
Higher Lev	□ RO 🖌 2.6 SRO 🗌 2.6
LP Number	LP Objective
0712-03	01.04
LIST the s	ystems and components that interface with the Radiation Monitoring System.
Question So	New
Referen	SHB -0715-33
Attachme	None
Commen	

Question Nu	101	
System/Mod	d 059000 Stem Ability to monitor automatic operation of the MFW, including:	
Main Feed	Main Feedwater System	
KANo	A3.05 Description Starts and stops on the main feed pumps	
Quest	<ul> <li>The plant is operating at 100% power. FW-4A and FW-4B are operating, when a LOCA occurs in containment. RCS pressure drops to 800 psia and containment pressure rises to 12 psia. During standard post-trip actions, the RO reports that all three Feedwater Pumps are tripped and that the 43-SIAS/FW4 switch was incorrectly placed in the FW-4C position. The RO requests permission to restart a main feedwater pump. What direction do you give him?</li> <li>A. Direct the RO to establish auxiliary feedwater flow because it is not possible to start a main Feedwater Pump in this condition</li> <li>B. Direct the RO to establish auxiliary feedwater flow because starting a main Feedwater pump will cause OPLS to actuate</li> <li>C. Direct the RO to ensure that the 43/FW switch is the "OFF" position and start FW-4C</li> <li>D. Direct the RO to place the 43-SIAS/FW4 switch in the 'FW-4B" position and restart FW-4B</li> </ul>	
Answo	Δ CEP Soct 41.7 / 45.5	
Allswe		
Higher Lev	✓ RO 2.4* SRO ✓ 2.7*	
LP Number     LP Objective       0711-11     02.03		
Question Sc	New	
Referen	Feedwater and Condensate STM page 32	
Attachme	None	
Commen	Combination of RCS and Containment pressures will produce a CSAS which sends a trip signal to all three Feed Pumps. OPPD Comment - Change B to "Direct RO to establish aux feed, attempting to start A main feedwater pump will cause OPLS to actuate. Choice B changed (5-28-01)	

Question N	102
System/Mo	d 059000 Stem Ability to monitor automatic operation of the MFW, including:
Main Feed	Iwater System
KANo	A3.06 Description Feedwater isolation
Quest	<ul> <li>A Steam Generator Isolation Signal (SGIS) has isolated Feed Water to both Steam Generators.</li> <li>All Main Feedwater pumps are tripped. FW-6 is running. Which one of the following actions result in water being provided to FW-2B's Feed Ring?</li> <li>A. Open HCV-1384, Override and Open HCV-1104 and FCV-1102</li> </ul>
	B. Open HCV-1384, Override and Open HCV-1385 and HCV-1106
	C Open HCV-1385, Override and Open HCV-1104 and FCV-1102
	D. Open HCV-1385, Override and Open HCV-1104 and HCV-1106
Answe	B CFR Sect 41.7 / 45.5
Higher Lev	✓ RO ✓ 3.2* SRO □ 3.3
LP Number	LP Objective
0711-11	02.03
EXPLAIN	the automatic features and interlocks associated with the feedwater components.
Question So	Modified 0711-11 2.3 008
Referen	AFW STM - AFW diagram
Attachme	None
Commen	

Question No	103
System/Mo	d 061000 Stem Ability to monitor automatic operation of the AFW, including:
Auxiliary /	Emergency Feedwater System
KANo	A3.02 Description RCS cooldown during AFW operations
Quest	AFAS was lined up for normal operation (emergency standby) and a cooldown transient resulted in the following plant conditions:
	S/G A level = 30% WR S/G A pressure = 710 psia
	S/G B level = 28% WR S/G B pressure = 480 psia
	AFW is being supplied to both Steam Generators.
	What action should the CRS direct the RO to take?
	A. Continue to feed both Steam Generators.
	B. Isolate AFW to both Steam Generators
	C. Isolate AFW to Steam Generator "A"
	D. Isolate AFW to Steam Generator "B"
Answe	D CFR Sect 41.7 / 45.5
Higher Lev	✓ RO 4.0 SRO √ 4.0
LP Number	LP Objective
0711-01	01.07
EXPLAIN	the automatic operations of AFW System components.
Question So	Bank 0711-01 1.7 001 cleaned up
Referen	ESC STM page 31
Attachme	None
Commen	NRC Comment- not SRO only. Add malfunction ask for procedural action. Question changed 6/4/01

Question Nu 104	
System/Mod         O61000         Stem         Knowledge of bus power supplies to the following:	
Auxiliary /	Emergency Feedwater System
KANo	K2.03 Description AFW diesel driven pump
Quest	A reactor startup is in progress. FW-54 is being used as a feedwater source. If a loss of offsite power occurs and DG-2 fails to start, how will power be supplied to MCC-4C6 to power FW-54 auxiliaries?
	B. Power will automatically be supplied from $EW_{-54}$ 's shaft driven generator
	C. Power will be supplied from D/G-1 via MCC-4C5 after transfer switch EE-55 is manually operated
	D. Power will be supplied from FW-54's shaft driven generator after transfer switch EE-55 is manually operated
Answe	B CFR Sect 41.7
Higher Lev	✓ RO ✓ 4.0* SRO ✓ 3.8*
LP Number 0711-01	LP Objective 01.10
DESCRIB FW-10, ar	E the operational conditions associated with the operation of each of the three AFW pumps: FW-6, ad FW-54.
Question So	New
Referen	ED STM page 89
Attachme	None
Commen	
Question No	105
-------------	---
System/Mo	d 061000 Stem Knowledge of the effect of a loss or malfunction of the following will
Auxiliary /	Emergency Feedwater System
KANo	K6.01 Description Controllers and positioners
Quest	<ul> <li>With an AFAS present, throttling the AFW Control Valve HCV-1107B using the hand controller on CB-10, requires the four-position switch on AI-66A to be selected to:</li> <li>A. CLOSE</li> <li>B. RESET</li> <li>C. AUTO</li> <li>D. OPEN</li> </ul>
Answe	A CFR Sect 41.7 / 45.7
Higher Lev	□ RO 🖌 2.5 SRO 🗆 2.8*
LP Number	LP Objective
0711-01	01.02
EXPLAIN	the operation of controls located in the Control Room associated with AFW components.
Question So	Bank 0711-01 1.2 001
Referen	AFW STM page 27
Attachme	None
Commen	

Question No	106
System/Mo	d 062000 Stem
A.C. Elect	rical Distribution
KANo	2.1.27 Description Knowledge of system purpose and or function.
-	
Quest	AOP-31 covers the situation where all 4160V buses are fed from the 22KV system. The reason special operations are required under these circumstances is that:
	A. All ESF loads are being supplied by only one off-site power supply.
	B. Fault current may exceed the maximum current interrupting capability of the supply breakers.
	C. Transformer faults may overload the supply bus.
	D. Differential voltages may develop if the loads are not balanced between transformers
Answe	B CFR Sect 41.7
Higher Lev	✓ RO ✓ 2.8 SRO ✓ 2.9
LP Number	LP Objective
0713-02	01.07
State any	special limitations on the 4160 Volt System.
Question So	Bank 0713-02 1.7 001
Referen	AOP-31 page 17
Attachme	None
Commen	

Question N	u 107
System/Mod 062000 Stem Ability to (a) predict the impacts of the following malfunctions of operations on the ac distribution system; and (b) based on the predictions use procedures to correct control or mitigate the	
KANo	A2.10 Description Effects of switching power supplies on instruments and controls
Quest	<ul> <li>With a normal electrical system lineup, which one of the following statements would be true if instrument inverter "C" failed?</li> <li>A. Power would be lost to instrument bus "C" until manually restored.</li> <li>B. The supply for instrument bus "C" would automatically switch to the bypass transformer for inverter "C"".</li> </ul>
	<ul><li>C. The cross tie breakers between instrument buses "A" and "C" would automatically close to supply instrument bus "C".</li><li>D. The cross tie breakers between instrument buses "1" and "C" would automatically close to supply instrument bus "C".</li></ul>
Answe	B CFR Sect 41.5 / 43.5 / 45.3 / 45.13
Higher Lev	□ RO 🖌 3.0 SRO 🗌 3.3
LP Number 0713-04 List the pr	LP Objective 01.03 imary (preferred) and alternate (if any) power supplies to each bus/component.
Question So	Bank 0713-04 1.3 004
Referen	ED STM page 75
Attachme	None
Commen	

Question N	108
System/Mo	d 064000 Stem
Emergeno	y Diesel Generators
KANo	2.1.23 Description Ability to perform specific system and integrated plant procedures during all modes of plant operation.
Quest	What does the red light above the EDG Breaker Auto Close Test Switch Indicate?
	A. It indicates when the auto closure relay picks up in response to the test switch.
	B. It indicates the occurrence of a "Breaker Off AUTO" alarm
	C. It indicates the breaker is in the test position
	D. It indicates that the Breaker Protection Mode Test Switch is positioned incorrectly
Answe	A CFR Sect 45.2/45.6
Higher Lev	□ RO 🖌 3.9 SRO 🖌 4.0
LP Number	LP Objective
0713-05	01.13a
Explain th following:	e use of the instrumentation and controls at CB-20 and AI-30. Include in your explanation the Interpretation of indication lights.
Question So	Bank 0713-05 1.13A 001
Referen	EDG STM page 30
Attachme	None
Commen	

Question N	109
System/Mo	d 064000 Stem Ability to manually operate and/or monitor in the control room:
Emergeno	y Diesel Generators
KANo	A4.06 Description Manual start, loading, and stopping of the ED/G
Quest	What is the result of placing the 183 Master Emergency Switch in the Emergency Mode at AI-133 A/B?
	A. The Diesel-Generator will immediately start and go to idle speed. If associated bus voltage is low, it will go to full speed.
	B. The Diesel-Generator will start and go to full speed, even if the associated bus voltage is normal.
	C. All automatic starts will be disabled. The Diesel-Generator can be started manually locally and from the control room
	D. All automatic starts will be disabled. The Diesel-Generator can be started manually locally but not from the control room.
Answe	D CFR Sect 41.7 / 45.5 to 45.8
Higher Lev	□ RO 🖌 3.9 SRO 🖌 3.9
LP Number	LP Objective
0713-05	01.17
Explain th	e effect of the 183MES switch on control and operation of the EDG. Include in your explanation:
Question So	Modified 0713-05 1.17 001
Referen	EDG STM page 44
Attachme	None
Commen	

Question N	u 110		
System/Mod Stem Ability to (a) predict the impacts of the following malfunctions or			
Liquid Ra	Liquid Radwaste System ; and (b) based on those predictions, use procedures to correct, control, or mitigate the		
KANo	A2.02 Description Lack of tank recirculation prior to release		
Quest	A sample was taken from the waste monitor tank prior to discharge. A release permit. Including the RM-055 setpoints, was prepared based on that sample. A few minutes after the release was initiated with the monitor tank pump selector switch in LEVEL, the running monitor tank pump tripped and HCV-691 and HCV-692 closed. Which one of the following was the most likely cause?		
	A. A VIAS signal was received during the release		
	B. One of the monitor tank inlet valves was not closed prior to the release		
	C. The release flow rate was too low		
	D. The monitor tank was not recirculated adequately		
Answe	D CFR Sect 41.5 / 43.5 / 45.3 / 45.13		
Higher Lev	✓ RO ✓ 2.7* SRO ✓ 2.8*		
LP NumberLP Objective0711-3201.01			
Explain th	e normal operation of the WDLS, including normal flowpath and parameters.		
Question Se	New		
Referen	WD STM page 17		
Attachme	None		
Commen	NRC Comment - B correct? Choice B would not have allowed the release to even begin.		

Question N	u 111
System/Mo	d 068000 Stem Knowledge of the physical connections and/or cause effect relationships between the Liquid Radwaste System and the
Liquid Ra	dwaste System following systems:
KANo	K1.02 Description Waste gas vent header
Quest	Inside containment, water collected in the waste gas vent header can be directly drained to
	A. The Containment Sump
	B. The Reactor Coolant Drain Tank (RCDT)
	C. The Pressurizer Quench tank (PQT)
	D. The Safety Injection Tanks (SITs)
Answe	B CFR Sect 41.2 to 41.9 / 45.7 to 45.8
Higher Lev	□ RO 🖌 2.5 SRO 🗌 2.6
LP Number	LP Objective
0711-32	01.01
Explain th	e normal operation of the WDLS, including normal flowpath and parameters.
Question So	New
Referen	WD STM page 4
Attachme	None
Commen	NRC Comment - Required from memory to know WD-199 vice WD-747 and flowpath? Stem and distractor changed (6/12/01)

Question N	112
System/Mo	d 071000 Stem Ability to manually operate and/or monitor in the control room:
Waste Ga	s Disposal System
KANo	A4.30 Description Water drainage from the WGOS decay tanks
o	
Quest	The "Moisture Separator WD-28A HI/LO Level" alarm was received on AI-100. The EONA noted that the level in the sight glass was high and that valves LC-533A and LC-533B were both open. What action should be taken?
	A. Trip the waste gas compressor
	B. Open WD-216 to drain the moisture separator
	C. Isolate Demineralized water to the moisture separator
	D. Isolate the gas analyzer from the system
Answe	C CFR Sect 41.7 / 45.5 to 45.8
Higher Lev	✓ RO ✓ 2.9* SRO ✓ 2.6*
LP Number	LP Objective
0711-31	01.02
EXPLAIN System.	the operation of controls located in the Control Room associated with the Waste Disposal (Gas)
Question So	New
Referen	ARP-AI100/A50
Attachme	None
Commen	NRC Comment - required from memory Operator should be able to deduce that drain valve is open due to high level and demin water makeup valve has failed open.

Question No	113
System/Mo	d 071000 Stem Knowledge of the physical connections and/or cause-effect
Waste Ga	s Disposal System following systems:
KANo	K1.06 Description ARM and PRM systems
Quest	In accordance with the Waste Gas Release procedure {OI-WDG-2}, which one of the following conditions would require immediate termination of a waste gas release? A. The stack radiation monitor becomes inoperable B. The stack radiation monitor goes into alarm C. The waste gas flow rate recorder fails
	<ul><li>D. The wind direction or stability class changes</li></ul>
Answe	B CFR Sect 41.2 to 41.9 / 45.7 to 45.8
Higher Lev	□ RO 🗹 3.1* SRO 🗹 3.1
LP Number	LP Objective
0711-31	03.03
Using OI-\ a waste g	NDG-2 and other plant references, EXPLAIN conditions that would require immediate termination of as release.
Question So	Bank 0711-31 3.3 001
Referen	OI-WDG-2 page 1
Attachme	None
Commen	NRC Comment - Verify other answers are incorrect.

Question Nu	114
System/Mod	072000 Stem
Area Radia	tion Monitoring System
KANo	2.1.32 Description Ability to explain and apply all system limits and precautions.
_	
Quest	Where can you find the alert and alarm setpoints for the area radiation monitors?
	A. In the Technical Data Book
	B. In Technical Specifications
	C. In the Offsite Dose Calculation Manual
	D. In OI-RM-01
Answe	A CFR Sect 41.10/43.2/45.12
Higher Lev	□ RO <b>✓</b> 3.4 SRO □ 3.8
LP Number	
0712-03	01.00
EXPLAIN t	he principle purposes of the Radiation Monitoring System.
Question So	New
Referen	TDB
Attachme	None
Common	
Commen	NRC Comment - Verify C always incorrect, wince wording of A is questionable for correct answer.
	OPPD Comment - can you argue for C
	New question written (6/12/01)

System/Mod       072000       Stem       Ability to manually operate and/or monitor in the control room:         Area Radiation Monitoring System       Alarm and interlock setpoint checks and adjustments         KANo       A4.01       Description       Alarm and interlock setpoint checks and adjustments         Quest       A source check is being performed on Containment Noble Gas Monitor (RM-051). During this test, the digital display will indicate increasing counts,:       A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur if the monitor is not in keypad         B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur       C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       □       CFR Sect       41.7/45.5 to 45.8         Higher Lev       Ro       ③.0*       SRO       ③.3         LP Number       LP Objective       012.00       04.00       0712-03 4.0 003         Question So       Modified       0712-03 4.0 003       0712-03 4.0 003       0012	Question Nu	115
Area Radiation Monitoring System         KANo       A4.01       Description         Alarm and interlock setpoint checks and adjustments         Quest       A source check is being performed on Containment Noble Gas Monitor (RM-051). During this test, the digital display will indicate increasing counts,:         A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur if the monitor is not in keypad         B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will occur         C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur         C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will occur         Answe       D       CFR Sect         Higher Lev       Ro       3.0*       SRO       3.3         LP Number       LP Objective       3.3         LP Number       LP Objective       3.3         EXPLAIN the operations, actuations and applications of the individual radiation monitors.       Question So       Modified	System/Mo	d 072000 Stem Ability to manually operate and/or monitor in the control room:
KANO       A4.01       Description       Alarm and interlock setpoint checks and adjustments         Quest       A source check is being performed on Containment Noble Gas Monitor (RM-051). During this test, the digital display will indicate increasing counts,:       A.         A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur if the monitor is not in keypad       B.         B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur       C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad       D.         Answe       D       CFR Sect       41.7 / 45.5 to 45.8         Higher Lev       Ro       3.0*       SRO       3.3         LP Number       LP Objective       04.00       0712-03 4.0 003         Question So       Modified       0712-03 4.0 003       0712-03 4.0 003	Area Radi	ation Monitoring System
Quest       A source check is being performed on Containment Noble Gas Monitor (RM-051). During this test, the digital display will indicate increasing counts,:         A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur if the monitor is not in keypad         B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur         C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       D       CFR Sect         41.7 / 45.5 to 45.8         Higher Lev       Ro       3.0*         RO       3.0*       SRO       3.3         LP Number       LP Objective       012-03         D       CFR Sect       41.7 / 45.5 to 45.8         LP Number       LP Objective       3.3         Cuestion So       04.00       0712-03 4.0 003	KANo	A4.01 Description Alarm and interlock setpoint checks and adjustments
A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur         if the monitor is not in keypad         B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur         C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       D         CFR Sect       41.7 / 45.5 to 45.8         Higher Lev       M         RO       Image: Single Sing	Quest	A source check is being performed on Containment Noble Gas Monitor (RM-051). During this test, the digital display will indicate increasing counts,:
B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur         C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       D         CFR Sect       41.7 / 45.5 to 45.8         Higher Lev       M         RO       ☑         3.0*       SRO         EXPLAIN the operations, actuations and applications of the individual radiation monitors.         Question So       Modified		A. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm and CRHS will occur if the monitor is not in keypad
C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad         D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       D       CFR Sect       41.7 / 45.5 to 45.8         Higher Lev       ✓       RO       ✓       3.0*       SRO       ✓       3.3         LP Number       LP Objective       04.00       04.00       0712-03       04.00         EXPLAIN the operations, actuations and applications of the individual radiation monitors.       0712-03 4.0 003       0712-03 4.0 003		B. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will alarm but CRHS will not occur
D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur         Answe       D       CFR Sect       41.7/45.5 to 45.8         Higher Lev       ✓       RO       ✓       SRO       ✓       3.3         LP Number       LP Objective       04.00       0712-03       04.00         EXPLAIN the operations, actuations and applications of the individual radiation monitors.       0712-03 4.0 003		C. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm but CRHS will occur if the monitor is not in keypad
Answe       D       CFR Sect       41.7 / 45.5 to 45.8         Higher Lev       ✓       RO       ✓       3.0*       SRO       ✓       3.3         LP Number       LP Objective       04.00       0712-03       04.00           EXPLAIN the operations, actuations and applications of the individual radiation monitors.       0712-03 4.0 003		D. Annuciator "RM-051 CNTMT NOBLE GAS HIGH RADIATION" will not alarm and CRHS will not occur
Higher Lev RO ☑ 3.0* SRO ☑ 3.3   LP Number LP Objective 0712-03 04.00 EXPLAIN the operations, actuations and applications of the individual radiation monitors.   Question So Modified 0712-03 4.0 003	Answe	D CFR Sect 41.7 / 45.5 to 45.8
LP Number     LP Objective       0712-03     04.00       EXPLAIN the operations, actuations and applications of the individual radiation monitors.       Question So     Modified         0712-03 4.0 003	Higher Lev	✓ RO ✓ 3.0* SRO ✓ 3.3
0712-03 04.00 EXPLAIN the operations, actuations and applications of the individual radiation monitors. Question So Modified 0712-03 4.0 003	LP Number	LP Objective
EXPLAIN the operations, actuations and applications of the individual radiation monitors.         Question So       Modified         0712-03 4.0 003	0712-03	04.00
Question So Modified 0712-03 4.0 003	EXPLAIN	the operations, actuations and applications of the individual radiation monitors.
	Question Sc	Modified 0712-03 4.0 003
Referen RM STM pages 14-15	Referen	RM STM pages 14-15
Attachme None	Attachme	None
Commen Note: K/A system addresses area monitors but KA description is more applicable to process monitors at FCS.	Commen	Note: K/A system addresses area monitors but KA description is more applicable to process monitors at FCS.
Typo fixed (5-28-01)		Typo fixed (5-28-01)

Question Nu 116	
System/Mo	d 078000 Stem Knowledge of the effect that a loss or malfunction of the IAS will
Instrumen	t Air System
KANo	K3.02 Description Systems having pneumatic valves and controls
F	
Quest	Instrument Air Containment Isolation Valves, 1849A and 1849B, have automatically closed during a plant event which resulted in a CIAS and loss of instrument air pressure. Following the event, CIAS was reset and Instrument air pressure was raised to 75 psig. The operator attempted to open 1849A, but it would not open. What additional action must be taken before PCV-1849A will open?
	A. PCV-1849B must be opened
	B. PCV-1753 must be opened
	C. PCV-1749A &B must be opened
	D. Instrument air pressure must be raised above 80 psig
Answe	A CFR Sect 41.7 / 45.6
Higher Lev	✓ RO ✓ 3.4 SRO □ 3.6
LP Number	LP Objective
0711-07	01.05
Explain th parameter	e principles of Abnormal operation of the Compressed Air System in terms of flow paths, major s, (temperature, pressure, flow, etc.), alarms and control devices.
Question So	New
Referen	S & IA STM page 11
Attachme	None
Commen	NRC Comment - Valve names needed?

Question Nu 117		
System/Mo	d 078000 Stem Knowledge of IAS design feature(s) and/or interlock(s) which	
Instrumen	t Air System	
KANo	K4.03 Description Securing of SAS upon loss of cooling water	
Quest	All off-site power has been lost. D1 and D2 have re-energized buses 1A3 and 1A4. What action must be taken to restart an air compressor?	
	A. No action is needed. The standby air compressor will start when the Diesel Generator energizes the 480V buses.	
	B. Start a Bearing Water Pump from the control room, then restart the air compressor using the control room switches	
	C. Start a Bearing Water Pump from the control room, then send the Water Plant Operator to locally start an air compressor	
	D. Send the Water Plant Operator to room 19 to establish backup cooling and locally start an air compressor	
Answe	B CFR Sect 41.7	
Higher Lev	✓ RO ✓ 3.1* SRO □ 3.3*	
LP Number	LP Objective	
0711-07	01.03	
State the power supply for the air compressors.		
Question So Bank 0711-07 1.3 002 reworded		
Referen	TPCW STM page 9	
Attachme	None	
Commen	Is B a local/control room/or either start of the BRG water pump? Reworded (5/28/01)	

Question Nu 118		
System/Mo	d 086000 Stem Knowledge of the physical connections and/or cause-effect relationships between the Fire Protection System and the following	
Fire Prote	ction System systems:	
KANo	K1.01 Description High-pressure service water	
г		
Quest	Following a loss of the Raw Water System, backup cooling is being provided to the CCW heat exchangers using the Fire Protection System. What should be the final position of the Raw Water inlet valves (HCV-2880A through HCV-2883A) and the outlet valves (HCV-2880B through HCV-2883B) for the selected heat exchanger?	
	A Inlet and Outlet valves should both be closed	
	B. Inlet and Outlet valves should both be open	
	C. The inlet valves should be open and the outlet valves closed	
	D. The inlet valves should be closed and the outlet valves open	
Answe	D CFR Sect 41.2 to 41.9 / 45.7 to 45.8	
Higher Lev	□ RO 🗹 3.0* SRO 🗹 3.4*	
LP Number	LP Objective	
0711-19	03.00	
Using the simulator, WALKTHROUGH the procedure to shut down the Raw Water System in accordance with OI-RW-2.		
Question So	Bank 0711-19 3.0 001 choice order changed	
Referen	AOP-18 pages 14-15	
Attachme	None	
Commen	NRC Comment - Required from memory?	

Question N	u 119	
System/Mo	d 103000 Stem Ability to (a) predict the impacts of the following malfunctions or	
Containm	ent System predictions, use procedures to correct, control, or mitigate the	
KANo	A2.04 Description Containment evacuation (including recognition of the alarm)	
Quest	<ul> <li>According to Standing Order O-21, with fuel in the reactor vessel, the Containment Equipment Hatch should not be opened unless it can be closed prior to reaching bulk boiling in the RCS. What is the basis for this requirement?</li> <li>A. Bulk boiling in the RCS may result in the immediate release of fission products</li> <li>B. Once bulk boiling starts, containment pressure may prevent closing the equipment hatch</li> <li>C. Steam produced by the bulk boiling may render the containment charcoal filters ineffective</li> <li>D. With a positive void coefficient, bulk boiling may result in a loss of shutdown margin</li> </ul>	
L		
Answe	B CFR Sect 41.5 / 43.5 / 45.3 / 45.13	
Higher Lev	✓ RO 3.5* SRO ✓ 3.6*	
LP Number	LP Objective	
0707-42	03.06	
Containment pressure response and different scenarios		
Question So	New	
Referen	LP 0707-42 page 20	
Attachme	None	
Commen	OPPD Comment - Only correct choice discusses equipment hatch	

Question Nu 120		
System/Mo	d 103000 Stem Knowledge of containment system design feature(s) and/or interlock(s) which provide for the following:	
Containm	ent System	
KANo	K4.06 Description Containment isolation system	
Quest	Which one of the following will result in a Containment Isolation Actuation Signal (CIAS)?	
	A. Containment Radiation Monitor, RM-050, fails high and alarms.	
	B. Pressure in both steam generators drops below 500 psia due to a steam line break downstream of the MSIVs	
	C. Pressurizer pressure channel B/PIA-102Y fails low	
	D. Inadvertent actuation of ESF relay, 86A/CPHS,	
Answe	D CFR Sect 41.7	
Higher Lev	✓ RO ✓ 3.1 SRO ✓ 3.7	
LP Number	LP Objective	
0712-14	01.04	
EXPLAIN how each prime and backup actuation signal is developed.		
Question So	New	
Referen	ESC STM page 20	
Attachme	None	
Commen		

Question Nu 121		
System/Mod CE-A11 Stem		
RCS Over	cooling	
KANo	2.1.14 Description Knowledge of system status criteria which require the notification of plant personnel.	
Quest	What actions must be taken, according to technical specifications, if the allowable cooldown rate is exceeded?	
	A. Immediately stabilize pressure and temperature. Then notify the NRC to perform an analysis to determine the effects of the out of limits condition on the fracture toughness properties of the RCS.	
	B. Immediately restore pressure and temperature to within the limits. Then notify plant management to perform an analysis to determine the effects of the out of limits condition on the fracture toughness properties of the RCS.	
	C. Immediately stabilize pressure and temperature. Notify NRC. Prior to restart, remove and test weld material samples from capsules for fracture toughness properties.	
	D. Immediately restore pressure and temperature to within the limits. Then notify Plant Management. Prior to restart, remove and test weld material samples from capsules for fracture toughness properties.	
Answe	B CFR Sect 43.5 / 45.12	
Higher Lev	□ RO □ 2.5 SRO ☑ 3.3	
LP NumberLP Objective0762-0805.00		
Given a copy of Technical Specifications, APPLY the requirements to a given condition covered by an LCO.		
Question So New		
Referen	Tech spec 2.1.2 (5)	
Attachme None		
Commen	NRC Comments - Add notification requirement to who? Question changed 6/4/01	

Question Nu 122		
System/Mo	d CE-A11 Stem Ability to operate and / or monitor the following as they apply to the (RCS Overcooling)	
RCS Over	cooling	
KANo	AA1.02 Description Operating behavior characteristics of the facility.	
Quest	What are the potential consequences of defeating the automatic rampdown feature of the main feedwater regulating valves? A. AFAS actuation following a reactor trip	
	P A steam generator water hammer following a reactor trip	
	B. A steam generator water nammer following a reactor trip	
	C. A loss of RCS heat removal following a reactor trip	
	D. Overcooling of the RCS following a reactor trip	
Answe	D CFR Sect 41.7 / 45.5 / 45.6	
Higher Lev	✓ RO ✓ 3.2 SRO □ 3.4	
LP Number	LP Objective	
0711-11	02.05	
EXPLAIN the operation of the Feedwater Control System following a turbine trip.		
Question Sc	New	
Referen	SHB 0715-20 page 12	
Attachme	None	
Commen		

Question Nu 123		
System/Mo	d CE-A13 Stem Ability to operate and / or monitor the following as they apply to the (Natural Circulation Operations)	
Natural Ci	rculation Operations	
KANo	AA1.01 Description Components, and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.	
Quest	The plant tripped from 100% power following a transient involving the loss of forced flow from all four reactor coolant pumps. The following conditions exist: RCS pressure is 2000 psia Pressurizer level is 50% Steam Generator Pressures are 900 psia Steam Generator Wide Range Levels are 40% Hot leg temperatures are 575F Cold leg temperatures are 532F Which one of the following actions would be most effective in enhancing natural circulation? A. Raise RCS pressure B. Raise Pressurizer Level C. Raise Steam Generator Pressures D. Raise Steam Generator Levels	
Answe	D CFR Sect 41.7 / 45.5 / 45.6	
Higher Lev	✓ RO ✓ 3.3 SRO 3.6	
LP Number	LP Objective	
0715-16	01.07	
EXPLAIN the plant response to the development of natural circulation.		
Question So	New	
Referen	SHB 0715-16 page 15	
Attachme		

Commen

OPPD Comment - Give RCS temperature to show adequate subcooling makes choice A clearly wrong. Temperatures added 6/4/01

Question Nu 124		
System/Mc	d CE-A16 Stem Knowledge of the operational implications of the following concepts as they apply to the (Excess RCS Leakage)	
Excess R	CS Leakage	
KANo	AK1.01 Description Components, capacity, and function of emergency systems.	
г		
Quest	In Section III of AOP-22, Reactor Coolant Leak Within Charging Capacity, after verifying RCS pressure less than 1700 psia the operator is directed to block PPLS.	
	Of the following, which ONE is the reason for this direction?	
	A. To allow better RCS pressure control by preventing the injection of cold SIRWT water.	
	B. To enable Low Temperature Overpressure Protection circuitry.	
	C. To maintain the normal boration path available during Steam Generator depressurization.	
	D. To prevent initiation of safety injection with HPSI stop-and-throttle criteria already met.	
Answe	B CFR Sect 41.8 / 41.10 / 45.3	
Higher Lev	□ RO 🗹 3.2 SRO 🗹 3.5	
LP Number	LP Objective	
0717-22	01.02	
Describe how the plant responds to a Reactor Coolant Leak in terms of how specific equipment is affected and how it affects overall plant operation and reliability.		
Question Se	Bank 0717-22 1.2 001	
Referen	AOP-22 page 44	
Attachme		
Commen		

Question N	Question Nu 125		
System/Mo	d CE-E05 Stem Knowledge of the interrelations between the (Excess Steam Demand) and the following:		
Excess S	eam Demand		
KANo	EK2.01 Description Components, and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes, and automatic and manual features.		
Quest	Which one of the following statements is true regarding HPSI stop and throttle?		
	A. HPSI flow should be reduced as soon as a UHE is diagnosed		
	B. HPSI flow should be reduced prior to the affected steam generator drying out in an UHE.		
	C. HPSI flow should not be reduced until all stop and throttle criteria are met in a UHE.		
	D. HPSI flow should not be reduced during a UHE.		
Answe	C CFR Sect 41.7 / 45.7		
Higher Lev	□ RO 🖌 3.3 SRO 🗌 3.6		
LP Number	LP Objective		
0718-15	0718-15 03.01		
GIVEN a copy of the HPSI Stop and Throttle Criteria floating step, EXPLAIN the four indications used to determine the HPSI Stop and Throttle Criteria are met.			
Question So	Bank 0718-15 3.1 001 one distractor changed		
Referen	SHB 0715-0 page 15		
Attachme	None		
Commen			

Question Nu 126		
System/Mo	d CE-E09 Stem	
Functiona	Recovery	
KANo	2.1.14 Description Knowledge of system status criteria which require the notification of plant personnel.	
Quest		
	You, as CRS, have entered EOP-20 due to multiple events. When would you notify the Shift Chemist to sample the steam generators using CH-SMP-SE-015, "Steam Generator Sampling - Room 60" ?	
	A. During any entry into EOP-20	
	B. During an entry into EOP-20 where secondary radiation monitors are in alarm	
	C. During an entry into EOP-20 where SGIS has actuated	
	D. During an entry into EOP-20 where CIAS has actuated	
Answe	D CFR Sect 43.5 / 45.12	
Higher Lev	□ RO □ 2.5 SRO ✔ 3.3	
LP Number	LP Objective	
0718-18	01.03	
STATE the entry conditions for EOP-20.		
Question So New		
Referen	EOP-20 pg 5	
Attachme	None	
Commen	NRC Comment - Required from memory?	

Question Nu 128		
System/Mod 000000 Stem		
Generic K	nowledges and Abilities	
KANo	2.4.10 Description Knowledge of annunciator response procedures.	
Quest	The plant is in mode 3 and surveillance tests are being performed. Annunciator window "flags" are being used in accordance with the OPD 6-04, "Annunciator Marking".? Which one of the following situations is unexpected and requires use of the Annunciator Response Procedures? A. A red flagged annunciator window is unlit B. A blue flagged annunciator window is unlit	
	C. A green flagged annunciator window is lit	
	D. An unflagged annunciator window is lit	
Answe	D CFR Sect 41.10 / 43.5 / 45.13	
Higher Lev	□ RO □ 3.0 SRO ✔ 3.1	
LP NumberLP Objective0762-1101.00		
USE the ARPs to diagnose plant problems.		
Question So	New	
Referen	OPDs	
Attachme	None	
Commen	SRO only question added after NRC review. (question 16 was made RO only) Need to verify choices with procedure Changed again on 6/12/01 to ensure 3 incorrect distractors.	