

January 20, 1998

Mr. W. R. McCollum
Vice President Oconee Site
Duke Energy Corporation
P. O. Box 1439
Seneca, SC 29679

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 - NOTICE OF
CONSIDERATION OF ISSUANCE OF AMENDMENTS (TAC NO. MA0607)

Dear Mr. McCullom:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication.

This notice relates to your application dated January 15, 1998, to amend the Oconee Nuclear Station, Units 1, 2 and 3 Technical Specifications to revise Table 4.1-1 and Specification 4.5.2.1.2 to allow a one-time extension for specified Unit 2 refueling outage surveillances during operating cycle 16.

Sincerely,

ORIGINAL SIGNED BY:

David E. LaBarge, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270 and 50-287

Enclosure:

cc w/encl: See next page

NRC FILE CENTER COPY

Distribution:

Docket File H Berkow BBoger OGC
PUBLIC LBerry ACRS COgle, RII
PD II-2 Rdg. DLaBarge JJohnson, RII

Document Name: G:\OCONEE\OCOA0607.IND

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDII-2/PM	PDII-2/LA		PDII-2/D
NAME	DLaBarge	LBerry		HBerkow
DATE	1/20/98	1/20/98	1/1998	1/1998

OFFICIAL RECORD COPY

9802030133 980120
PDR ADOCK 05000269
P PDR



PDR ADOCK P



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 20, 1998

Mr. W. R. McCollum
Vice President Oconee Site
Duke Energy Corporation
P. O. Box 1439
Seneca, SC 29679

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 - NOTICE OF
CONSIDERATION OF ISSUANCE OF AMENDMENTS (TAC NO. MA0607)

Dear Mr. McCullom:

The Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication.

This notice relates to your application dated January 15, 1998, to amend the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications to revise Table 4.1-1 and Specification 4.5.2.1.2 to allow a one-time extension for specified Unit 2 refueling outage surveillances during operating cycle 16.

Sincerely,

A handwritten signature in black ink, appearing to read "D. LaBarge".

David E. LaBarge, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Notice of Consideration

cc w/encl: See next page

Oconee Nuclear Station

cc:

Mr. Paul R. Newton
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Mr. Robert B. Borsum
Framatome Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852-1631

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory
Commission
7812B Rochester Highway
Seneca, South Carolina 29672

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, S.W., Suite 23T85
Atlanta, Georgia 30303

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Mr. J. E. Burchfield
Compliance Manager
Duke Energy Corporation
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28242-0001

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

UNITED STATES NUCLEAR REGULATORY COMMISSIONOCONEE NUCLEAR STATION, UNITS 1, 2, AND 3DOCKET NOS. 50-269, 50-270, AND 50-287NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. DPR-38, DPR-47, and DPR-55 issued to Duke Energy Corporation (the licensee) for operation of the Oconee Nuclear Station, Units 1, 2, and 3, located Oconee County, South Carolina.

The proposed amendments would revise Technical Specification (TS) Table 4.1-1 and Specification 4.5.2.1.2 to allow a one-time extension for specified Unit 2 refueling outage surveillances during operating cycle 16.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As

required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

This proposed change has been evaluated against the standards in 10 CFR 50.92 and has been determined to involve no significant hazards, in that operation of the facility in accordance with the proposed amendment would not:

1. Involve a significant increase in the probability or consequences of an accident previously evaluated?

No. A review of the previous two instrument channel tests and calibrations for the instruments discussed in the amendment request concluded that no adverse effects should occur as a result of the one-time extension. The ICCM [Inadequate Core Cooling Monitor] should be available to perform its intended function during the requested extension period. Thus, the probability and consequences of an accident previously evaluated will not be significant[ly] increased.

In addition, a review of the previous ES channel 5 and 6 manual trip test and Reactor Building Cooling system test that are discussed in the amendment request concluded that no adverse effects should occur as a result of the one-time extension. ES channels 5 and 6 and the Reactor Building Cooling system should be available to perform their intended function during the requested extension period. Thus, the probability and consequences of an accident previously evaluated will not be significantly increased.

2. Create the possibility of a new or different kind of accident from the accidents previously evaluated?

No. Since the one-time extension should not cause any adverse effects on the ICCM, ES channels 5 and 6, or Reactor Building Spray system, a new or different kind of accident from the accidents which were previously evaluated will not occur. The ICCM, ES channels 5 and 6, and Reactor Building Cooling system, should be available to perform their intended function during the requested extension period.

3. Involve a significant reduction in a margin of safety?

No. The margin of safety will not be significantly reduced by this amendment request because the ICCM, ES channels 5 and 6, and Reactor Building Cooling system, should be available to perform their intended function during the requested extension period. In addition, the review of the previous tests and calibrations which are discussed in the amendment request concluded that no adverse effects should occur as a result of the one-time extension.

Duke has concluded based on the above information that there are no significant hazards involved in this amendment request.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D22, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By February 23, 1998, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene.

Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2.

Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Oconee County Library, 501 West South Broad Street, Walhalla, South Carolina. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave

of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.


A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to J. Michael McGarry, III, Winston and Strawn, 1200 17th Street, NW., Washington, DC 20036, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendments dated January 15, 1998, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Oconee County Library, 501 West South Broad Street, Walhalla, South Carolina.

Dated at Rockville, Maryland, this 20th day of January 1998.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "David E. LaBarge". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

David E. LaBarge, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation