



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET SW SUITE 23T85
ATLANTA, GEORGIA 30303-8931**

July 23, 2001

Mr. Dale E. Young,
Vice President,
Crystal River Nuclear Plant (NA1B)
ATTN: Supervisor, Licensing &
Regulatory Programs
15760 West Power Line Street
Crystal River, FL 34428-6708

SUBJECT: ASSESSMENT FOLLOWUP - CRYSTAL RIVER 3 NUCLEAR PLANT

Dear Young:

On July 19, 2001, the NRC staff completed a review of the performance indicators of Crystal River 3 Nuclear Plant for the second quarter of 2001. The review identified that you had crossed the threshold from green to white for the Reactor Coolant System (RCS) leakage performance indicator. The increase in leakage, reported as a percentage of the Technical Specification limiting value, was identified by your staff while the plant was shutdown to correct a feedwater valve problem. A modification was completed to Decay Heat Valve (DHV)-3 which reduced the RCS leakage prior to the plant being restarted. The performance indicator was White for about one day.

In accordance with the Regulatory Response Column of the NRC's Reactor Oversight Process Agency Action Matrix, we plan to perform supplemental Inspection Procedure 95001 at your facility during the week of August 6, 2001, to review your actions to address the RCS leakage issue. We conducted baseline inspections to review some aspects of your corrective actions as they were implemented. An onsite meeting with your staff has been scheduled for August 9, 2001, to discuss the results of the inspections, the cause of the PI going white, and your plans for additional corrective actions.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/NRC/ADAMS/index.html> (the Public Electronic Reading Room).

Please contact me at 404-562-4540 with any questions you may have regarding this letter.

Sincerely,

/RA/

Leonard D. Wert, Chief
Reactor Projects Branch 3
Division of Reactor Projects

Docket No. 50-302
License No. DPR-72

cc:

Daniel L. Roderick
Plant General Manager
Crystal River Nuclear Plant (NA2C)
Electronic Mail Distribution

Sherry L. Bernhoft
Manager Regulatory Affairs
Crystal River Nuclear Plant (NA2H)
Electronic Mail Distribution

Richard L. Warden
Manager Nuclear Assessment
Crystal River Nuclear Plant (NA2C)
Electronic Mail Distribution

R. Alexander Glenn
Associate General Counsel (MAC - BT15A)
Florida Power Corporation
Electronic Mail Distribution

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, FL 32304

William A. Passetti
Bureau of Radiation Control
Department of Health
Electronic Mail Distribution

Joe Myers, Director
Division of Emergency Preparedness
Department of Community Affairs
Electronic Mail Distribution

Chairman
Board of County Commissioners
Citrus County
110 N. Apopka Avenue
Inverness, FL 36250

Michael A. Schoppman
Framatome Technologies
Electronic Mail Distribution

FPC

3

Distribution w/encl:

J. Goshen, NRR

A. Boland (Part 72 Only)

RIDSNRRDIPMLIPB

PUBLIC

PUBLIC DOCUMENT : YES

OFFICE	RII:DRP	RII:DRP					
SIGNATURE	SON	JSS1					
NAME	SNinh	SStewart					
DATE	7/23/2001	7/21/2001	January 7, 2002	January 7, 2002	January 7, 2002	January 7, 2002	January 7, 2002
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\Program Files\Adobe\Acrobat 4.0\PDF Output\CRsuppltr.wpd

