

# **INDIAN POINT UNIT 2 Steam Generator Tube Failure February 15, 2000**

- **Sequence of Events**
- **Safety Significance**
- **Root Cause Areas**
- **Risk Significance**

## **EVENT DESCRIPTION**

C/42

- **Initiator: PWSCC of the R2C5 tube of the #24 SG; initial primary to secondary leak rate of approximately 150 gpm.**
  
- **Complications: Several operator, procedural and equipment problems delayed establishing cold, shutdown conditions.**
  
- **Results:**
  - **The plant remained in an "Alert" Status ~24 hours**
  - **Minor radiological release.**

## **SEQUENCE OF EVENTS**

February 15, 2000

**7:17 p.m. -- Operators Identified Increased SG Leak**

7:29 p.m. -- Declared Alert  
7:30 p.m. -- Tripped Reactor  
7:41 p.m. -- State/County Officials Notified  
8:31 p.m. -- Isolated Affected SG  
9:02 p.m. -- Operators Initiated Plant

### Cooldown

9:04 p.m. -- Manually Initiated Safety Injection  
11:38 p.m. -- Tube Leak Stopped


### February 16, 2000

12:39 p.m. -- Shutdown Cooling System  
4:57 p.m. -- Achieved Cold Shutdown  
6:50 p.m. -- Terminated Alert

# SAFETY SIGNIFICANCE

- Initial Operator Response  
Prompt/Appropriate
- Licensee Successful in Achieving Cold  
Shutdown
- Several Operator Performance/Procedural  
Issues, and Equipment Issues Identified  
Which Delayed Achieving Cold Shutdown  
Conditions

- **Several Emergency Response Problems**
- **No Measurable Offsite Radiological Release Impact (consistent with calculated results)**
- **No Impact on Public Health and Safety**



# ROOT CAUSE AREAS

- **Operator Performance**
- **Procedural Adequacy**
- **Equipment Performance**
- **Emergency Response**

# OPERATOR PERFORMANCE

- **Initial Response Prompt and**

## **Appropriate; Procedure Adherence Good Overall**

- **Some Deficiencies in the Plant  
Cooldown Phase**
  - **Initial Cooldown Excessive (led to  
SI)**
  - **Operator Recognition of Plant  
Configuration (CCW Valve  
Configuration, Auxiliary Spray)**

# PROCEDURE QUALITY

- **Procedures (AOPs/EOPs) to Guide Initial Response were Good**
  
- **Several Procedural Deficiencies Challenged Operators During the Plant Cooldown Phase**
  - **Delayed Placing Shutdown Cooling In-Service**
  - **System Configuration (CCW Valves, Aux Spray)**
  - **Shutdown Conditions (RCS Temperature)**

# **EQUIPMENT PERFORMANCE**

- **Event Mitigation Systems Worked Properly**
  - **Reactor Protection System**
  - **Auxiliary Feedwater System**
  - **Safety Injection System**
  
- **Some Pre-existing Equipment Problems Challenged Operators**
  - **Automatic Condenser Vacuum Control Valve**
  - **Condenser Mechanical Vacuum Pump**
  - **Containment Valve Seal Water System Design Problem**
  - **Pressurizer Power Operated Relief Valve Design Problem**

## **EMERGENCY**



# RESPONSE

- **Emergency Response Protected Health and Safety of Public**
- **Event Classified Properly/Good Critique of Emergency Response**
  
- **Emergency Plan/Implementing Procedure Problems**
  - **Augmented Emergency Response Facility Staffing Not Timely**
  - **Accountability Problems**
  - **Emergency Response Data System (ERDS) not Operable for Several Hours (Pre-Existing Problem)**
  - **Problems in Implementation of the Media Response Plan**
  - **Emergency Response Facility Equipment Problems**
  - **Technical Support Timeliness and Quality Issues**
  
- **Supplemental EP Inspection**

# RISK SIGNIFICANCE

## Actual Event Risk:

- Initial estimated CCDP for a SGTR ~ 1E-4  
GEM/SPAR & ~7.7E-5 based IPE
- Revised CCDP based on actual leak rate was ~  
2.2E-6

## Key Assumptions:

- Actual SGT failure leak rate ~ 100gpm - HRA revised accordingly
- Charging pumps available for HP makeup

## SDP Conditional Risk Assessment:

- Delta-CDF is used to determine risk significance of inspection findings
- Deficiencies with the 1997 SGT inspection program have a high delta-CDF and are risk significant

## Key Assumptions:

- SGT failure IE frequency ~ 1/RY
- 1/2 tube failures result in ruptures