

RAY - SUGGESTED SIDE FOR Risk Significance  
See ACRS Briefing.

## RISK SIGNIFICANCE

- *Full = Flow  $10^4$  & frequency  $7.7E^{-5}$*
- The CCDP for this event was  $\sim 2.2E-6$  *Revised*
- Potential deficiencies with the 1997 SGT inspection program are ~~risk significant~~ *THE*  
(ACRF one of  $10^4$ )
- Dominant sequence - Failure to depressurize RCS & failure to terminate FW flow to ruptured generator

EVENT RISK  
DOMINANT RISK

### Key Assumptions

- *Flow* SGT  $\sim 100$  gpm - HRA revised accordingly
- Charging pumps available for HP makeup

C/47