CCDP currently being evaluated by RES for THE ABP & may change

RISK SIGNIFICANCE

- CCDP ~ 2E-4
- Dominant Sequence
  - Loss of one MDAFW Pump + Loss of TDAFW Pump + Failure to Recover Feedwater
- Key Assumptions
  - No Credit for 480 Volt Bus Recovery
  - Bleed and Feed Success needs 2 of 2

1/2 Power may be adequate if AFW did not fail immediately

(1) Close bus 6 EDG BKR
(2) Alternate AC Power Appendix R Source to #1 AFW P
(3) Reset Block Signal and Close normal Offsite Power Breakers to 480V Bus.

FW Recovery 2.91E-2 OR .26 If operators Failed to Start TDAFW Pump.

C/39