RISK SIGNIFICANCE

- CCDP ~ 2E-4
- Dominant Sequence
  - Loss of one MDAFW Pump + Loss of TDAFW Pump + Failure to Recover Feedwater
- Key Assumptions
  - No Credit for 480 Volt Bus Recovery
  - Bleed and Feed Success needs 2 of 2

C/40