

# IP2 SGTL Risk Analysis

---

Region I

US NRC

C/54

# Risk Evaluations Performed and Results

---

---

- NRR PRAB Risk Analysis
  - Determined a delta-CDF  $\sim 1E-4$  and a delta LERF  $\sim 1E-4$  for SGT inspection findings
- ConEdison Risk Analysis
  - Determined a CCDFP  $\sim 2.2E-6$  and CLERP  $\sim 0$  for the actual SGT event

# NRC Risk Assessment

## Assumptions

---

- The 1997 SGT inspection performance deficiencies resulted in a IE frequency for SGT failures of 1/year
- The probability that the degraded tube would rupture rather than leak is 0.5
- Includes induced SGTRs - RCS overpressurization events (ATWS); Faulted SGs; and spontaneous failures

# ConEdison Risk Assessment Assumptions

---

- Evaluated risk of actual event (Tube leak versus rupture)
- Assumed additional time available for operator actions & equipment recovery
- RWST inventory sufficient for long period of time and evacuation time sufficient that conditional LERF  $\sim 0$

# Comparison of Risk Assessments

---

- Both risk assessments are technically accurate
- The risk associated with the 2/15/00 SGTL was Low to Moderate (CCDP ~  $2E-6$ )
- The 1997 SGT inspection deficiencies were highly risk significant (delta-CDF ~  $1E-4$ )

# Application of Revised Reactor Oversight Program

---

- Delta-CDF not CCDF is used to determine finding risk significance
- IAW IMC 0609 delta-CDF ~ delta-LERF for SGTR issues
- IAW IMC 0609 delta-LERF  $> 1E-5$  is a Red risk significance finding
- The NRC risk evaluation determined a delta-CDF/LERF of  $> 1E-5$  (Red)

# Summary/Conclusion

---

- The risk significance of the actual SGT event was low to moderate
- Poor SGT inspection in 1997 resulted in a highly risk significance condition
- Applying the guidance of IMC 0609 the risk associated with the SGT inspection findings are Red based on delta-LERF and Red/Yellow based on delta-CDF