

February 8, 1978

DISTRIBUTION

Dockets  
NRC PDRs  
LOCAL PDR  
ORB#1 Reading  
VStello  
KRGoller  
JCGough  
ASchwencer  
DNeighbors  
SMSheppard  
DEisenhut  
OIUE&3(  
OELD  
BJones  
TBAbernathy  
JRBuchanan  
ACRS(16)

Docket Nos. 50-269  
50-270  
and 50-287

Duke Power Company  
ATTN: Mr. William O. Parker, Jr.  
Vice President - Steam Production  
Post Office Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

Gentlemen:

This confirms our telephoned authorization given today, February 8, 1978, for a change in Technical Specifications for the Oconee Nuclear Station as requested by your telecopy on February 8, 1978. Facility Operating License Nos. DPR-38, DPR-47 and DPR-55 are amended on this date by making the following Technical Specification change:

The following sentence to be added to Section 3.3.5 to read:

"In the case of Reactor Building Spray valve 3BS2, 72 consecutive hours are allowed to return the valve to operable status on a one time basis only; this 72 hour allowance shall expire on February 10, 1978."

Copies of the license amendments, our evaluation and Federal Register Notice for this Technical Specification change will be sent to you when completed.

Sincerely,

Original signed by ASchwencer

for/  
Karl R. Goller, Assistant Director  
for Operating Reactors  
Division of Operating Reactors

Cc: See next page

OFFICE →	DOR:ORB#1N	DOR:ORB#1	DOR:AD/OR		
SURNAME →	DNeighbors:1b	ASchwencer	KRGoller		
DATE →	2/8/78	2/ /78	2/ /78		

February 8, 1978

cc: Mr. William L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

J. Micheal McGarry, III, Esquire  
DeBevoise & Liberman  
700 Shoreham Building  
806-15th Street, NW.,  
Washington, D.C. 20005

Oconee Public Library  
201 South Spring Street  
Walhalla, South Carolina 29691

Honorable James M. Phinney  
County Supervisor of Oconee County  
Walhalla, South Carolina 29621

Chief, Energy Systems  
Analyses Branch (AW-459)  
Office of Radiation Programs  
U. S. Environmental Protection Agency  
Room 645, East Tower  
401 M Street, S. W.  
Washington, D. C. 20460

U. S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Coutland Street, N. E.  
Atlanta, Georgia 30308

Chrys Baggett  
State Clearinghouse  
Division of Policy Development  
116 West Jones Street  
Raleigh, N.C. 27603