

*docket*

JAN 14 1974

Docket Nos. ~~50-269~~  
and ~~50-270~~

Duke Power Company  
ATTN: Mr. Austin C. Thies  
Senior Vice President,  
Production & Transmission  
422 South Church Street  
P. O. Box 2178  
Charlotte, N. C. 28201

Gentlemen:

Your letter of November 28, 1973 requested that Technical Specifications 3.1.5.2 and 3.1.5.3, Appendix A to License No. DPR-38 and No. DPR-47, be revised to raise the chloride and fluoride concentration limits in the primary coolant from 0.1 ppm to 0.15 ppm.

The 0.15 ppm limit for chlorides and fluorides is consistent with Regulatory Guide 1.44, May 1973, and is acceptable to us. We find that there is reasonable assurance that the health and safety of the public will not be endangered by this change.

Pursuant to Section 50.59 of 10 CFR Part 50, Technical Specifications, Appendix A to License Nos. DPR-38 and DPR-47, have been changed in accordance with the revised Technical Specifications 3.1.5.2 and 3.1.5.3 enclosed. These changes are identified as Change No. 8 to Technical Specifications License DPR-38 and Change No. 3 to Technical Specifications License DPR-47, and are effective on date of issuance.

Sincerely,

151

R. C. DeYoung, Assistant Director  
for Pressurized Water Reactors  
Directorate of Licensing

Enclosures:  
See Next Page

*fy*

Austin C. Thies

JAN 14 1974

Enclosures:

- 1. Change No. 8 to Technical Specifications  
License DPR-38
- 2. Change No. 3 to Technical Specifications  
License DPR-47

cc: William L. Porter  
 Duke Power Company  
 P. O. Box 2178  
 422 South Church St.  
 Charlotte, N. C. 28201

DISTRIBUTION:

AEC PDR  
 Local PDR  
 Dockets  
 PWR-4 Rdg  
 RCDeYoung  
 RO (3)  
 DSkovholt  
 RWKiecker  
 RVollmer  
 MJinks (w/4encls)  
 IAPeltier  
 EIGoulbourne  
 ASchwencer  
 WOMiller (W/encls)  
 ACRS (16)  
 Wilchins/Gallo  
 5 extra

L:AD/PWRs  
 RCDeYoung

12/11/73

OFFICE	PWR-4	L:C/PWR-4	OSC	RO	L	L:DD/TR
SURNAME	IAPeltier:kmf	ASchwencer		JM	Pawlicki	JHendrie
DATE	12/6/73	12/11/73	12/11/73	12/11/73	12/7/73	12/11/73