

Exelon Nuclear
200 Exelon Way
KSA 3-E
Kennett Square, PA 19348

Telephone 610.765.5520
www.exeloncorp.com

Nuclear

10CFR50, Appendix E

July 25, 2001

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: Limerick Generating Station, Units 1 & 2
Facility Operating License Nos. NPF-39 and NPF-85
NRC Docket Nos. 50-352 and 50-353
ERP-101 Bases, Revision 2, "LGS EAL Technical Basis Manual"

Dear Sir/Madam:

Enclosed is the subject referenced Emergency Response Procedure (ERP) for Limerick Generating Station (LGS), Units 1 and 2. This procedure is required to be submitted within thirty (30) days of its revision in accordance with 10CFR50, Appendix E, and 10CFR50.4.

Also, enclosed is a copy of a computer generated report index identifying the latest revisions of the LGS ERPs.

If you have any questions or require additional information, please do not hesitate to contact us.

Very truly yours,



James A. Hutton
Director - Licensing
Mid-Atlantic Regional Operating Group

Enclosures

cc: H. J. Miller, Administrator, Region I, USNRC (2 copies)
A. L. Burritt, USNRC Senior Resident Inspector, LGS

A-45

ATTACHMENT 1

LIMERICK GENERATING STATION, UNITS 1 & 2

**Docket Nos. 50-352
50-353**

**License Nos. NPF-39
NPF-85**

EMERGENCY RESPONSE PROCEDURE

**ERP-101 Bases, "LGS EAL Technical Basis Manual"
Revision 2**

LGS EAL Technical Basis Manual

Table of Contents

Section I - Introduction	2
Section II - Acronyms	4
Section III - EAL Technical Basis	6
1.0 Reactor Fuel	
1.1 Coolant Activity	7
1.2 Irradiated Fuel or New Fuel	9
2.0 Reactor Pressure Vessel	
2.1 Reactor Water Level	19
2.2 Reactor Power	23
3.0 Fission Product Barrier	
3.1 Initiating Condition Matrix	29
3.2 Fuel Clad Barrier Thresholds	32
3.3 Reactor Coolant System Barrier Thresholds	41
3.4 Primary Containment Barrier Thresholds	46
3.5 Fission Product Barrier Table	57
4.0 Secondary Containment Bypass	
4.1 Main Steam Line	59
5.0 Radioactivity Release	
5.1 Effluent Release and Dose	61
5.2 In-Plant Radiation	71
6.0 Loss of Power	
6.1 Loss of AC or DC Power	77
7.0 Internal Events	
7.1 Technical Specifications & Control Room Evacuation	87
7.2 Loss of Decay Heat Removal Capability	90
7.3 Loss of Assessment/Communications Capability	94
8.0 External Events	
8.1 Security Events	101
8.2 Fire/Explosion and Toxic/Flammable Gases	106
8.3 Man-Made Events	113
8.4 Natural Events	116
9.0 Other	
9.1 General	123

Section I - Introduction

This manual contains the technical basis for the Emergency Action Levels as utilized in ERP-101, Classification of Emergencies. The format and use of this manual is as follows.

1. Heading and Sub-Heading

There are nine major headings each containing one or more sub-headings. These are as follows:

- 1.0 Reactor Fuel
 - 1.1 Coolant Activity
 - 1.2 Irradiated Fuel or New Fuel
- 2.0 Reactor Pressure Vessel
 - 2.1 Reactor Water Level
 - 2.2 Reactor Power
- 3.0 Fission Product Barrier
 - 3.1 Initiating Condition Matrix
 - 3.2 Fuel Clad Barrier Thresholds
 - 3.3 Reactor Coolant System Barrier Thresholds
 - 3.4 Primary Containment Barrier Thresholds
 - 3.5 Fission Product Barrier Table
- 4.0 Secondary Containment
 - 4.1 Main Steam Line
- 5.0 Radioactivity Release
 - 5.1 Effluent Release and Dose
 - 5.2 In-Plant Radiation
- 6.0 Loss of Power
 - 6.1 Loss of AC or DC Power
- 7.0 Internal Events
 - 7.1 Technical Specifications & Control Room Evacuation
 - 7.2 Loss of Decay Heat Removal Capability
 - 7.3 Loss of Assessment/Communications Capability
- 8.0 External Events
 - 8.1 Security Events
 - 8.2 Fire/Explosion and Toxic/Flammable Gases
 - 8.3 Man-Made Events
 - 8.4 Natural Events
- 9.0 Other
 - 9.1 General

2. Emergency Classification Level and Number Identification

The classifications range from Unusual Event through Alert, Site Area Emergency to General Emergency. For each sub-heading, there may not be an EAL in every classification level. Each EAL is individually and uniquely numbered. No two numbers are the same.

3. INITIATING CONDITION

The Initiating Condition or IC (as described in NUMARC NESP-007) is contained in this section. ICs are a predetermined subset of conditions where either the potential exists for a radiological emergency or such an emergency has occurred. Additionally, ICs are the means by which EALs for different nuclear power plants are standardized.

4. EAL

Each Emergency Action Level exactly as it is contained in ERP-101.

5. OPCON

The operational condition (OPCON) that the EAL is applicable in is contained here. There are six OPCONs (1, 2, 3, 4 and 5 and defueled) that are used. LGS also uses mode switch position. These positions are stated below and are Run, Startup, Shutdown and Refueling. It should be noted that these OPCONs are entry level conditions. The EAL is applicable if the plant was in the OPCON at the start of the event. Subsequent positions of the mode selector switch should be ignored for purposes of classification.

<u>OPCON (MODE)</u>	<u>MODE SWITCH POSITION</u>
1	Run
2	Startup
3	Shutdown (hot)
4	Shutdown (cold)
5	Refueling
D	N/A (defueled)

6. BASIS

The technical basis of each EAL is contained in this section. This includes any necessary calculations and also includes escalation references.

7. DEVIATION

Any deviations from the NUMARC NESP-007 methodology are contained in this section. If there are no deviations, NONE is used.

8. REFERENCES

All applicable references used in developing the technical basis for each EAL are contained in this section.

Section II - Acronyms

AC	-	Alternating Current
ADS	-	Automatic Depressurization System
APRM	-	Average Power Range Monitor
ARI	-	Alternate Rod Insertion
ARM	-	Area Radiation Monitor
ATWS	-	Anticipated Transient Without Scram
BRP	-	Bureau of Radiation Protection
CAC	-	Containment Atmosphere Control
CDE	-	Committed Dose Equivalent
CFM	-	Cubic Feet Per Minute
CFR	-	Code of Federal Regulations
CRD	-	Control Rod Drive
CS	-	Core Spray
DBA	-	Design Basis Accident
DC	-	Direct Current
DEI	-	Dose Equivalent Iodine
EAL	-	Emergency Action Level
ECCS	-	Emergency Core Cooling Systems
EDG	-	Emergency Diesel Generator
EPA	-	Environmental Protection Agency
ERP-C	-	Emergency Response Procedure - Common
ESW	-	Emergency Service Water
FC	-	Fuel Clad (Barrier)
FTS	-	Federal Telephone System
GPM	-	Gallons Per Minute
HCTL	-	Heat Capacity Temperature Limit
HPCI	-	High Pressure Coolant Injection
IC	-	Initiating Condition
IRM	-	Intermediate Range Monitor
KV	-	KiloVolt
LCO	-	Limiting Condition for Operation
LGS	-	Limerick Generating Station
LOCA	-	Loss of Coolant Accident
LPCI	-	Low Pressure Coolant Injection
MPH	-	Miles Per Hour
mR/hr	-	Milli Roentgen Per Hour
MSIV	-	Main Steam Isolation Valve
NFPB	-	Normal Full Power Background
NPSH	-	Net Positive Suction Head
NRC	-	Nuclear Regulatory Commission
NUMARC	-	Nuclear Management and Resources Council
ODCM	-	Offsite Dose Calculation Manual
OPCON	-	Operating Condition
PEMA	-	Pennsylvania Emergency Management Agency
PC	-	Primary Containment (Barrier)
PCIS	-	Primary Containment Isolation System
PSIG	-	Pounds Square Inch Gauge
RERS	-	Reactor Enclosure Recirc System
RC	-	Reactor Coolant (Barrier)
RCIC	-	Reactor Core Isolation Cooling
RCS	-	Reactor Coolant System
RHR	-	Residual Heat Removal

RPS	-	Reactor Protection System
RPV	-	Reactor Pressure Vessel
RRCS	-	Redundant Reactivity Control System
SBO	-	Station Blackout
SGTS	-	Standby Gas Treatment System
SJAE	-	Steam Jet Air Ejector
SRM	-	Source Range Monitor
SRV	-	Safety Relief Valve
TAF	-	Top of Active Fuel
TPARD	-	Total Protective Action Recommendation Dose
TRIPs	-	Transient Response Implementation Plan Procedures
$\mu\text{Ci/cc}$	-	Micro Curie Per Cubic Centimeter
$\mu\text{Ci/gm}$	-	Micro Curie Per Gram
UFSAR	-	Updated Final Safety Analysis Report
VDC	-	Volts Direct Current

Section III - EAL Technical Basis

1.0 Reactor Fuel

1.1 Coolant Activity

UNUSUAL EVENT - 1.1.1.a

IC Fuel Clad Degradation

EAL

Reactor Coolant activity > 4 $\mu\text{Ci/gm}$ Dose Equivalent Iodine 131

OPCON ALL

BASIS

Coolant activity in excess of Technical Specifications ($> 4 \mu\text{Ci/gm}$) is considered to be a precursor of more serious problems. The Technical Specification limit reflects a degrading or degraded core condition. This level is chosen to be above any possible short duration spikes under normal conditions. An Unusual Event is only warranted when actual fuel clad damage is the cause of the elevated coolant sample (as determined by laboratory confirmation). However, fuel clad damage should be assumed to be the cause of elevated Reactor Coolant activity unless another cause is known, e.g., Reactor Coolant System chemical decontamination evolution (during shutdown) is ongoing with resulting high activity levels.

This event will be escalated to an Alert when Reactor Coolant activity exceeds 300 $\mu\text{Ci/gm}$ Dose Equivalent Iodine 131 per Fission Product Barrier Table.

DEVIATION

None

REFERENCES

Technical Specification Section 3.4.5
NUMARC NESP-007, SU4.2

1.0 Reactor Fuel

1.1 Coolant Activity

UNUSUAL EVENT - 1.1.1.b

IC Fuel Clad Degradation

EAL

SJAE Radiation (Offgas Monitor) > 2.1×10^4 mR/hr

OPCON 1, 2, 3

BASIS

The steam jet air ejector radiation monitor in the Control Room would be one of the first indicators of a degrading core. The high-high alarm is set at the Technical Specification limit of 2.1×10^4 mR/hr. This instrument takes a sample before the recombiner. This indicator of elevated activity is considered to be a precursor of more serious problems. The Technical Specification limit reflects a degrading or degraded core condition.

Escalation of this IC to the Alert level is via the Fission Product Barrier Degradation Monitoring ICs.

DEVIATION

The OPCON applicability [1,2,3] is a deviation from NUMARC [all] in that the SJAE Radiation Monitor and Main Steam Line Radiation Monitors will only be a valid indication of Fuel Clad Degradation in those OPCON's. At Limerick, there are no other monitors which can be an indicator of Fuel Clad Degradation. Degradation in cold shutdown or refueling will be first indicated by ventilation release monitor's which are covered by EAL on Effluent Release and Dose.

REFERENCES

Technical Specifications Section 3.3.7.12, 3.11.2.6
NUMARC NESP-007, SU4.1

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

UNUSUAL EVENT - 1.2.1.a

IC Unexpected Increase in Plant Radiation or Airborne Concentration.

EAL

Uncontrolled water level decrease in the spent fuel pool with all irradiated fuel assemblies remaining covered by water

OPCON ALL

BASIS

UNCONTROLLED - An unexplained level drop that cannot be quickly terminated and is not the result of a planned evolution.

This event tends to have a long lead time relative to potential for radiological release outside the site boundary, thus impact to public health and safety is very low.

In light of Reactor Cavity Seal failure incidents at two different PWRs and loss of water in the Spent Fuel Pit/Fuel Transfer Canal at a BWR all occurring since 1984, explicit coverage of these types of events via this EAL is appropriate given their potential for increased doses to plant staff. Classification as an Unusual Event is warranted as a precursor to a more serious event.

This event will be escalated to an Alert as a result of uncovering of a fuel assembly and/or indication of high radiation levels on the refueling floor.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AU2.2
Technical Specifications

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

UNUSUAL EVENT - 1.2.1.b

IC Unexpected Increase in Plant Radiation or Airborne Concentration.

EAL

Unexpected Fuel Pool Storage low level alarm

AND

Visual observation of an uncontrolled water level decrease below the fuel pool skimmer surge tank inlet

OPCON ALL

BASIS

UNEXPECTED - An alarm that is not a result of a planned evolution.

UNCONTROLLED - An unexplained level drop that cannot be quickly terminated and is not the result of a planned evolution.

A drop in the Spent Fuel Pool level or the RPV [when in refueling and flooded up with the gates removed] will result in a control room annunciator Fuel Pool Storage Lo Level Alarm. This Control Room alarm directs an operator to be dispatched to a local alarm panel which will identify the reason for the alarm. This alarm is validated with visual observation of a decreasing Spent Fuel Pool level. If the spent fuel pool level decreases below the inlet to the skimmer surge tank, without a planned event such as removing a large piece of equipment, there must be a leak in the spent fuel pool or the RPV. This event has a long lead time relative to potential for radiological release outside the site boundary, thus the impact to public health and safety is very low. Classification as an Unusual Event is warranted as a precursor to a more serious event.

In light of Reactor Cavity Seal failure incidents at two different PWRs and loss of water in the Spent Fuel Pit/Fuel Transfer Canal at a BWR all occurring since 1984, explicit coverage of these types of events via this EAL is appropriate given their potential for increased doses to plant staff. Classification as an Unusual Event is warranted as a precursor to a more serious event.

This event will be escalated to an Alert as a result of uncovering of a fuel assembly and/or indication of high radiation levels on the refueling floor.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AU2.1

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

ALERT - 1.2.2.a

IC Major Damage to Irradiated Fuel, or Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Unplanned general area radiation > 500 mR/hr on the refuel floor (Table 1-1)

OPCON ALL

BASIS

This IC applies to spent fuel requiring water coverage and is not intended to address spent fuel which is licensed for dry storage, which is discussed in NUMARC/NESP-007 IC AU2, "Unexpected Increase in Plant Radiation or Airborne Concentration."

NUREG-0818, "Emergency Action Levels for Light Water Reactors," forms the basis for this EAL. The areas where irradiated fuel is located forms the basis for the radiation monitors listed in Table 1-1.

Unexpected radiation levels which are at least 100 times higher than the normal background will generally indicate a fuel handling accident or loss of water covering the irradiated fuel. Readings may be from refuel floor Area Radiation Monitors or taken during a qualified radiological survey. Table 1-1 monitors are as follows:

Table 1-1 Refuel Floor ARMs

RIS29-M1-1(2)K600, Drywell Head Laydown
RIS30-M1-1(2)K600, Dryer/Seperator Area
RIS31-M1-1(2)K600, Spent Fuel Pool
RIS32-M1-1(2)K600, New Fuel Storage Vault
RIS33-M1-1(2)K600, Pool Plug Laydown

There is time available to take corrective actions, and there is little potential for substantial fuel damage. In addition, NUREG/CR-4982, "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82," July 1987, indicates that even if corrective actions are not taken, no prompt fatalities are predicted, and that risk of injury is low. In addition, NRC Information Notice No. 90-08, "Kr-85 Hazards from Decayed Fuel" presents the following in its discussion:

In the event of a serious accident involving decayed spent fuel, protective actions would be needed for personnel on site, while offsite doses (assuming an exclusion area radius of one mile from the plant site) would be well below the Environmental Protection Agency's Protective Action Guides. Accordingly, it is important to be able to properly survey and monitor for Kr-85 in the event of an accident with decayed spent fuel.

Licensees may wish to reevaluate whether Emergency Action Levels specified in the emergency plan and procedures governing decayed fuel-handling activities appropriately focus on concern for onsite workers and Kr-85 releases in areas where decayed spent fuel accidents could occur, for example, the spent fuel pool working floor. Furthermore, licensees may wish to determine if emergency plans and corresponding exposures of onsite personnel who are in other areas of the plant. Among other things, moving onsite personnel away from the plume and shutting off building air intakes downwind from the source may be appropriate.

Offsite doses during these accidents would be well below the EPA Protective Action Guidelines and the classification as an Alert is therefore appropriate. This radiation level could also be caused by an inadvertent criticality and is included even though the probability of this event occurring is low. Radiation increases above 500 mR/hr which were expected should not cause an Alert to be declared during a planned evolution. Additionally, surveys which identify "hot spots" greater than 500 mR/hr should not cause an Alert to be declared.

Escalation, if appropriate, would occur via Effluent Release, In-plant radiation, or Emergency Director Judgement.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.1

NUREG-1228, Source Term Estimation During Incident Response to Severe Nuclear Power Plant Accidents

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

ALERT - 1.2.2.b

IC Major Damage to Irradiated Fuel, or Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Report of visual observation of irradiated fuel uncovered

OPCON ALL

BASIS

This IC applies to spent fuel requiring water coverage and is not intended to address spent fuel which is licensed for dry storage, which is discussed in NUMARC/NESP-007 IC AU2, "Unexpected Increase in Plant Radiation or Airborne Concentration."

NUREG-0818, "Emergency Action Levels for Light Water Reactors," forms the basis for this EAL.

Studies of the loss of fuel pool water level indicate that a significant release may occur if rapid oxidation of the fuel clad occurs due to prolonged fuel uncovering. Offsite doses are not; however, expected to exceed EPA PAGs. In addition, NRC Information Notice No. 90-08, "Kr-85 Hazards from Decayed Fuel" presents the following in its discussion:

In the event of a serious accident involving decayed spent fuel, protective actions would be needed for personnel on site, while offsite doses (assuming an exclusion area radius of one mile from the plant site) would be well below the Environmental Protection Agency's Protective Action Guides. Accordingly, it is important to be able to properly survey and monitor for Kr-85 in the event of an accident with decayed spent fuel.

Licensees may wish to reevaluate whether Emergency Action Levels specified in the emergency plan and procedures governing decayed fuel-handling activities appropriately focus on concern for onsite workers and Kr-85 releases in areas where decayed spent fuel accidents could occur, for example, the spent fuel pool working floor. Furthermore, licensees may wish to determine if emergency plans and corresponding exposures of onsite personnel who are in other areas of the plant. Among other things, moving onsite personnel away from the plume and shutting off building air intakes downwind from the source may be appropriate.

Thus, an Alert Classification for this event is appropriate. Escalation, if appropriate, would occur via Effluent Release, In-plant radiation, or Emergency Director Judgement.

I
DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.2

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

ALERT - 1.2.2.c

IC Major Damage to Irradiated Fuel, or Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Water Level < **22 feet above RPV flange** for the Reactor Refueling Cavity that will result in Irradiated Fuel uncovering

OPCON ALL

BASIS

This IC applies to spent fuel requiring water coverage and is not intended to address spent fuel which is licensed for dry storage, which is discussed in NUMARC/NESP-007 IC AU2, "Unexpected Increase in Plant Radiation or Airborne Concentration."

NUREG-0818, "Emergency Action Levels for Light Water Reactors," forms the basis for this EAL.

There is time available to take corrective actions, and there is little potential for substantial fuel damage. In addition, NUREG/CR-4982, "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82," July 1987, indicates that even if corrective actions are not taken, no prompt fatalities are predicted, and that risk of injury is low. In addition, NRC Information Notice No. 90-08, "Kr-85 Hazards from Decayed Fuel" presents the following in its discussion:

In the event of a serious accident involving decayed spent fuel, protective actions would be needed for personnel on site, while offsite doses (assuming an exclusion area radius of one mile from the plant site) would be well below the Environmental Protection Agency's Protective Action Guides. Accordingly, it is important to be able to properly survey and monitor for Kr-85 in the event of an accident with decayed spent fuel.

Licensees may wish to reevaluate whether Emergency Action Levels specified in the emergency plan and procedures governing decayed fuel-handling activities appropriately focus on concern for onsite workers and Kr-85 releases in areas where decayed spent fuel accidents could occur, for example, the spent fuel pool working floor. Furthermore, licensees may wish to determine if emergency plans and corresponding exposures of onsite personnel who are in other areas of the plant. Among other things, moving onsite personnel away from the plume and shutting off building air intakes downwind from the source may be appropriate.

The value 22 feet above RPV flange is the Tech. Spec. Limit and an uncontrolled level decrease that would uncover irradiated fuel is an indicator of a decrease in the level of safety of the plant.

Thus, an Alert Classification for this event is appropriate. Escalation, if appropriate, would occur via Effluent Release, In-plant radiation, or Emergency Director Judgement.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.3
Tech Spec 3.9.8

1.0 Reactor Fuel

1.2 Irradiated Fuel or New Fuel

ALERT - 1.2.2.d

IC Major Damage to Irradiated Fuel, or Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Water Level < **22 feet above seated Irradiated Fuel** for the Spent Fuel Pool that will result in Irradiated Fuel uncovering

OPCON ALL

BASIS

This IC applies to spent fuel requiring water coverage and is not intended to address spent fuel which is licensed for dry storage, which is discussed in NUMARC/NESP-007 IC AU2, "Unexpected Increase in Plant Radiation or Airborne Concentration."

NUREG-0818, "Emergency Action Levels for Light Water Reactors," forms the basis for this EAL.

There is time available to take corrective actions, and there is little potential for substantial fuel damage. In addition, NUREG/CR-4982, "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82," July 1987, indicates that even if corrective actions are not taken, no prompt fatalities are predicted, and that risk of injury is low. In addition, NRC Information Notice No. 90-08, "Kr-85 Hazards from Decayed Fuel" presents the following in its discussion:

In the event of a serious accident involving decayed spent fuel, protective actions would be needed for personnel on site, while offsite doses (assuming an exclusion area radius of one mile from the plant site) would be well below the Environmental Protection Agency's Protective Action Guides. Accordingly, it is important to be able to properly survey and monitor for Kr-85 in the event of an accident with decayed spent fuel.

Licensees may wish to reevaluate whether Emergency Action Levels specified in the emergency plan and procedures governing decayed fuel-handling activities appropriately focus on concern for onsite workers and Kr-85 releases in areas where decayed spent fuel accidents could occur, for example, the spent fuel pool working floor. Furthermore, licensees may wish to determine if emergency plans and corresponding exposures of onsite personnel who are in other areas of the plant. Among other things, moving onsite personnel away from the plume and shutting off building air intakes downwind from the source may be appropriate.

The value 22 feet above seated Irradiated Fuel is the Tech. Spec. Limit and an uncontrolled level decrease that would uncover irradiated fuel is an indicator of a decrease in the level of safety of the plant.

Thus, an Alert Classification for this event is appropriate. Escalation, if appropriate, would occur via Effluent Release, In-plant radiation, or Emergency Director Judgement.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.4
Tech Spec 3.9.9

2.0 Reactor Pressure Vessel

2.1 Reactor Pressure Boundary

UNUSUAL EVENT - 2.1.1

IC Reactor Coolant System Leakage

EAL

The following conditions exist:

Unidentified Primary System Leakage > **10 gpm** into the Drywell

OR

Identified Primary System Leakage > **25 gpm** into the Drywell

OPCON 1, 2, 3, 4

BASIS

Utilizing the leak before break methodology, it is anticipated that there will be indication(s) of minor reactor coolant system boundary integrity loss prior to this fault escalating to a major leak or rupture. Detection of low levels of leakage while pressurized is utilized to monitor for the potential of catastrophic failures. Leakage not associated with catastrophic failure potential such as SRV leakage, should not be considered in this EAL.

Identified and unidentified Primary System Leakage is measured by the normal primary system leakage monitoring system and is leakage into the drywell.

This EAL is included as an Unusual Event because it may be a precursor of more serious conditions and, as a result, it is considered to be a potential degradation of the level of safety of the plant. The value of 10 gpm unidentified leakage is significantly higher than the expected pressurized leak rate from the reactor coolant system. The 10 gpm value for the unidentified pressure boundary leakage was selected as it is twice the Technical Specification value, indicating an increase beyond that assumed in Safety Analysis. It also is observable with normal control room indications. The EAL for identified leakage is set at a higher value (25 gpm) due to the lesser significance of identified leakage in comparison to unidentified or pressure boundary leakage.

Technical Specification LCO required actions would necessitate a plant shutdown and subsequent depressurization, unless the source of the leak can be isolated, identified, and/or stopped. Actions initiated by plant staff would include close monitoring of the calculated break size such that any sudden or gradual increase in leak rate would be identified. A slow power reduction and gradual depressurization would be necessitated due to the possibility that a sudden power and/or pressure surge could potentially worsen the break or cause a catastrophic failure.

The leak rate of 10 gpm may cause a high drywell pressure indication. Other indications of a leak of this magnitude would include an increase in drywell temperature or radiation.

This event will escalate to an Alert based upon high Drywell pressure per Fission Product Barrier Table.

DEVIATION

NUMARC Example EAL SU5.1.a identifies pressure boundary leakage. There is no Limerick EAL listed for pressure boundary leakage specifically since it is a subset of unidentified leakage. Limerick Tech. Specs. requires a shutdown if any pressure boundary leakage is found.

REFERENCES

NUMARC NESP-007, SU5
Technical Specifications
T-101, RPV Control
T-102, Primary Containment Control

2.0 Reactor Pressure Vessel

2.1 Reactor Water Level

SITE AREA EMERGENCY - 2.1.3

IC Loss of Water Level in the Reactor Vessel That Has or Will Uncover fuel in the Reactor Vessel

EAL

RPV level < -161 "

OPCON 4, 5

BASIS

The indicator for "core is or will be uncovered" is Reactor Pressure Vessel Water level below the Top of Active Fuel (TAF) -161 inches as indicated on RPV Fuel Zone Level Instruments. Core submergence ensures adequate core cooling. When RPV level decreases below the top of active fuel the ability to remove the decay heat generated from the nuclear fuel becomes suspect and the Fuel Clad Fission Product barrier can no longer be considered intact. Sustained partial or total core uncover can result in the release of a significant amount of fission products to the reactor coolant.

Under the conditions specified by this IC, severe core damage can occur and reactor coolant system pressure boundary integrity may not be assured. It is intended to address concerns raised by NRC Office for Analysis and Evaluation of Operational Data (AEOD) report AEOD/EG09, "BWR Operating Experience Involving Inadvertent Draining of the Reactor Vessel," dated August 8, 1986. This report states:

In broadest terms, the dominant causes of inadvertent reactor vessel draining are related to the operational and design problems associated with the residual heat removal system when it is entering into or exiting from the shutdown cooling mode. During this transitional period, water is drawn from the reactor vessel, cooled by the residual heat removal system heat exchangers (from the cooling provided by the service water system), and returned to the reactor vessel. First, there are piping and valves in the residual heat removal system which are common to both the shutdown cooling mode and other modes of operation such as low pressure coolant injection and suppression pool cooling. These valves, when improperly positioned, provide a drain path for reactor coolant to flow from the reactor vessel to the suppression pool or the radwaste system. Second, establishing or making such evolutions vulnerable to personnel and procedural errors. Third, there is no comprehensive valve interlock arrangement for all shutdown cooling. Collectively, these factors have contributed to the inadvertent draining of the reactor vessel.

Thus, declaration of a Site Area Emergency is warranted under the conditions specified by the IC. Escalation to a General Emergency is via effluent release EAL.

DEVIATION

During EAL review and approval process, it was determined that the condition stated in NUMARC NESP-007, SS5, 1.a "Loss of all decay heat removal cooling as determined by (site-specific) procedure" is not necessary to conclude that the plant condition warrants a Site Area Emergency. Therefore, that sample NUMARC EAL was not included in this EAL.

REFERENCES

NUMARC NESP-007, SS5

2.0 Reactor Pressure Vessel

2.2 Reactor Power

ALERT - 2.2.2

IC Failure of Reactor Protection System Instrumentation to Complete or Initiate an Automatic Reactor Scram Once a Reactor Protection System Setpoint Has Been Exceeded and Manual Scram Was Successful

EAL

Automatic RPS SCRAM should occur due to RPS Setpoint being exceeded

AND

Failure of Automatic RPS SCRAM to make Reactor shutdown

OPCON 1, 2

BASIS

This EAL is not applicable if a manual scram is initiated and no RPS setpoints are exceeded. Taking the mode switch to shutdown is considered a manual scram action. This may cause an RPS Setpoint to be exceeded due to the change in Nuclear Instrumentation Scram setpoint when the mode switch is placed in shutdown. If the RPS then fails to initiate a scram, then this should be evaluated as an automatic RPS setpoint being exceeded.

Entry into this EAL is based on a reactor parameter actually exceeding a RPS setpoint and the reactor is not brought to a shutdown condition and maintained at that state with automatic RPS functions. The parameter must exceed the RPS setpoint by a significant margin eliminating minor setpoint drifts which are accounted for in the Technical Specification Margin of Safety. Subsequent manual scram actions were successful in bringing the reactor to a shutdown condition. Confirmation indications include control room annunciators, APRM/IRM/SRM power level, SRM period, and Control rod position indication.

A failure of the Reactor Protection System (RPS) to initiate and complete a reactor scram may indicate that the design limits of the nuclear fuel has been compromised. RPS is designed to automatically detect and generate a reactor scram signal when a limiting safety system setpoint is reached or exceeded. Control rod insertion following a scram signal is designed to be passive (i.e., system de-energizes, control rod motive energy source is previously charged).

Assuming that shutdown (subcritical) conditions cannot be established/maintained, an automatic scram signal failure followed by a successful manual scram would still constitute a scram failure and should be classified under this event.

Although the reactor may be brought initially subcritical based on partial control rod insertion, there is a possibility that positive reactivity may be introduced by a number of factors. Xenon decay and factors associated with cooldown, lower fuel temperature (doppler), lower moderator temperature, and a lower presence of steam bubbles (voids) may all contribute to cause a power increase.

Subcritical conditions can be assured even with the most reactive control rod fully withdrawn from the core if the remaining 184 control rods fully insert. Any other control rod pattern resulting from partial control rod insertion must be carefully analyzed and/or monitored to detect the possibility of re-criticality or local criticality.

Due to the buildup of Xenon in areas of the core that have previously been operating at high power levels, attention should be applied to the possibility that control rods which previously had low worth (e.g., peripheral control rods) may now have significant control rod worth.

When the reactor is not shutdown as identified in the Transient Response Implementing Plan Procedures (TRIPs), then entry into this EAL is warranted. When partial control rod insertion occurs following a scram signal (either manual or automatic) judgement should be applied as to whether classification should occur. Multiple control rods failing to insert beyond notch position 02 may require actions to fully insert the control rods. However, the reactor has been made subcritical, and for all intent the reactor will remain subcritical. TRIP guidance will govern the insertion of these control rods.

This EAL would be escalated with a failure of both manual and automatic scram signals with the Reactor remaining critical.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SA2
T-101, RPV Control, RC-1

2.0 Reactor Pressure Vessel

2.2 Reactor Power

SITE AREA EMERGENCY - 2.2.3

IC Failure of Reactor Protection System Instrumentation to Complete or Initiate an Automatic Reactor Scram Once a Reactor Protection System Setpoint Has Been Exceeded and Manual Scram Was NOT Successful

EAL

RPS SCRAM should occur due to RPS Setpoint being exceeded

AND

Failure of Automatic RPS, ARI **AND** Manual SCRAM
to reduce reactor power < 4%

OPCON 1, 2

BASIS

This EAL is not applicable if a manual scram is initiated and no RPS setpoints are exceeded. Taking the mode switch to shutdown is considered a manual scram action. This may cause an RPS Setpoint to be exceeded due to the change in Nuclear Instrumentation Scram setpoint when the mode switch is placed in shutdown. If the RPS then fails to initiate a scram, then this should be evaluated as an automatic RPS setpoint being exceeded.

A valid automatic and/or manual scram signal is present as indicated by control room indications and/or alarms and APRM indication is greater than 4% power. The Reactor Protection System (RPS) is designed to function to shut down the reactor (either manually or automatically). The system is "fail safe," that is, it de-energizes to function. An Anticipated Transient Without Scram (ATWS) event can be caused either by a failure of RPS (electrical failure) or a failure of the Control Rod Drive system to permit the control rods to insert (hydraulic failure).

A failure of the Reactor Protection System to shut down the reactor (as indicated by reactor power remaining above 4%) is a degraded plant condition that together with suppression pool temperature approaching 110°F requires the injection of boron to shut down the reactor.

The RPV Control Trip Procedure establishes 4% power coincident with loss of scram capability as the initiating condition for various plant responses to ATWS events. With Reactor Power less than 4% the heat being generated in the core can be removed from the RPV and containment while actions are taken to bring the reactor subcritical.

A manual scram is defined as any set of actions by the reactor operator(s) at the reactor control console which causes control rods to be rapidly inserted into the core and brings the reactor subcritical (i.e., mode switch to shutdown, manual scram push buttons, or manual ARI initiation). Taking the mode switch to shutdown as part of the actions required by trip procedure is considered a manual scram action.

While the plant is being shutdown, significant heat is being generated in the core and the heat up rate of the Suppression Pool (due to heat rejection through SRVs) can increase which could approach the Suppression Pool temperature limit prior to shutting down. As the Suppression Pool heat increases towards the limiting temperature, the probability of causing a major over-pressure event increases substantially.

After an ATWS event, there is a potential that the Main Steam Isolation Valves (MSIV) will remain open. There is additional guidance in the Trip procedures to ensure that the MSIVs remain open even if RPV level is intentionally lowered to below the normal MSIV isolation level. This situation would allow the plant to remove heat and provide makeup through the normal steam/feed cycle. If this path is not available, or becomes unavailable during the transient, heat rejection will be to the Suppression Pool.

With Standby Liquid Control initiated and with partial or no control rod insertion, there is a possibility that the neutron flux profile in the reactor core may become uneven or distorted. Localized clad damage is possible, if localized power levels increase significantly.

With reactor power remaining above 4% containment integrity is threatened, as the ability of systems to remove all of the heat transferred to the containment may be exceeded. As the energy contained in the containment increases there may be a degradation in the ability to remove heat generated by the "at power" reactor core. There is therefore a potential loss of the containment or the fuel cladding (caused by overheating).

This event will be escalated based on Suppression Pool Temperature exceeding 180 degrees F.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SS2
T-101, RPV Control, RC/L-2
T-117, Level/Power Control

2.0 Reactor Pressure Vessel

2.2 Reactor Power

GENERAL EMERGENCY - 2.2.4

IC Failure of the Reactor Protection System to Complete an Automatic Scram and Manual Scram was NOT Successful and There is Indication of an Extreme Challenge to the Ability to Cool the Core

EAL

RPS SCRAM should occur due to RPS Setpoint being exceeded

AND

Failure of Automatic RPS, ARI AND Manual SCRAM
to reduce reactor power < 4%

AND

Suppression Pool Temperature is on the "UNSAFE" side of the Heat Capacity Temperature Limit (HCTL) curve (T-102, SP/T-1) OR RPV level < -186 "

OPCON 1, 2

BASIS

Taking the mode switch to shutdown is considered a manual scram action. This may cause an RPS Setpoint to be exceeded due to the change in Nuclear Instrumentation Scram setpoint when the mode switch is placed in shutdown. If the RPS then fails to initiate a scram, then this should be evaluated as an automatic RPS setpoint being exceeded.

When Suppression Pool level is outside of the Heat Capacity Temperature Limit Curve, High or Low, it is appropriate to consider operation to be on the "UNSAFE" side.

A valid automatic or manual scram signal is present as indicated by control room indications and/or alarms and APRM indication is greater than 4% power. In addition, control room instrumentation indicates that operation is on the "UNSAFE" side of the Heat Capacity Temperature Limit (HCTL) Curve (T-102, SP/T-1) or RPV level is < -186".

Failure of all automatic and manual trip functions coincident with a high Suppression Pool temperature will place the plant in a condition where reactivity control capability is jeopardized and heat removal capability is severely limited.

RPV level < -186 " indicates an extreme challenge to the ability to cool the core.

The RPV Control Trip Procedure establishes 4% power coincident with loss of scram capability as the initiating condition for various plant responses to ATWS events. The timely initiation of Standby Liquid Control (prior to Suppression Pool temperature reaching 110°F) would bring the reactor to < 4 % power before Suppression Pool temperature approaches the heat capacity temperature limit curve limitations.

Under ATWS conditions, it is important to assure continuous, stable steam condensation capability. An elevated Suppression Pool temperature on the "UNSAFE" side of the HCTL curve would result in unstable steam condensation should rapid reactor depressurization occur (ADS activation). Maintaining the ability to condense steam will preclude the pressurization of the containment and prevent possible containment failure.

Containment over-pressurization, which would be an eventual result of sustained operation with heat being added to the containment and high Suppression Pool temperature would result in the loss of containment integrity and the inability to remove the heat generated from the fuel. Fuel clad failure would result from the overheating of the fuel.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SG2.1, SG2.2
T-101, RPV Control
T-102, Primary Containment Control, SP/T-1
T-117, Level/Power Control, RC/L-2

3.0 Fission Product Barrier

3.1 Initiating Condition Matrix

Determine which combination of the three barriers (Fuel Clad, Reactor Coolant, Primary Containment) are lost or have a potential loss and use the following key to classify the event. Also, an event for multiple events could occur which result in the conclusion that exceeding the loss or potential loss thresholds is IMMINENT (i.e., within 1 to 2 hours). In this IMMINENT LOSS situation, use judgement and classify as if the thresholds are exceeded.

UNUSUAL EVENT

IC ANY Loss or ANY Potential Loss of Primary Containment

EAL

ANY Loss <u>OR</u> ANY Potential Loss of Primary Containment
--

ALERT

IC ANY Loss or ANY Potential Loss of EITHER Fuel Clad OR RCS

EAL

ANY Loss <u>OR</u> ANY Potential Loss of EITHER Fuel Clad <u>OR</u> RCS

SITE AREA EMERGENCY

IC Loss of BOTH Fuel Clad AND RCS
OR
Potential Loss of BOTH Fuel Clad AND RCS
OR
Potential Loss of EITHER Fuel Clad OR RCS, and Loss of ANY Additional Barrier

EAL

Loss of BOTH Fuel Clad <u>AND</u> RCS <u>OR</u> Potential Loss of BOTH Fuel Clad <u>AND</u> RCS <u>OR</u> Potential Loss of EITHER Fuel Clad <u>OR</u> RCS, <u>AND</u> Loss of ANY Additional Barrier

GENERAL EMERGENCY

IC Loss of ANY Two Barriers
 AND
 Potential Loss of Third Barrier

EAL

Loss of ANY Two Barriers <u>AND</u> Potential Loss of Third Barrier

OPCON 1, 2, 3

NOTES:

1. Although the logic used for these initiating conditions appears overly complex, it is necessary to reflect the following considerations:
 - The Fuel Clad barrier and the RCS barrier are weighted more heavily than the Primary Containment barrier. Unusual Event ICs associated with RCS and Fuel Clad barriers are addressed under the other plant condition EALs.
 - At the Site Area Emergency level, there must be some ability to dynamically assess how far present conditions are from General Emergency. For example, if the Fuel Clad barrier and RCS barrier "Loss" EALs existed, this would indicate to the Emergency Director that, in addition to offsite dose assessments, must focus on continual assessments of radioactive inventory and containment integrity. If, on the other hand, both Fuel Clad barrier and RCS barrier "Potential Loss" EALs existed, the Emergency Director would have more assurance that there was no immediate need to escalate to a General Emergency.
 - The ability to escalate to higher emergency classes as an event gets worse must be maintained. For example, RCS leakage steadily increasing would represent an increasing risk to public health and safety.
2. Fission Product Barrier ICs must be capable of addressing event dynamics. Thus, the EAL Reference Table states that IMMINENT (i.e., within 1 to 2 hours) Loss or Potential Loss should result in a classification as if the affected threshold(s) are already exceeded, particularly for the higher emergency classes.
3. The Fuel Clad barrier is the cladding tubes that contain the fuel pellets.
4. The RCS Barrier is the reactor coolant system pressure boundary and includes the reactor vessel and all reactor coolant system piping up to the isolation valves.
5. The Primary Containment Barrier includes the drywell, the wetwell, their respective interconnecting paths, and other connections up to and including the outermost containment isolation valves.

6. If a "Loss" condition is satisfied, the "Potential Loss" category can be considered satisfied. This is also applicable to conditions where this is a "Loss" indication with no corresponding "Potential Loss" condition.
7. For all conditions listed in Fission Product Barrier Table, the barrier failure column is only satisfied if it fails when called upon to mitigate an accident. For example, failure of both containment isolation valves to isolate with a downstream pathway to the environment is only a concern during an accident. If this condition exists during normal power operations, it will be an active Technical Specification Action Statement. However, during accident conditions, this will represent a breach of Primary Containment.

DEVIATION

None

REFERENCES

NUMARC NESP-007, Recognition Category F, Table 3

3.0 Fission Product Barrier

3.2 Fuel Clad Barrier

FC.1 Primary Coolant Activity Level

EAL

LOSS

Reactor Coolant activity > 300 $\mu\text{Ci/gm}$ Dose Equivalent Iodine 131

POTENTIAL LOSS

Not Applicable

OPCON 1, 2, 3

BASIS

A reactor coolant sample activity of greater than > 300 $\mu\text{Ci/gm}$ was determined to indicate significant clad heating and is indicative of the loss of the fuel clad barrier. This concentration is well above that expected for Iodine spikes and corresponds to 2.8% clad damage. 2.8% fuel clad damage is based upon NUREG-1228 core damage analysis.

Calculation of 300 $\mu\text{Ci/cc}$ equivalence to percent fuel clad damage is as follows (for purposes of this calculation, cc and gm are considered equivalent):

Iodine Isotope	Dose Factors		Ci/MWe Values (Time After Shutdown = 0)	
	(Reg Guide 1.109)		(NUREG-1228)	
I-131	4.39E-3		85000	
I-132	5.23E-5		120000	
I-133	1.04E-3		170000	
I-134	1.37E-5		190000	
I-135	2.14E-4		150000	

Time After Shutdown (T = 0) Ratios

$$R_{132} = 120000/85000(I-131) = 1.41(I-131)$$

$$R_{133} = 170000/85000(I-131) = 2.00(I-131)$$

$$R_{134} = 190000/85000(I-131) = 2.24(I-131)$$

$$R_{135} = 150000/85000(I-131) = 1.76(I-131)$$

Equation for Dose Equivalent Iodine (DEI_{131})

$$DEI_{131} = \frac{A_{131} DF_{131} + (R_{132}) A_{131} DF_{132} + (R_{133}) A_{131} DF_{133} + (R_{134}) A_{131} DF_{134} + (R_{135}) A_{131}}{DF_{131}}$$

Solve for A_{131} assuming $DEI_{131} = 300 \mu\text{Ci/cc}$

$$300 = \frac{A_{131} 4.39E-3 + 1.41 A_{131} 5.23E-5 + 2.00 A_{131} 1.04E-3 + 2.24 A_{131} 1.37E-5 + 1.76 A_{131} 2.14E-3}{4.39E-3}$$

$$300 = \frac{6.95E-3 A_{131}}{4.39E-3}$$

Therefore: $A_{131} = 189 \mu\text{Ci/cc I-131}$

Clad damage fraction (NUREG-1228, Table 4.1) = .02
Full Power = 1150 MWe

Clad Activity I-131 = (Ci/MWe) (MWe) (Clad Damage Fraction)
= (85000Ci/MWe) (1150MWe) (.02)
= 1.96E6 Ci

Reactor Water Volume = 2.93E8 cc (ERP-C-1410)

Total Coolant Activity I-131 = (A_{131}) (Rx Water Volume) (Ci/ μCi)
= (189 $\mu\text{Ci/cc}$) (2.93E8cc) (1.0E-6Ci/ μCi)
= 5.54E4Ci

Percent Clad Damage = Total Coolant Activity/Clad Activity I-131
= (5.54E4) / (1.96E6)
= 2.8%

This event will be escalated to an Site Area Emergency when additional fission product barriers are lost.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #1
NUREG 1228 - Source Term Estimation During Incident Response to Severe Nuclear Power Plant Accidents, Table 2.2
Reg. Guide 1.109, Table E-9
ERP-C-1410

3.0 Fission Product Barrier

3.2 Fuel Clad Barrier

FC.2 Reactor Vessel Water Level

EAL

LOSS

RPV level < **-186 "**

POTENTIAL LOSS

RPV level < **-161 "**

OPCON 1, 2, 3

BASIS

The "Loss" EAL **-186 "** value corresponds to the level which is used in the TRIPS to indicate challenge of core cooling. This is the minimum value to assure core cooling without further degradation of the clad. The "Potential Loss" EAL is the same as the RCS barrier "Loss" EAL 4 and corresponds to the fuel zone water level at the top of the active fuel. Thus, this EAL indicates a "Loss" of RCS barrier and a "Potential Loss" of the Fuel Clad Barrier. This EAL appropriately escalates the emergency class to a Site Area Emergency.

Core submergence is the preferred method of core cooling and as such, the failure to re-establish RPV water level above the top of active fuel for an extended period of time could lead to significant fuel damage. This condition, -186 ", could be indicative of a large break Loss Of Coolant Accident (LOCA) (where ECCS Systems are designed to maintain level at 2/3 core height) or a small LOCA with the inability of emergency core cooling systems to reflood the RPV.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #2 , RC EAL #4
T-101, RPV Control
T-111, Level Restoration/Steam Cooling, LR-11
T-112, Rapid Depressurization
T-117, Level/Power Control
T-116, RPV Flooding

3.0 Fission Product Barrier

3.2 Fuel Clad Barrier

FC.3 Drywell Radiation Monitoring

EAL

LOSS

Drywell Rad Monitor reading $> 4 \times 10^4$ R/hr

POTENTIAL LOSS

Not Applicable

OPCON 1, 2, 3

BASIS

The 4×10^4 R/hr reading on a containment high range radiation monitor RR-26-191.291A, B, C, D, indicates the release of reactor coolant, with elevated activity indicative of fuel damage, into the drywell. The reading was calculated assuming an instantaneous release and dispersal of the Reactor Coolant noble gas and iodine inventory into the Primary Containment (direct reading not shine) at a coolant concentration of 300 $\mu\text{Ci/gm}$ Dose Equivalent Iodine 131. This calculation is as follows:

Using Curve 3 [1%] of ERP-C-1410

Time after Shutdown = 1 hour (more conservative due to lower value for EAL)

1% fuel clad damage
the dose rate = 15,000 R/hr

Extrapolating to 2.8%
 $(15,000 \text{ R/hr}/1\%)(2.8) = 42,000 \text{ R/hr}$

This is rounded conservatively to 40,000 R/hr for human factors considerations

2.8% clad damage is based upon NUREG-1228 core damage analysis, and by virtue of its release into containment, the loss of the Reactor Coolant barrier (detailed calculations are contained in the Basis for Fission Product Barrier EAL FC #1).

Reactor coolant concentrations of this magnitude are several times larger than the maximum concentrations (including iodine spiking) allowed within technical specifications and are therefore indicative of fuel damage. This value is higher than that specified for RCS barrier Loss EAL #3. Thus, this EAL indicates a loss of both Fuel Clad barrier and RCS barrier.

There is no "Potential Loss" EAL associated with this item.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #3 and RC EAL #3

NUREG 1228 - Source Term Estimation During Incident Response to Nuclear Power Plant
Accidents

ERP-C-1410

3.0 Fission Product Barrier

3.2 Fuel Clad Barrier

FC.4 Other Indications

EAL

<u>LOSS</u> Not Applicable <u>POTENTIAL LOSS</u> Not Applicable
--

OPCON 1, 2, 3

BASIS

There are no other indications at LGS for loss of the Fuel Clad Barrier.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #4 and RC EAL #5

3.0 Fission Product Barrier

3.2 Fuel Clad Barrier

FC.5 Emergency Director Judgement

EAL

Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the FUEL CLAD barrier

OPCON 1, 2, 3

BASIS

This EAL addresses any other factors that are to be used by the Emergency Director in determining whether the Fuel Clad barrier is lost or potentially lost. In addition, the inability to monitor the barrier should also be incorporated in this EAL, as a factor in Emergency Director judgement, that the barrier may be considered lost or potentially lost. (See also IC, "Prolonged Loss of All Offsite Power and Prolonged Loss of All Onsite AC Power", for additional information.)

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #5

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.1 RCS Leak Rate

EAL

LOSS

Not Applicable

POTENTIAL LOSS

RCS leakage **>50 gpm**

OR

Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating **Temperature** is exceeded in ONE area requiring a SCRAM

OR

Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe **Radiation** is exceeded in ONE area requiring a SCRAM

OPCON 1, 2, 3

BASIS

UNISOLABLE - A leak that cannot be isolated from the Control Room.

When evaluating this EAL for unisolable primary system leakage, it is appropriate to attempt isolation from the Control Room prior to classification.

The potential loss of RCS based on leakage is set at a level indicative of a small breach of the RCS but which is well within the makeup capability of normal and emergency high pressure systems. Core uncover is not a significant concern for a 50 gpm leak, however, a break propagation leading to a significantly larger loss of inventory is possible. RCS leakage is measured by the normal primary system leakage monitoring system and is leakage into the drywell. Under certain conditions, this system may be isolated due to increased drywell pressure caused by the leak. In that case, a "loss" of RCS will be indicated and this "potential loss" of RCS would not impact the classification.

Inventory loss events, such as a stuck open SRV, should not be considered when referring to "RCS leakage" because they are not indications of a break which could propagate.

Potential loss of RCS based on primary system leakage outside the drywell is determined from T-103 area temperatures or radiation levels. TRIP guidance stipulates that when the Temperature or Radiation Action Level limits have been exceeded for one area, that the reactor be manually scrammed.

There are two ways that the temperatures in the Secondary Containment can reach these levels; i.e., primary leak into secondary and a fire within the secondary containment. As the temperatures rise above normal conditions, the plant staff will isolate the containment and all systems, except those required for shutdown and cooling, at the Temperature Action Levels Isolation levels. If the temperatures continue to rise to the Temperature Action Levels it is indicative that an unisolable leak has occurred. If the radiation levels rise above the Radiation Action Levels, it also indicates that an unisolable leak has occurred.

This event signifies that there is a direct path established for the transfer of main steam to inside the Turbine Building. Assumptions made in dose calculations regarding radioactive material transport (e.g., hold up, plate out, scrubbing, and retention) may be invalid. Additionally the transport time associated with a radiological release may be significantly shortened and there may be a higher percentage of short lived radioisotopes in any release. As both the reactor coolant pressure boundary and the primary containment are degraded; the extent of radioactive release is dependent on fuel clad integrity. Should a rapid reactor depressurization occur as a result of this event then there is a potential that a large amount of radioiodine may be released.

DEVIATION

None

REFERENCES

NUMARC NESP-007, RC EAL #1 PC EAL #2
T-103 Secondary Containment Control

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.2 Drywell Pressure

EAL

LOSS

Drywell Pressure > **1.68 psig**

AND

Indication of a leak inside drywell

POTENTIAL LOSS

Not Applicable

OPCON 1, 2, 3

BASIS

The **1.68 psig** drywell pressure is based on the drywell high pressure alarm set point and indicates a LOCA.

If drywell pressure exceeds 1.68 psig, there is a clear indication that a leak of sufficient magnitude exists that prevents drywell pressure stabilization.

DEVIATION

The NUMARC EAL contains only the drywell pressure. A qualifying:

"AND

Indication of a leak inside drywell"

was added as a human factor reminder to the Emergency Director that use of this EAL is for accident scenarios only. Thus, a Drywell pressure increase due to the loss of Drywell cooling will not require an emergency classification.

REFERENCES

NUMARC NESP-007, RC EAL #2

T-101, RPV Control

T-102, Primary Containment Control

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.3 Drywell Radiation Monitoring

EAL

LOSS

Drywell Rad Monitor reading > **15 R/hr**

POTENTIAL LOSS

Not Applicable

OPCON 1, 2, 3

BASIS

The **15 R/hr** reading is a value which indicates the release of reactor coolant to the drywell. The value assumes an instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory associated with concentrations corresponding to 0.001% Total Isotopic Distribution (TID) into the drywell atmosphere.

Using attachment 5 of ERP-C-1410, Curve 6

Time after Shutdown = 0.1 hour

0.001% TID = 13 R/hr

This is rounded to 15 R/hr for human factors considerations

This reading is less than that specified for Fuel Clad Barrier EAL #3. Thus, this EAL would be indicative of a RCS leak only. If the radiation monitor reading increases to that value specified by Fuel Clad Barrier EAL #3, fuel damage would also be indicated.

There is no "Potential Loss" EAL associated with this item.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #3 and RC EAL #3

NUREG 1228 - Source Term Estimation During Incident Response to Nuclear Power Plant Accidents

ERP-C-1410, Attachment 5

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.4 Reactor Vessel Water Level

EAL

LOSS
RPV level < **-161 "**

POTENTIAL LOSS
Not Applicable

OPCON 1, 2, 3

BASIS

This "Loss" EAL is the same as "Potential Loss" Fuel Clad Barrier EAL #2. The **-161 "** water level corresponds to the level which is used in TRIPS to indicate challenge of core cooling. This EAL appropriately escalates the emergency class to a Site Area Emergency. Thus, this EAL indicates a loss of the RCS barrier and a Potential Loss of the Fuel Clad Barrier.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #2 , RC EAL #4
T-101, RPV Control
T-111, Level Restoration/Steam Cooling, LR-11
T-112, Rapid Depressurization
T-117, Level/Power Control
T-116, RPV Flooding

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.5 Other Indications

EAL

LOSS

Not Applicable

POTENTIAL LOSS

RPV level cannot be determined

OPCON 1, 2, 3

BASIS

Inability to determine Reactor Pressure Vessel level may be due to reference leg boil-off, instrument power failure, or conflicting information on uncontrolled parameter oscillations. TRIP procedure guidance will require the flooding of the Reactor Pressure Vessel, thus ensuring core submergence. Based on differences in calibration and design, all ranges of level instruments may not indicate exactly the same; this operational difference is expected and is not to be used for deciding that conflicting RPV level indication exists. Multiple indications of level instruments pegged high is indication that the level is above the range and that it is known, also visual observation during refueling is indication of RPV water level.

If indeterminate RPV level is due to reference leg boil-off, it is an indicator of a potential loss of the Reactor Coolant System. Adequate core cooling would be rapidly assured using the guidance provided in the TRIP Procedures. If it can be determined that the cause is due to an instrument power or instrumentation failure, then it is not appropriate to classify the event as a potential loss of the Reactor Coolant System.

Operator attention should be given to the possibility that under depressurized conditions, there is the possibility that gases may come out of solution and result in distorted RPV level indications. Operators should be attentive to observe multiple level indications (particularly those which utilize separate reference legs) to ensure that actual RPV level is known and displayed. Unexplained and/or sudden changes in specific level indications may be a result of degassification of the coolant contained in the level instrumentation.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #4 and RC EAL #5
T-101, RPV Control, RC/L-1
T-112, Rapid Depressurization
T-117, Level/Power Control
T-116, RPV Flooding

3.0 Fission Product Barrier

3.3 Reactor Coolant System Barrier

RC.6 Emergency Director Judgement

EAL

Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the RCS barrier

OPCON 1, 2, 3

BASIS

This EAL addresses any other factors that are to be used by the Emergency Director in determining whether the RCS barrier is lost or potentially lost. In addition, the inability to monitor the barrier should also be incorporated in this EAL as a factor in Emergency Director judgement that the barrier may be considered lost or potentially lost. (See also IC, "Prolonged Loss of All Offsite Power and Prolonged Loss of All Onsite AC Power", for additional information.)

DEVIATION

None

REFERENCES

NUMARC NESP-007, RCS EAL #6

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.1 Drywell Pressure

EAL

LOSS

Rapid, unexplained decrease in Drywell Pressure following initial increase

OR

Drywell pressure response not consistent with LOCA conditions

POTENTIAL LOSS

Drywell Pressure > **44 psig** and increasing

OR

Drywell Hydrogen > **6%** AND Drywell Oxygen > **5%**

OPCON 1, 2, 3

BASIS

Rapid unexplained loss of pressure (i.e., not attributable to drywell spray or condensation effects) following an initial pressure increase indicates a loss of Primary Containment integrity. Drywell pressure should increase as a result of mass and energy release into containment from a LOCA. Thus, drywell pressure not increasing under these conditions indicates a loss of containment integrity. The **44 psig** for potential loss of Primary Containment is based on the containment drywell design pressure and is equal to the peak pressure expected from a DBA LOCA.

The specified value of 6% hydrogen concentration is the minimum which can support a deflagration. Likewise, the minimum concentration of oxygen required to support a deflagration is 5%. Combustion of hydrogen in the deflagration concentration range creates a traveling flame causing a rapid rise in primary containment pressure. A deflagration may result in a peak primary containment pressure high enough to rupture the primary containment or damage the drywell-to-suppression pool boundary.

DEVIATION

None

REFERENCES

NUMARC NESP-007, PC EAL #1
T-101, RPV Control
T-102, Primary Containment Control w/Bases
T-103, Secondary Containment Control

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.2 Containment Isolation Valve After Containment Isolation

EAL

LOSS

Failure of both valves in any one line to close AND downstream pathway to the environment exists

OR

Intentional venting per T-200 OR T-228 is required

OR

Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating **Temperature** is exceeded in ONE area requiring a SCRAM

OR

Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating **Radiation** is exceeded in ONE area requiring a SCRAM

POTENTIAL LOSS

Not Applicable

OPCON 1, 2, 3

BASIS

UNISOLABLE - A leak that cannot be isolated from the Control Room.

When evaluating this EAL for unisolable primary system leakage, it is appropriate to attempt isolation from the Control Room prior to classification.

This EAL is intended to cover containment isolation failures allowing a direct flow path to the environment such as failure of both MSIVs to close with open valves downstream to the turbine or to the condenser. In addition, the presence of area radiation or temperature alarms indicating unisolable primary system leakage outside the drywell are covered. Also, an intentional venting of primary containment per TRIPS to the secondary containment and/or the environment is considered a loss of containment.

Loss of containment based on primary system leakage outside the drywell is determined from T-103 area temperatures or radiation levels. TRIP guidance stipulates that when the Temperature or Radiation Action Level limits have been exceeded for one area, that the reactor be manually SCRAMmed.

There are two ways that the temperatures in the Secondary Containment can reach these levels; i.e., primary leak into secondary and a fire within the secondary containment. As the temperatures rise above normal conditions, the plant staff will isolate the containment and all systems, except those required for shutdown and cooling, at the Temperature Action Level Isolation levels. If the temperatures continue to rise to the Temperature Action Levels it is

indicative that an unisolable leak has occurred. If the radiation levels rise above the Radiation Action Levels, it also indicates that an unisolable leak has occurred.

DEVIATION

None

REFERENCES

NUMARC NESP-007, RCS EAL #1, PC EAL #2

T-103 Secondary Containment Control

T-104, Radioactivity Release Control

T-200, Primary Containment Emergency Vent Procedure

T-228, Inerting/Purging Primary Containment

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.3 Significant Radioactive Inventory in Containment

EAL

LOSS

Not Applicable

POTENTIAL LOSS

Drywell Rad Monitor reading $> 3 \times 10^5$ R/hr

OPCON 1, 2, 3

BASIS

A containment high range radiation monitor RR-26-191/291A, B, C, D reading 3×10^5 R/hr indicates significant fuel damage, well in excess of that required for the loss of the RCS and Fuel Clad. As stated in Section 3.8 of NUMARC/NESP-007, a major release of radioactivity requiring offsite protective actions from core damage is not possible unless a major failure of fuel cladding allows radioactive material to be released from the core into the reactor coolant. Regardless of whether containment is challenged, this amount of activity in containment, if released, could have such severe consequences that it is prudent to treat this as a potential loss of containment, such that a General Emergency declaration is warranted. NUREG-1228, "Source Estimations During Incident Response to Severe Nuclear Power Plant Accidents," indicates that such conditions do not exist when the amount of clad damage is less than 20%.

The reading was calculated assuming an instantaneous release of the Reactor Coolant volume into the Primary Containment (direct reading not shine) where the value corresponds to a release of approximately 20% of the gap region. This calculation is as follows:

Using Curve 3 [1%] of ERP-C-1410

Time after Shutdown = 1 hour (more conservative due to lower value for EAL)

1% fuel clad damage
the dose rate = 15,000 R/hr

Extrapolating to 20%
 $(15,000 \text{ R/hr}/1\%)(20) = 300,000 \text{ R/hr}$

There is no "Loss" EAL associated with this item.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #3, RC EAL #3 and PC EAL #3
NUREG 1228 - Source Term Estimation During Incident Response to Severe Nuclear Power
Plant Accidents
ERP-C-1410

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.4 Reactor Vessel Water Level

EAL

LOSS

Not Applicable

POTENTIAL LOSS

RPV level cannot be restored above **-186 "** within the time limit of the "SAFE" region of the Maximum Core Uncovery Time Limit Curve (T-116, RF-1)

OPCON 1, 2, 3

BASIS

In this EAL, the **-186 "** water level corresponds to the level which is used in the TRIPS to indicate challenge of core cooling. This is the minimum value to assure core cooling without further degradation of the clad.

When evaluating this EAL for a time after shutdown of less than 90 minutes, it is appropriate to use the value of the Maximum Core Uncovery Time Limit Curve at 90 minutes after shutdown.

The conditions in this potential loss EAL represent imminent melt sequences which, if not corrected, could lead to vessel failure and increased potential for containment failure. In conjunction with the level EALs in the Fuel and RCS barrier columns, this EAL will result in the declaration of a General Emergency on loss of two barriers and the potential loss of a third. If the TRIPS have been ineffective in restoring reactor vessel level within the maximum core uncovery time limit, there is not a "success" path.

Severe accident analysis (e.g., NUREG-1150) have concluded that function restoration procedures can arrest core degradation with the reactor vessel in a significant fraction of the core damage scenarios, and the likelihood of containment failure is very small in these events. Given this, it is appropriate to provide a reasonable period to allow TRIPS to arrest the core melt sequence. Whether or not the procedures will be effective should be apparent within the time provided by the maximum core uncovery time limit. The Emergency Director should make the declaration as soon as it is determined that the procedures have been, or will be, ineffective.

There is no "Loss" EAL associated with this item.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #2 , RC EAL #4
T-101, RPV Control
T-111, Level Restoration/Steam Cooling, LR-11
T-112, Rapid Depressurization
T-117, Level/Power Control
T-116, RPV Flooding

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.5 Other Indications

EAL

LOSS

Not Applicable

POTENTIAL LOSS

RPV level cannot be determined

AND

RPV Flooding cannot be established as indicated by inability to maintain 5 ADS/SRVs open with RPV pressure at least 50 psig above Suppression Pool pressure per T-116

OPCON 1, 2, 3

BASIS

The decision to enter RPV Flooding is made when RPV water level cannot be determined. This judgement consists of evaluating all plant indications which can influence the ability to maintain adequate core cooling. Entry to RPV flooding requires rapid RPV depressurization. The minimum RPV Flooding Pressure is defined as the lowest differential pressure between the RPV and the Suppression Pool at which steam flow through the SRVs will be sufficient to remove all of the generated decay heat. Operation at the minimum reactor flooding pressure requires that a sufficient amount of water reach the core to carry away decay heat by boiling, which in turn requires that RPV water level increase. So RPV flooding not established requires containment flooding. This represents a potential loss of containment due to the potential need to vent containment in order to facilitate flooding. Additionally, it represents a potential inability to remove decay heat which may also lead to containment failure.

Inability to determine Reactor Pressure Vessel level may be due to reference leg boil-off, instrument power failure, or conflicting information on uncontrolled indication oscillations. TRIP procedure guidance will require the flooding of the Reactor Pressure Vessel, thus ensuring core submergence. Based on differences in calibration and design, all ranges of level instruments may not indicate exactly the same; this operational difference is expected and is not to be used for deciding that conflicting RPV level indication exists. Level indication pegged high is indication that the level is above the range and that it is known, also visual observation during refueling is indication of RPV water level.

If it can be determined that the loss of ability to monitor RPV level is due to an instrument power or instrumentation failure, then it is not appropriate to classify the event as a potential loss of the Primary Containment.

The minimum RPV flooding pressure will ensure that adequate core cooling exists independent of RPV level indication. Failure to establish the differential pressure between the RPV and the Suppression Pool in a timely manor can jeopardize the ability of the reactor coolant system to dissipate the decay heat generated.

Ample time must be allotted for determining the failure of ECCS systems to pressurize the RPV. Control Room indications such as RPV level (used for trending), RPV Pressure, ECCS injection flow rates, Containment parameters, and injection system operability should all be used to gauge the effectiveness of the RPV Flood.

If the loss of level indication was caused by reference leg flashing, then level indicators can still be utilized to monitor the trend in RPV level. Actual RPV level will never be higher than indicated level.

In the event that the loss of level indication is only a result of degassification of the coolant contained in the level instrumentation piping, then it is anticipated that flooding pressure can be obtained.

RPV water level below the top of active fuel for a sustained period of time represents an early indicator that significant core damage is in progress while providing sufficient time to initiate public protective actions. For events starting from power operation, some core melting can be expected. Even under these conditions vessel failure and containment failure with resultant release to the public would not be expected for some time.

DEVIATION

None

REFERENCES

NUMARC NESP-007, FC EAL #4 , RCS EAL #5 and PC EAL #5
T-101, RPV Control
T-111, Level Restoration/Steam Cooling, LR-11
T-112, Rapid Depressurization
T-117, Level/Power Control
T-116, RPV Flooding

3.0 Fission Product Barrier

3.4 Primary Containment Barrier

PC.6 Emergency Director Judgement

EAL

Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the Primary Containment barrier

OPCON 1, 2, 3

BASIS

This EAL addresses any other factors that are to be used by the Emergency Director in determining whether the Containment Barrier is lost or potentially lost. In addition, the inability to monitor the barrier should also be incorporated in this EAL as a factor in Emergency Director judgement that the barrier may be considered lost or potentially lost. (See also IC, "Prolonged Loss of All Offsite Power and Prolonged Loss of All Onsite AC Power", for additional information.)

DEVIATION

None

REFERENCES

NUMARC NESP-007, PC EAL #6

This Page Intentionally Left Blank

3.2 Fission Product Barrier Status Table

ERP-101 BASES, Rev. 2
Page 57 of 126
RDM/aa

Barrier Parameter	Fuel Clad		Reactor Coolant System		Primary Containment	
	Loss	Potential Loss	Loss	Potential Loss	Loss	Potential Loss
Reactor Coolant Activity	Reactor Coolant activity > 300 $\mu\text{Ci/gm}$ Dose Equivalent Iodine 131	N/A	N/A	N/A	N/A	N/A
RPV Level	RPV level < -186 "	RPV level < -161 "	RPV level < -161 "	N/A	N/A	RPV level cannot be restored above -186 " within the time limit of the "SAFE" region of the Maximum Core Uncovery Time Limit Curve (T-116, RF-1)
RPV Level Unknown	N/A	N/A	N/A	RPV level cannot be determined	N/A	RPV level cannot be determined AND RPV Flooding cannot be established as indicated by inability to maintain 5 ADS/SRVs open with RPV pressure at least 50 psig above Suppression Pool pressure per T-116
RCS Leak Rate	N/A	N/A	N/A	RCS leakage > 50 gpm	N/A	N/A
Drywell Pressure	N/A	N/A	Drywell Pressure > 1.68 psig AND Indication of a leak inside drywell	N/A	Rapid, unexplained decrease in Drywell Pressure following initial increase OR Drywell pressure response not consistent with LOCA conditions	Drywell Pressure > 44 psig and increasing OR Drywell Hydrogen > 6% AND Drywell Oxygen > 5%
Drywell Radiation	Drywell Rad Monitor reading > 4×10^4 R/hr	N/A	Drywell Rad Monitor reading > 15 R/hr	N/A	N/A	Drywell Rad Monitor reading > 3×10^5 R/hr ***PAR*** Evacuate 5 mile radius, evacuate affected sector(s) and 2 adjacent sectors for 5-10 miles.

3.2 Fission Product Barrier Status Table

ERP-101 BASES, Rev. 2
Page 58 of 126
RDM/aa

Parameter	Barrier	Fuel Clad		Reactor Coolant System		Primary Containment	
		Loss	Potential Loss	Loss	Potential Loss	Loss	Potential Loss
Containment Isolation	N/A			N/A	Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating Temperature is exceeded in ONE area requiring a SCRAM <u>OR</u> Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating Radiation is exceeded in ONE area requiring a SCRAM	Failure of both valves in any one line to close AND downstream pathway to the environment exists <u>OR</u> Intentional venting per T-200 <u>OR</u> T-228 is required <u>OR</u> Unisolable primary system leakage outside drywell as indicated by T-103, Max Safe Operating Temperature is exceeded in ONE area requiring a SCRAM <u>OR</u> Unisolable primary system leakage outside drywell as indicated by a T-103, Max Safe Operating Radiation is exceeded in ONE area requiring a SCRAM	N/A
Emergency Director Judgement		Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the FUEL CLAD barrier		Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the RCS barrier		Any condition in the judgement of the Emergency Director that indicates Loss or Potential Loss of the Primary Containment barrier	

In the table below, circle all of the appropriate X's in each applicable row for each Loss or Potential Loss of Fission Product Barrier as determined by the table above.

Classify the event as identified in the table heading if all X's in a column under that heading are circled.

Fission Product Barrier Status	Unusual Event		ALERT				SITE AREA EMERGENCY								GENERAL EMERGENCY			
Fuel Clad - Loss			X				X		X		X				X	X		X
Fuel Clad - Potential Loss				X				X		X		X					X	
Reactor Coolant System - Loss					X		X		X			X			X	X	X	
Reactor Coolant System-Potential Loss						X		X	X				X					X
Primary Containment - Loss	X										X	X	X	X	X		X	X
Primary Containment - Potential Loss		X														X		

****PAR****

Evacuate 2 mile radius, evacuate affected sector(s) and 2 adjacent sectors for 2-5 miles. (Upgrade PAR for D/W Rad > 3×10^5 R/hr)

4.0 Secondary Containment Bypass

4.1 Main Steam Line

UNUSUAL EVENT - 4.1.1

IC Fuel Clad Degradation

EAL

Main Steam Line HiHi Radiation (3xNFPB)

OPCON 1, 2, 3

BASIS

Main Steam Line High-High Radiation alarm (RE-41/42N6A,B,C,D) > 3 times normal full power background may be indicative of minor fuel cladding degradation and warrants the declaration of an Unusual Event. This level is set to preclude most spurious events including resin intrusion.

The main steam line high-high radiation condition requires a manual Main Steam Isolation Valve closure and a reactor scram. This transient may result in the introduction of fission product gases (previously contained in the gap area) to be suddenly released into the coolant due to the rapid down power transient and subsequent collapse of voids in the coolant.

This level of steam line activity is indicative of the release of gap activity to the coolant however, this level is not indication of a major failure of the fuel clad. The mechanics that caused main steam line radiation to increase to this level indicate there is a degradation of fuel clad integrity.

This event will escalate to an Alert based on the breach in the main steam line together with a failure of the MSIVs to isolate the main steam lines per Fission Product Barrier Table.

DEVIATION

The OPCON applicability [1,2,3] is a deviation from NUMARC [all] in that, the SJAE Radiation Monitor and Main Steam Line Radiation Monitors will only be a valid indication of Fuel Clad Degradation in those OPCON's. At Limerick, there are no other monitors which can be an indicator of Fuel Clad Degradation. Degradation in cold shutdown or refueling will be first indicated by ventilation release monitors and covered in Effluent Release section.

REFERENCES

NUMARC NESP-007, SU4.1
T-100, Scram/ Scram Recovery
T-101, RPV Control

4.0 Secondary Containment Bypass

4.1 Main Steam Line

ALERT - 4.1.2

IC RCS Leak Rate

EAL

Indication of a Main Steam Line Break:

Hi Steam Flow Annunciator AND Hi Steam Tunnel Temperature Annunciator

OR

Direct report of steam release

OPCON 1, 2, 3

BASIS

When evaluating this EAL "Direct report of steam release" is considered a leak of magnitude and location that is indicative of a Main Steam Line Break.

Design basis accident analyses of a Main Steam Line Break outside of secondary containment shows that even if MSIV closure occurs within design limits, dose consequences offsite from a "puff" release would be in excess of 10 millirem.

Hi Steam Flow Annunciator and Hi Steam Tunnel Temperature Annunciator are both indicators of a Main Steam Line Break. Both parameters will cause an isolation of the MSIV's. Should both valves in any one line fail to isolate, this event would be considered a loss of Primary Containment and a potential loss of the RCS per the Fission Product Barrier Table and appropriately classified as a Site Area Emergency.

DEVIATION

None

REFERENCES

NUMARC NESP-007, RC.1

T-101, RPV Control

NUMARC Questions and Answers, June 1993, "Fission Product Barriers #7"

5.0 Radioactivity Release

5.1 Effluent Release and Dose

UNUSUAL EVENT - 5.1.1.a

IC Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment that Exceeds Two Times the Radiological Technical Specifications for 60 Minutes or Longer

EAL

A valid reading on one or more of the following radiation monitors that exceeds **TWO TIMES** the HiHi alarm setpoint value for **> 60 minutes**:

North Stack, South Stack, Radwaste Discharge, Service Water, RHRSW

AND

Calculated maximum offsite dose rate using computer dose model exceeds **0.114 mRem/hr TPARD OR 0.342 mRem/hr child thyroid CDE** based on a 60 minute average

Note: If the required dose projections cannot be completed within the 60 minute period, then the declaration must be made based on the valid sustained monitor reading.

OPCON ALL

BASIS

The term "Unplanned", as used in this context, includes any release for which a radioactive discharge permit was not prepared, or a release that exceeds the conditions (e.g., minimum dilution flow, maximum discharge flow, alarm setpoints, etc.) on the applicable permit.

Unplanned releases in excess of 0.114 mRem/hr TPARD or 0.342 mRem/hr CDE that continue for > 60 minutes represent an uncontrolled situation and hence a potential degradation in the level of safety. The final integrated dose is very low and is not the primary concern. Rather it is the degradation in plant control implied by the fact that the release was not isolated within 60 minutes.

It is not intended that the release be averaged over 60 minutes, but exceed 0.114 mRem/hr TPARD or 0.342 mRem/hr CDE limits for 60 minutes. This EAL includes a 60 minute average for the dose projection with the release point radiation monitor above two times the HiHi alarm set point value for the entire 60 minutes. Also, it is intended that the event be declared as soon as it is determined that the release will exceed 0.114 mRem/hr TPARD or 0.342 mRem/hr CDE for greater than 60 minutes.

An indication or report is considered to be valid when it is verified by:

1. An instrument channel check
2. Indications on related or redundant instruments
3. By direct observation by plant personnel

Monitor indications are calculated based on the methodology of the site Offsite Dose Calculation Manual (ODCM). The HiHi alarm setpoints are set conservatively to indicate when a potential release may approach Technical Specification (ODCM) limits assuming multiple

release points. Use of this conservative setpoint in establishing a monitor reading will not cause an inappropriate event classification since this EAL requires the magnitude of the monitor reading to be two times the setpoint, sustained for >60 minutes, and assessment by a dose projection indicating an offsite dose rate in excess of two times Technical Specification (ODCM) limits. In the unlikely event that a dose projection cannot be completed within the 60 minute period, the event will be declared based on the sustained monitor reading.

Total Protective Action Recommendation Dose (TPARD) is equal to Total Effective Dose Equivalent (TEDE) + 4 Day Deposition Dose. Committed Dose Equivalent (CDE) is equal to the thyroid exposure due to iodine. The computerized dose model provides projected TPARD and CDE.

The Total Protective Action Recommendation Dose (TPARD) is calculated by dividing the yearly allowable Technical Specification limit (500 mRem/yr.) by the number of hours per year (8760 hr/yr.), and then multiplying by a factor of 2 times Technical Specifications [ODCM].

$$\begin{aligned}\text{TPARD} &= 2 \times (\text{Tech Spec Limit}) / (\text{hours per year}) \\ &= 2(500 \text{ mRem/yr.}) / (8760 \text{ hr/yr.}) \\ &= 0.114 \text{ mRem/hr}\end{aligned}$$

The Committed Dose Equivalent (CDE) is calculated by dividing the yearly allowable Technical Specification limit (1500 mRem/yr.) by the number of hours per year (8760 hr/yr.), and then multiplying by a factor of 2 times Technical Specifications [ODCM].

$$\begin{aligned}\text{CDE} &= 2 \times (\text{Tech Spec Limit}) / (\text{hours per year}) \\ &= 2(1500 \text{ mRem/yr.}) / (8760 \text{ hr/yr.}) \\ &= 0.342 \text{ mRem/hr}\end{aligned}$$

This event will be escalated to an Alert when effluents increase.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AU1.1

Offsite Dose Calculation Manual

NUMARC Questions and Answers, June 1993, "Abnormal Rad Levels/Radiological Effluents #9"

5.0 Radioactivity Release

5.1 Effluent Release and Dose

UNUSUAL EVENT - 5.1.1.b

IC Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment that Exceeds Two Times Radiological Technical Specifications for 60 Minutes or Longer

EAL

Confirmed sample analyses for gaseous or liquid releases indicates concentrations or release rates exceeding **TWO TIMES** Tech Specs (ODCM 3.2.2 and 3.2.3) for **> 60 minutes**

OPCON ALL

BASIS

Releases in excess of two times technical specifications that continue for > 60 minutes represent an uncontrolled situation and hence a potential degradation in the level of safety. The final integrated dose is very low and is not the primary concern. Rather it is the degradation in plant control implied by the fact that the release was not isolated within 60 minutes.

It is not intended that the release be averaged over 60 minutes, but exceed two times technical specifications limits for 60 minutes. Further, it is intended that the event be declared as soon as it is determined that the release will exceed two times technical specifications for greater than 60 minutes.

An indication or report is considered to be valid when it is verified by:

1. An instrument channel check
2. Indications on related or redundant instruments
3. By direct observation by plant personnel

The calculation called for in this EAL should also be conducted whenever a liquid release occurs for which a radioactive discharge permit wasn't prepared or that exceeds the conditions on the permit (e.g. minimum dilution, alarm setpoints, etc).

This event will be escalated to an Alert when effluents increase.

DEVIATION

None

REFERENCES

NUMARC NESP-007 AU1.2
Offsite Dose Calculation Manual
T-104, Radioactivity Release Control

5.0 Radioactivity Release

5.1 Effluent Release and Dose

ALERT - 5.1.2.a

IC Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment that Exceeds 200 Times Radiological Technical Specifications for 15 Minutes or Longer

EAL

A valid reading on one or more of the following radiation monitors that exceeds **TWO HUNDRED TIMES** the HiHi alarm setpoint value for **> 15 minutes**:

North Stack, South Stack, Radwaste Discharge, Service Water, RHRSW

AND

Calculated maximum offsite dose rate exceeds **11.4 mRem/hr TPARD OR 34.2 mRem/hr child thyroid CDE** based on a 15 minute average

Note: If the required dose projections cannot be completed within the 15 minute period, then the declaration must be made based on the valid sustained monitor reading.

OPCON ALL

BASIS

Releases in excess of 11.4 mRem/hr TPARD or 34.2 mRem/hr CDE that continue for > 15 minutes represent an uncontrolled situation and hence a potential degradation in the level of safety. The primary concern is the final integrated dose [100 times greater than the Unusual Event] and the degradation in plant control implied by the fact that the release was not isolated within 15 minutes.

This EAL includes a 15 minute average for the dose projection with the release point radiation monitor above two hundred times the HiHi alarm set point value for the entire 15 minutes. Also, it is intended that the event be declared as soon as it is determined that the release will exceed 11.4 mRem/hr TPARD or 34.2 mRem/hr CDE for greater than 15 minutes.

An indication or report is considered to be valid when it is verified by:

1. An instrument channel check
2. Indications on related or redundant instruments
3. By direct observation by plant personnel

Monitor indications are calculated based on the methodology of the site Offsite Dose Calculation Manual (ODCM). The HiHi alarm setpoints are set conservatively to indicate when a potential release may approach Technical Specification (ODCM) limits assuming multiple release points. Use of this conservative setpoint in establishing a monitor reading will not cause an inappropriate event classification since this EAL requires the magnitude of the monitor reading to be two hundred times the setpoint, sustained for >15 minutes, and assessment by a dose projection indicating an offsite dose rate in excess of two hundred times Technical Specification (ODCM) limits. In the unlikely event that a dose projection cannot be

completed within the 15 minute period, the event will be declared based on the sustained monitor reading.

Total Protective Action Recommendation Dose (TPARD) is equal to Total Effective Dose Equivalent (TEDE) + 4 Day Deposition Dose. Committed Dose Equivalent (CDE) is equal to the thyroid exposure due to iodine. The computerized dose model provides projected TPARD and CDE.

The Total Protective Action Recommendation Dose (TPARD) is calculated by dividing the yearly allowable Technical Specification limit (500 mRem/yr.) by the number of hours per year (8760 hr/yr.), and then multiplying by a factor of 200 times Technical Specifications [ODCM].

$$\begin{aligned}\text{TPARD} &= 200 \times (\text{Tech Spec Limit}) / (\text{hours per year}) \\ &= 200(500 \text{ mRem/yr.}) / (8760 \text{ hr/yr.}) \\ &= 11.4 \text{ mRem/hr}\end{aligned}$$

The Committed Dose Equivalent (CDE) is calculated by dividing the yearly allowable Technical Specification limit (1500 mRem/yr.) by the number of hours per year (8760 hr/yr.), and then multiplying by a factor of 200 times Technical Specifications [ODCM].

$$\begin{aligned}\text{CDE} &= 200 \times (\text{Tech Spec Limit}) / (\text{hours per year}) \\ &= 200(1500 \text{ mRem/yr.}) / (8760 \text{ hr/yr.}) \\ &= 34.2 \text{ mRem/hr}\end{aligned}$$

This event will be escalated to a Site Area Emergency when actual or projected doses are determined to exceed 10CFR20 annual average population exposure limits.

DEVIATION

None

REFERENCES

NUMARC NESP-007 AA1.1

Offsite Dose Calculation Manual

NUMARC Questions and Answers, June 1993, "Abnormal Rad Levels/Radiological Effluents #9"

5.0 Radioactivity Release

5.1 Effluent Release and Dose

ALERT - 5.1.2.b

IC Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment that Exceeds 200 Times Radiological Technical Specifications for 15 Minutes or Longer

EAL

Confirmed sample analyses for gaseous or liquid releases indicates concentrations or release rates exceeding **TWO HUNDRED TIMES** Tech Specs (ODCM 3.2.2 and 3.2.3) for **> 15 minutes**

OPCON ALL

BASIS

Releases in excess of two hundred times technical specifications that continue for > 15 minutes represent an uncontrolled situation and hence a potential degradation in the level of safety. The primary concern is the final integrated dose [100 times greater than the Unusual Event] and the degradation in plant control implied by the fact that the release was not isolated within 15 minutes.

It is not intended that the release be averaged over 15 minutes, but exceed two hundred times technical specifications limits for 15 minutes. Further, it is intended that the event be declared as soon as it is determined that the release will exceed two hundred times technical specifications for greater than 15 minutes.

An indication or report is considered to be valid when it is verified by:

1. An instrument channel check
2. Indications on related or redundant instruments
3. By direct observation by plant personnel

The calculation called for in this EAL should also be conducted whenever a liquid release occurs for which a radioactive discharge permit wasn't prepared or that exceeds the conditions on the permit (e.g. minimum dilution, alarm setpoints, etc).

This event will be escalated to higher classifications based on plant conditions.

DEVIATION

None

REFERENCES

NUMARC NESP-007 AA1.2
Offsite Dose Calculation Manual
T-104, Radioactivity Release Control

5.0 Radioactivity Release

5.1 Effluent Release and Dose

SITE AREA EMERGENCY - 5.1.3

IC Boundary Dose Resulting from an Actual or Imminent Release of Gaseous Radioactivity Exceeds 100 mR Whole Body or 500 mR Child Thyroid for the Actual or Projected Duration of the Release

EAL

A valid reading on one or more of the following radiation monitors that exceeds or is expected to exceed the value shown for **> 15 minutes** AND Dose Projections are not available:

North Stack	4.16E+6 $\mu\text{Ci}/\text{second}$
South Stack	2.25E-3 $\mu\text{Ci}/\text{cc}$

Note: If the required dose projections cannot be completed within the 15 minute period, then the declaration must be made based on the valid sustained monitor reading.

OR

Projected offsite dose using computer dose model exceeds **100 mRem TPARD** OR **500 mRem child thyroid CDE**

OR

Analysis of Field Survey results indicate site boundary whole body dose rate exceeds **100 mRem/hr** expected to continue for more than one hour, OR Analysis of Field Survey results indicate child thyroid dose commitment of **500 mRem** for one hour of inhalation

OPCON ALL

BASIS

Valid means that a radiation monitor reading has been confirmed by the operators to be correct.

A monitor reading is considered to be valid when it is verified by:

1. An instrument check indicating the monitor has not failed;
2. Indications on related or redundant instrumentation; or,
3. Direct observation by plant personnel.

Total Protective Action Recommendation Dose (TPARD) is equal to Total Effective Dose Equivalent (TEDE) + 4 Day Deposition Dose. Committed Dose Equivalent (CDE) is equal to the thyroid exposure due to iodine. The computerized dose model provides projected TPARD and CDE.

An actual or projected dose of 100 mrem Total Protective Action Recommendation Dose (TPARD) is based on the 10 CFR 20 annual average population exposure limit. This value also provides a desirable gradient (one order of magnitude) between the Site Area Emergency

and General Emergency classifications. The 500 mrem integrated child thyroid dose was established in consideration of the 1:5 ratio of the EPA Protective Action Guidelines for TPARD and Child Thyroid Committed Dose Equivalent (CDE). Actual meteorology is used, since it gives the most accurate dose projection.

Monitor indications are calculated using the computerized dose model with UFSAR source terms applicable to each monitored pathway in conjunction with annual average meteorology and a one hour release duration. The inputs are as follows:

	<u>North Stack</u>	<u>South Stack</u>
Stability Class	E	E
Wind Speed	6.2 mph	6.2 mph
Wind Direction	292°	292°
Accident	LOCA	LOCA
Release Rate	4.16E+6 μ Ci/sec	2.25E-3 μ Ci/cc

Child thyroid dose factors, rather than adult thyroid dose factors, are used for consistency with Pennsylvania Emergency Management Agency (PEMA) / Bureau of Radiation Protection (BRP).

This event will be escalated to a General Emergency when actual or projected doses exceed EPA Protective Action Guidelines per EAL Section 5.1.4.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AS1.1, AS1.3 and AS1.4
EPA 400

5.0 Radioactivity Release

5.1 Effluent Release and Dose

GENERAL EMERGENCY - 5.1.4

IC Boundary Dose Resulting from an Actual or Imminent Release of Gaseous Radioactivity that Exceeds 1000 mR Whole Body or 5000 mR Child Thyroid for the Actual or Projected Duration of the Release Using Actual Meteorology

EAL

A valid reading on one or more of the following radiation monitors that exceeds or is expected to exceed the value shown for **> 15 minutes** AND Dose Projections are not available:

North Stack	4.16E+7 $\mu\text{Ci}/\text{second}$
South Stack	2.25E-2 $\mu\text{Ci}/\text{cc}$

Note: If the required dose projections cannot be completed within the 15 minute period, then the declaration must be made based on the valid sustained monitor reading.

OR

Projected offsite dose using computer dose model exceeds **1000 mRem TPARD** OR **5000 mRem child thyroid CDE**

OR

Analysis of Field Survey results indicate site boundary whole body dose rate exceeds **1000 mRem/hr** expected to continue for more than one hour, OR Analysis of Field Survey results indicate child thyroid dose commitment of **5000 mRem** for one hour of inhalation

OPCON ALL

BASIS

Valid means that a radiation monitor reading has been confirmed by the operators to be correct.

A monitor reading is considered to be valid when it is verified by:

1. An instrument check indicating the monitor has not failed;
2. Indications on related or redundant instrumentation; or,
3. Direct observation by plant personnel.

Total Protective Action Recommendation Dose (TPARD) is equal to Total Effective Dose Equivalent (TEDE) + 4 Day Deposition Dose. Committed Dose Equivalent (CDE) is equal to the thyroid exposure due to iodine. The computerized dose model provides projected TPARD and CDE.

The 1000 mR TPARD and the 5000 mR child thyroid integrated dose are based on the EPA protective action guidance. This is consistent with the emergency class description for a General Emergency. This level constitutes the upper level of the desirable gradient for the

Site Area Emergency. Actual meteorology is specifically identified in the initiating condition since it gives the most accurate dose assessment.

Monitor indications are calculated using the computerized dose model with UFSAR source terms applicable to each monitored pathway in conjunction with annual average meteorology and a one hour release duration. The inputs are as follows:

	<u>North Stack</u>	<u>South Stack</u>
Stability Class	E	E
Wind Speed	6.2 mph	6.2 mph
Wind Direction	292°	292°
Accident	LOCA	LOCA
Release Rate	4.16E+7 μ Ci/sec	2.25E-2 μ Ci/cc

Child thyroid dose factors, rather than adult thyroid dose factors, are used for consistency with Pennsylvania Emergency Management Agency (PEMA) / Bureau of Radiation Protection (BRP).

DEVIATION

None

REFERENCES

NUMARC NESP-007, AG1.1, AG1.3 and AG1.4
EPA-400

5.0 Radioactivity Release

5.2 In-Plant Radiation

UNUSUAL EVENT - 5.2.1

IC Unexpected Increase in Plant Radiation or Airborne Concentration

EAL

Valid Direct Area Radiation Monitor readings increase by a factor of 1000 over normal* levels

- * Normal levels can be considered as the highest reading in the past twenty-four hours excluding the current peak value.

OPCON ALL

BASIS

Valid means that a radiation monitor reading has been confirmed by the operators to be correct.

An area monitor reading is considered to be valid when it is verified by:

1. an instrument channel check indicating the monitor has not failed;
2. indications on related or redundant instrumentation; or
3. direct observation by plant personnel

This EAL addresses unplanned increases in in-plant radiation levels that represent a degradation in the control of radioactive material, and represents a potential degradation in the level of safety of the plant.

This event will be escalated to an Alert when radiation levels increase in areas required for the safe shutdown of the plant resulting in impeded access.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AU2.4
T-103, Secondary Containment Control

5.0 Radioactivity Release

5.2 In-Plant Radiation

ALERT - 5.2.2.a

IC Release of Radioactive Material or Increases in Radiation Levels Within the Facility That Impedes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown

EAL

Valid radiation level readings **> 5000 mR/hr** in areas requiring infrequent access to maintain plant safety functions as identified in procedure SE-1, SE-6 or FSSG

AND

Access is required for safe plant operation, but is impeded, due to radiation dose rates

OPCON ALL

BASIS

Valid means that a radiation monitor reading has been confirmed by the operators to be correct.

An area monitor reading is considered to be valid when it is verified by:

1. An instrument check indicating the monitor has not failed;
2. Indications on related or redundant instrumentation; or,
3. Direct observation by plant personnel.

The single value of 5000 mR/hr was selected because it is based on radiation levels which result in exposure control measures intended to maintain doses within normal occupational exposure guidelines and limits (i.e., 10 CFR 20), and in doing so, will impede necessary access. Stay times for levels up to that value are, generally several minutes, enough time to enter an area and manually operate the equipment.

This EAL addresses increased radiation levels that impede necessary access to operating stations, or other areas containing equipment that must be operated manually, in order to maintain safe operation or perform a safe shutdown. These areas are identified in procedures SE-1, SE-6, and FSSG. Use of these procedures will indicate the need to access the areas. It is this impaired ability to operate the plant that results in the actual or potential substantial degradation of the level of safety of the plant. The cause and/or magnitude of the increase in radiation levels is not a concern of this IC. The Emergency Director must consider the source or cause of the increased radiation levels and determine if any other IC may be involved. For example, a dose rate of 15 mR/hr in the control room or high radiation monitor readings may also be indicative of high dose rates in the containment due to a LOCA. In this latter case, a SAE or GE may be indicated by the fission product barrier table.

This EAL could result in declaration of an Alert at one unit due to a radioactivity release or radiation shine resulting from a major accident at the other unit.

This EAL is not meant to apply to increases in drywell radiation monitors, as these are events which are addressed in the fission product barrier table. Nor is it intended to apply to anticipated temporary increases due to planned events (e.g., incore detector movement, radwaste container movement, depleted resin transfers, etc.)

This event will be escalated to a Site Area Emergency when loss of control of radioactive materials cause significant offsite doses.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA3.2
T-103, Secondary Containment Control
SE-1, Remote Shutdown
SE-6, Alternate Remote Shutdown

5.0 Radioactivity Release

5.2 In-Plant Radiation

ALERT - 5.2.2.b

IC Release of Radioactive Material or Increases in Radiation Levels Within the Facility That Impedes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown

EAL

Valid Control Room <u>OR</u> Central Alarm Station radiation reading > 15 mR/hr

OPCON ALL

BASIS

Valid means that a radiation monitor reading has been confirmed by the operators to be correct.

An area monitor reading is considered to be valid when it is verified by:

1. An instrument check indicating the monitor has not failed;
2. Indications on related or redundant instrumentation; or,
3. Direct observation by plant personnel.

The EAL address radiation levels which would impede operation of systems required to maintain safe operations or to establish or maintain cold shutdown. Radiation levels could be indicated by ARM or radiological survey.

Plant normal and emergency procedures may be implemented without requiring any areas except the Control Room and Central Alarm Station to be continuously occupied. The Radwaste Control Room is not required to be continuously occupied in order to maintain plant safety functions since inputs to radwaste will be isolated with a secondary containment isolation and releases can only be performed manually.

The value of 15 mR/hr is derived from the GDC 19 value of 5 REM in 30 days with adjustment for expected occupancy times. Although Section III.D.3 of NUREG-0737, "Clarification of TMI Action Plan Requirements", provides that the 15 mR/hr value can be averaged over the 30 days, the value is used here without averaging, as a 30 day duration implies an event potentially more significant than an Alert.

This event will be escalated to a Site Area Emergency when loss of control of radioactive materials cause significant offsite doses.

DEVIATION

None

REFERENCES

NUMARC NESP-007 AA3.1

This page intentionally left blank

6.0 Loss of Power

6.1 Loss of AC or DC Power

UNUSUAL EVENT - 6.1.1.a

IC Loss of All Offsite Power to Essential Busses for Greater Than 15 Minutes

EAL

The following conditions exist:

Loss of Power to 101 and 201 Safeguard Transformers for **>15 minutes**

AND

At least **Two** Diesel Generators are supplying power to their respective 4 KV emergency busses

OPCON ALL

BASIS

This EAL addresses the loss of offsite AC power supplying the station. Offsite power is fed through 101 and 201 Safeguard Transformers. Loss of offsite power will cause a reactor scram and a containment isolation. All four (4) emergency Diesel Generators will be available to carry the essential loads for each unit (the four Diesel Generators are shared between each unit). Balance of Plant systems that would assist in plant operations (i.e., condensate pumps, etc.) may be unavailable due the loss of power.

Prolonged loss of AC power reduces required redundancy and potentially degrades the level of safety of the plant by rendering the plant more vulnerable to a complete Loss of AC Power (Station Blackout). Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Escalation of this event to an Alert would be based on having a loss of all offsite AC power coincident with on-site AC power being reduced to a single power source in Modes 1, 2, and 3 or having a loss of all offsite and on-site AC power in Modes 4 or 5.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SU1
E-10/20, Loss of Offsite Power

6.0 Loss of Power

6.1 Loss of AC or DC Power

UNUSUAL EVENT - 6.1.1.b

IC Unplanned Loss of Required DC Power During Cold Shutdown or Refueling Mode for Greater than 15 Minutes

EAL

The following conditions exist:

Unplanned Loss of ALL safety related DC Power indicated by **< 105 VDC** bus voltage indications for DC Panels 1(2)FA, B, C, D

AND

Failure to restore power to at least one required DC bus within **15 minutes** from the time of the loss

OPCON 4, 5

BASIS

The purpose of this EAL is to recognize a loss of DC power compromising the ability to monitor and control the removal of decay heat during Cold Shutdown or Refueling operations. This EAL is intended to be anticipatory in as much as the operating crew may not have necessary indication and control of equipment needed to respond to the loss. The safety related 125 volt DC Distribution Panels are as follows:

1(2)FA, Division I Safeguard 125/250 DC Bus 1(2)FA
1(2)FB, Division II Safeguard 125/250 DC Bus 1(2)FB
1(2)FC, Division III Safeguard 125 DC Bus 1(2)FC
1(2)FD, Division IV Safeguard 125 DC Bus 1(2)FD

105 VDC bus voltage is based on the minimum bus voltage necessary for the operation of safety related equipment. This voltage value incorporates a margin of at least 15 minutes of operation before the onset of inability to operate those loads. This voltage is near the minimum voltage selected when battery sizing is performed.

Unplanned is included in this IC and EAL to preclude the declaration of an emergency as a result of planned maintenance activities. Routinely, plants will perform maintenance on a Train related basis during shutdown periods. It is intended that the loss of the operating (operable) train is to be considered. If this loss results in the inability to maintain cold shutdown, the escalation to an Alert will occur.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SU7

E-1FA, Loss of Division I Safeguard 125/250 DC Bus 1FA

E-1FB, Loss of Division II Safeguard 125/250 DC Bus 1FB

E-1FC, Loss of Division III Safeguard 125 DC Bus 1FC

E-1FD, Loss of Division IV Safeguard 125 DC Bus 1FD

6.0 Loss of Power

6.1 Loss of AC or DC Power

ALERT - 6.1.2.a

IC AC power capability to essential busses reduced to a single power source for greater than 15 minutes such that any additional single failure would result in station blackout

EAL

The following conditions exist:

Loss of Power to 101 and 201 Safeguard Transformers for **>15 minutes**

AND

Only **One** 4 KV emergency bus powered from a Single Onsite Power Source due to the Loss of: Three of Four Division Diesel Generators, D/G Output Breakers, or 4 KV Emergency Busses as indicated by bus voltage

OPCON 1, 2, 3

BASIS

This EAL is intended to provide an escalation from "Loss of offsite Power for greater than 15 minutes." This condition is a degradation of the offsite and onsite power systems such that any additional failure would result in a station blackout. Fifteen (15) minutes has been selected to exclude transient or momentary power losses. However, an Alert should be declared in less than 15 minutes if it can be determined in less than 15 minutes that the power loss is not transient or momentary.

Depending on the 4 KV AC bus that remains energized there is a disparity in the systems that may be available. The ability to remove heat from the containment via Suppression Pool cooling may be lost due to the need to operate the remaining available RHR pump in other than Suppression Pool cooling (e.g., LPCI). As such there is a decrease in the systems available to remove heat transferred to the containment and there is an ongoing release of energy from the reactor to the containment (via SRVs, HPCI and/or RCIC operation). The ability to cool the nuclear fuel, remove decay heat, and control containment parameters is severely limited. Should equipment be unavailable prior to the loss of power, functions necessary to maintain the plant in a cold shutdown condition may be threatened.

Escalation of this event would be based on the loss of the remaining Emergency Diesel Generator.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SA5
E-1, Loss of All AC Power (Station Blackout)

6.0 Loss of Power

6.1 Loss of AC or DC Power

ALERT - 6.1.2.b

IC Loss of All Offsite Power and Loss of All Onsite AC Power to Essential Busses During Cold Shutdown Or Refueling Mode

EAL

The following conditions exist:

Loss of Power to 101 and 201 Safeguard Transformers

AND

Failure to restore power to at least **One** 4 KV emergency bus **within 15 minutes** from the time of loss of both offsite and onsite AC power

OPCON 4, 5, D

BASIS

Loss of all AC power compromises all plant safety systems requiring electric power including RHR, ECCS, Containment Heat Removal, Spent Fuel Heat Removal and the Ultimate Heat Sink. When in cold shutdown, refueling, or defueled mode, the event can be classified as an Alert, because of the significantly reduced decay heat, lower temperature and pressure, increasing the time to restore one of the emergency busses, relative to that specified for the Site Area Emergency EAL. Escalating to Site Area Emergency, if appropriate, is be Effluent Release/In-Plant Radiation, or Emergency Director Judgement.

Fifteen (15) minutes has been selected to exclude transient or momentary power losses. However, an Alert should be declared in less than 15 minutes if it can be determined in less than 15 minutes that the power loss is not transient or momentary.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SA1
E-1, Loss of All AC Power (Station Blackout)

6.0 Loss of Power

6.1 Loss of AC or DC Power

SITE AREA EMERGENCY - 6.1.3.a

IC Loss of All Offsite Power and Loss of All Onsite AC Power to Essential Busses

EAL

The following conditions exist:

Loss of Power to 101 and 201 Safeguard Transformers

AND

Failure to restore power to at least **One** 4 KV emergency bus ***within 15 minutes*** from the time of loss of both offsite and onsite AC

OPCON 1, 2, 3

BASIS

Control Room annunciators would indicate that all offsite and onsite AC power feeds have been lost. Loss of all AC power compromises all plant safety systems requiring electric power including RHR, ECCS, Containment Heat Removal, Spent Fuel Heat Removal, RHR Service Water, and Emergency Service Water. Although instrumentation (supplied through instrument inverters) and DC power loads would be available, their operability would be limited to the amount of stored energy contained in their respective batteries. Instrumentation, communication equipment, and in-plant lighting and ventilation will be significantly hampered by the loss of all AC power.

Fifteen (15) minutes has been selected to exclude transient or momentary power losses. However, an Alert should be declared in less than 15 minutes if it can be determined in less than 15 minutes that the power loss is not transient or momentary.

Escalation of this event would be based on the time that the Emergency Diesel Generator are unavailable.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SS1
E-1, Loss of All AC Power (Station Blackout)

6.0 Loss of Power

6.1 Loss of AC or DC Power

SITE AREA EMERGENCY - 6.1.3.b

IC Loss of All Vital DC Power

EAL

Loss of ALL Safety Related DC Power indicated by **< 105 VDC** on DC Panels 1(2)FA, B, C, D
for **> 15 minutes**

OPCON 1, 2, 3

BASIS:

A loss of all DC power compromises the ability to monitor and control plant functions. 125 Volt DC system provides control power to engineered safety features valve actuation, diesel generator auxiliaries, plant alarm and indication circuits as well as the control power for the associated load group. If 125 Volt DC power is lost for an extended period of time (greater than 15 minutes) critical plant functions such as RPS Logic, Alternate Rod Insertion, Emergency Service Water Indication, 4KV Breaker Controls, HPCI, RCIC and RHR pump controls required to maintain safe plant conditions may not operate and core uncover with subsequent reactor coolant system and primary containment failure might occur. The 125 volt DC Main Distribution Panel Busses are as follows:

1(2)FA, Division I Safeguard 125/250 DC Bus 1(2)FA
1(2)FB, Division II Safeguard 125/250 DC Bus 1(2)FB
1(2)FC, Division III Safeguard 125 DC Bus 1(2)FC
1(2)FD, Division IV Safeguard 125 DC Bus 1(2)FD

Loss of all DC Power causes the loss of the following equipment:

- Alternate Rod Insertion
- HPCI
- Normal EDG Control
- Containment Instrument Gas Compressors
- Other 4KV Circuit Breakers (e.g., RHR, CS, CRD)
- ADS
- RCIC
- Normal Recirculation Pump Trip

Loss of ADS creates a loss of low pressure ECCS due to the inability to depressurize the reactor. In addition, loss of these buses will eventually lead to MSIV closure and reactor trip due to the loss of the Containment Instrument Gas Compressor as a result of suction valve closure. Subsequent to MSIV closure, much of the equipment noted above will be required for plant stabilization and shutdown.

A sustained loss of DC power will threaten the ability to remove heat from the reactor core, resulting in eventual fuel clad damage. The loss of DC power will also result in the loss of the ability to remove heat from the containment. SRVs will remain operable in the relief mode and

the heat addition to the containment could result in a loss of the primary containment as a fission product release barrier.

105 VDC bus voltage is based on the minimum bus voltage necessary for the operation of safety related equipment. This voltage value incorporates a margin of at least 15 minutes of operation before the onset of inability to operate those loads. This voltage is near the minimum voltage selected when battery sizing is performed.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SS3
T-101, RPV Control
T-102, Primary Containment Control
E-1, Loss of All AC Power (Station Blackout)

6.0 Loss of Power

6.1 Loss of AC or DC Power

GENERAL EMERGENCY - 6.1.4

IC Prolonged Loss of All Offsite Power and Prolonged Loss of All Onsite AC Power

EAL

Prolonged loss of all offsite and onsite AC power as indicated by:

Loss of Power to 101 and 201 Safeguard Transformers

AND

Failure of ALL Emergency Diesel Generators to supply power to 4 KV emergency busses

AND

At least one of the following conditions exist:

- Restoration of at least **One** 4 KV emergency bus within **2 hours** is **NOT** likely

OR

- Reactor Water Level cannot be maintained **> -161 "**

OR

- Suppression Pool temperature is on the **"UNSAFE"** side of the Heat Capacity Temperature Limit (HCTL) curve (T-102, SP/T-1)

OPCON 1, 2, 3

BASIS

When evaluating this EAL for Suppression Pool level outside of the Heat Capacity Temperature Limit Curve, High or Low, it is appropriate to consider the operation to be on the "UNSAFE" side.

Loss of all AC power compromises all plant safety systems requiring electric power including RHR, ECCS, Containment Heat Removal and the Ultimate Heat Sink. Prolonged loss of all AC power will lead to loss of fuel clad, RCS, and containment. The two hours to restore AC power is based on the site blackout coping analysis as described below. Although this IC may be viewed as redundant to the Fission Product Barrier Degradation IC, its inclusion is necessary to better assure timely recognition and emergency response.

10 CFR 50.2 defines Station Blackout (SBO) as complete loss of AC power to essential and non-essential buses. SBO does not include loss of AC Power to busses fed by station batteries through inverters, nor does it assume a concurrent single failure or design basis accident. Successful SBO coping maintains the following key parameters within given acceptable limits:

1. Reactor water level **> -161"** (TAF)
2. Suppression Pool level low enough to prevent HPCI and/or RCIC steam exhaust line flooding

3. Reactor pressure >150 psig to maintain HPCI and RCIC operable
4. Containment pressure < 62.5 psig, design limit
5. Suppression Pool temperature < 170 degrees F, HPCI/RCIC lube oil temperature concern when suction aligned to Suppression Pool
6. Drywell temperature
 - <200 degrees F indefinitely
 - <250 degrees F 99 days
 - <320 degrees F 18 hours
 - <340 degrees F 3 hours

Successful extended SBO coping depends on ability to keep HPCI/RCIC available for injection, and ability to maintain RPV depressurized for low pressure injection should HPCI and RCIC become unavailable. Control power for HPCI, RCIC and SRVs is provided by 125V DC. The parameters listed above can be maintained as long as the batteries are intact. Two hours is the earliest the batteries would fail, and thus is the basis for the time limit in this EAL.

The significance of a station blackout relative to the loss of fission product release barriers is that all three barriers will eventually be lost due to the inability to remove heat from the fuel and the containment. Although the RCS will be intact the longest, eventually SRVs will operate in the relief mode due to RPV over-pressurization and if the containment has already failed then there is a direct bypass of the RCS boundary.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SG1
E-1, Loss of All AC Power (Station Blackout)
T-101, RPV Control
T-102, Primary Containment Control
T-104, Radioactivity Release Control

7.0 Internal Events

7.1 Technical Specification & Control Room Evacuation

UNUSUAL EVENT - 7.1.1

IC Inability to Reach Required Shutdown Mode Within Technical Specification Limits

EAL

Inability to reach required shutdown mode within Tech. Spec. LCO required action completion time.

OPCON 1, 2, 3

BASIS

Limiting Conditions of Operation (LCOs) require the plant to be brought to a required shutdown mode when the Technical Specification required configuration cannot be restored. Depending on the circumstances, this may or may not be an emergency or precursor to a more severe condition. In any case, the initiation of plant shutdown required by the site Technical Specifications requires a one hour report under 10 CFR 50.72 (b) Non-emergency events. The plant is within its safety envelope when being shut down within the allowable action statement time in the Technical Specifications. An immediate Notification of an Unusual Event is required when it is determined that the plant cannot be brought to the required operating mode within the allowable action statement time in the Technical Specifications. Declaration of an Unusual Event is based on the time at which the LCO-specified action statement time period elapses under the site Technical Specifications and is not related to how long a condition may have existed. Other required Technical Specification shutdowns that involve precursors to more serious events are addressed by other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SU2
Technical Specifications

7.0 Internal Events

7.1 Technical Specification & Control Room Evacuation

ALERT - 7.1.2

IC Control Room Evacuation Has Been Initiated

EAL

Entry into SE-1 or SE-6 procedure for Control Room evacuation

OPCON ALL

BASIS

Control Room evacuation requires establishment of plant control from outside the control room (e.g., local control and remote shutdown panel) and support from the Technical Support Center and/or other emergency facilities as necessary. Control Room evacuation represents a serious plant situation since the level of control is not as complete as it would be without evacuation. The establishment of system control outside of the Control Room will bypass many protective trips and interlocks. In addition, much of the instrumentation and assessment tools available in the Control Room will not be available.

This event will be escalated to an Site Area Emergency if control cannot be established within fifteen minutes.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA5
SE-6, Alternate Remote Shutdown
SE-1, Remote Shutdown

7.0 Internal Events

7.1 Technical Specification & Control Room Evacuation

SITE AREA EMERGENCY - 7.1.3

IC Control Room Evacuation Has Been Initiated and Plant Control Cannot Be Established

EAL

The following conditions exist:

Control room evacuation has been initiated

AND

Control of the plant cannot be established per SE-1 or SE-6 within **15 minutes**

OPCON ALL

BASIS

Transfer of safety system control has not been performed in an expeditious manner but it is unknown if any damage has occurred to the fission product barriers. The 15 minute time limit for transfer of control is based on a reasonable time period for personnel to leave the control room, arrive at the remote shutdown area, and reestablish plant control to preclude core uncover and/or core damage. During this transitional period the function of monitoring and/or controlling parameters necessary for plant safety may not be occurring and as a result there may be a threat to plant safety.

This event will be escalated based upon system malfunctions or damage consequences.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HS2
SE-6, Alternate Remote Shutdown
SE-1, Remote Shutdown

7.0 Internal Events

7.2 Loss of Decay Heat Removal Capability

ALERT - 7.2.2

IC Inability to Maintain Plant in Cold Shutdown

EAL

The following conditions exist:

Unplanned Loss of ALL Tech Spec required systems available to provide Decay Heat Removal functions

AND

Uncontrolled Temperature increase that either:

- Exceeds **200 °F**
(Excluding a <15 minute rise >200° F with a heat removal function restored)

OR

- Results in temperature rise approaching **200 °F**
(with NO heat removal function restored)

OPCON 4, 5

BASIS

This EAL addresses complete loss of functions required for core cooling during refueling and cold shutdown modes. A loss of Technical Specifications components is paired with exceeding temperature limits to acknowledge additional plant capabilities to maintain plant cooling. Escalation to Site Area Emergency or General Emergency would be via Effluent Release/In-Plant Radiation or Emergency Director Judgement ICs.

The statement "Unplanned Loss of ALL Tech Spec required systems available to provide Decay Heat Removal functions" is intended to represent a complete loss of functions available, or an inadequate ability, to provide core cooling during the Cold Shutdown and Refueling Modes, including alternate decay heat removal methods. This EAL allows for actions taken in GP-6.2, "Shutdown Operations - Shutdown Condition Tech. Spec. Actions," to reestablish RHR in the Shutdown Cooling Mode or provide for alternate methods of decay heat removal, with the intent of maintaining RCS temperature below 200° F.

For loss of an in-service Decay Heat Removal system with other decay heat removal methods available, actions taken to provide for restoration of a decay heat removal function may require time to implement. If the event results in RCS temperature "momentarily" (for less than 15 minutes) rising above 200°F with heat removal capability restored, Emergency Director/Shift Management judgment will be required to determine whether heat removal systems are adequate to prevent boiling in the core and restoration of RCS temperature control. Momentary (not to exceed 15 minutes) unplanned excursions above 200° F, when alternate decay heat removal capabilities exist, should not be classified under this EAL.

"Uncontrolled" means that system temperature increase is not the result of planned actions by the plant staff.

The EAL guidance related to uncontrolled temperature rise is necessary to preserve the anticipatory philosophy of NUREG-0654 for events starting from temperatures much lower than the cold shutdown temperature limit.

This EAL is concerned with the ability to keep the reactor core temperature less than 200 °F. The criteria of uncontrolled Reactor Coolant temperature increase > 200 °F is met as soon as it becomes known that sufficient cooling cannot be restored in time to maintain the temperature < 200 °F, regardless of the current temperature. The inability to establish alternate methods of decay heat removal indicates that either alternate methods are unavailable to cool the core in the RPV or when the steam is transferred to the Suppression Pool, Suppression Pool cooling is unavailable. Loss of Suppression Pool cooling will result in a continuing, uncontrolled increase in reactor coolant temperature.

Special Test Exception 3.10.8 allows for temperature increases above 200 °F during hydrostatic testing. The limit of 200 °F in this EAL does not apply under those conditions as that is not an "Uncontrolled Temperature increase."

Escalation to the Site Area Emergency is by EAL IC, "Loss of Water Level in the Reactor Vessel that has or will uncover Fuel in the Reactor Vessel," or by Effluent Release/In-Plant Radiation ICs.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SA3
GP-6.2 , Shutdown Operations - Shutdown Conditions Tech. Spec. Actions
Technical Specifications

7.0 Internal Events

7.2 Loss of Decay Heat Removal Capability

SITE AREA EMERGENCY - 7.2.3

IC Complete Loss of Function Needed to Achieve or Maintain Hot Shutdown

EAL

Loss of SUPPRESSION POOL heat sink capabilities as evidenced by T-102 SP/T legs directing a T-112 Emergency Blowdown

OPCON 1, 2, 3

BASIS:

This EAL is concerned with Suppression Pool temperature. It is not appropriate to make a Site Area Emergency classification for the condition where the T-102 Suppression Pool Level leg alone directs a T-112 Emergency Blowdown since the Emergency Blowdown is performed PRIOR to those Suppression Pool levels which may cause a loss of containment capability due to uncovering downcomers of excessive SRV tailpipe stresses..

This EAL addresses complete loss of functions, including ultimate heat sink, required for hot shutdown with the reactor at pressure and temperature. Reactivity control is addressed in other EALs. The loss of heat removal function is indicated by T-102 SP/T legs requiring an Emergency Blowdown which is directed when the Heat Capacity Temperature Limit (HCTL) curve is exceeded.

Under these conditions, there is an actual major failure of a system intended for protection of the public. Thus, declaration of a Site Area Emergency is warranted. Escalation to General Emergency would be via Effluent Release/In-Plant Radiation, Emergency Director Judgement, or Fission Product Barrier Degradation ICs.

DEVIATION

None

REFERENCES

NEI 97-03, SS4
T-102, Primary Containment Control, SP/L-8

7.0 Internal Events

7.3 Loss of Assessment / Communication Capability

UNUSUAL EVENT - 7.3.1.a

IC Unplanned Loss of Most or All Safety System Annunciation or Indication in The Control Room for Greater Than 15 Minutes

EAL

Unplanned loss of most or all safety system annunciators (Table 7-1) OR indicators (Table 7-2) for > 15 minutes requiring increased surveillance to safely operate the unit(s).

OPCON 1, 2, 3

BASIS

This EAL recognizes the difficulty associated in monitoring conditions without normal annunciators. In the opinion of the Shift Supervisor this loss of annunciators requires increased surveillance to safely operate the plant. It is not intended that a detailed count of instrumentation be performed, but that only a rough approximation be used to determine the severity of the loss. The Plant Monitoring System (PMS) is available to provide compensatory indication. Fifteen minutes is used as a threshold to exclude transient or momentary power losses. Unplanned loss of annunciators excludes scheduled maintenance and testing activities. Control Room panels with annunciators and direction for response are included in ON-122, Loss of Main Control Room Annunciators.

Table 7-1 indicates those system annunciator panels considered to be safety related:

Table 7-1 Safety System Annunciators

ECCS
Containment Isolation
Reactor Trip
Process Radiation Monitoring

Table 7-2 indicates those indications important for monitoring:

Table 7-2 Safety Function Indicators

Reactor Power
Decay Heat Removal
Containment Safety Functions

Reportability of Technical Specification imposed shutdowns, or the inability to comply with Technical Specification action statements is covered in EAL section, Technical Specifications.

This EAL is not applicable in cold shutdown or refueling modes due to the limited number of safety systems required for operation.

This event will be escalated to an Alert if a transient is in progress or if compensatory indications become unavailable.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SU3
ON-122, Loss of Main Control Room Annunciators
AIT A0004447, EP Self Assessment on Salem Loss of Annunciators

7.0 Internal Events

7.3 Loss of Assessment / Communication Capability

UNUSUAL EVENT - 7.3.1.b

IC Unplanned Loss of All Onsite or Offsite Communications Capabilities

EAL

Loss of ALL Onsite communications (Table 7-3) affecting the ability to perform routine operations
OR
Loss of ALL Offsite communications (Table 7-3)

OPCON ALL

BASIS

This EAL recognizes a loss of communication ability that significantly degrades the plant operations staff's ability to perform tasks necessary for plant operations or the ability to communicate with offsite authorities. This EAL is separated into two groups of communications, Onsite and Offsite. A complete loss of either group is so severe, that the Unusual Event declaration is warranted. Table 7-3 is identified as follows:

Table 7-3 Communications

	Onsite	Offsite
Site Phones (Dimension 2000)	X	X
PRELUDE System	X	X
Plant Public Address	X	
Station Radio	X	
NRC (FTS-2000)		X
PA State Police Radio		X
County Police Radio		X
Load Dispatcher Radio		X
PECO Dial Network		X

DEVIATION

None

REFERENCES

NUMARC NESP-007, SU6
Nuclear Emergency Plan

7.0 Internal Events

7.3 Loss of Assessment / Communication Capability

ALERT - 7.3.2

IC Unplanned Loss of Most or All Safety System Annunciation or Indication In Control Room With Either (1) a Significant Transient in Progress, or (2) Compensatory Non-Alarming Indicators are Unavailable

EAL

Unplanned loss of most or all safety system annunciators (Table 7-1) OR indicators (Table 7-2) for > 15 minutes requiring increased surveillance to safely operate the unit(s)

AND EITHER

A significant plant transient is in progress (Table 7-4) OR the plant monitoring system (PMS) is unavailable.

OPCON 1, 2, 3

BASIS

This EAL recognizes the difficulty associated in monitoring conditions without normal annunciators. In the opinion of the Shift Supervisor this loss of annunciators requires increased surveillance to safely operate the plant. This EAL represents an increase in severity above 7.3.1.a in that the Plant Monitoring System (PMS) can not provide compensatory indication, or that a significant transient is in progress.

Table 7-1 indicates those system annunciator panels considered to be safety related:

Table 7-1 Safety System Annunciators

ECCS

Containment Isolation

Reactor Trip

Process Radiation Monitoring

Table 7-2 indicates those indications important for monitoring:

Table 7-2 Safety Function Indicators

Reactor Power

Decay Heat Removal

Containment Safety Functions

Table 7-4, significant plant transients include response to automatic or manually initiated actions including:

Table 7-4 Significant Plant Transients

SCRAM

Recirc runbacks > 25% thermal power
Sustained power oscillations 25% peak to peak
Stuck open relief valves
ECCS injection

Fifteen minutes is used as a threshold to exclude transient or momentary power losses. Control Room panels with annunciators and direction for restoration is included in ON-122, Loss of Main Control Room Annunciators.

Reportability of Technical Specification imposed shutdowns, or the inability to comply with Technical Specification action statements is covered in EAL section, Technical Specifications.

This EAL is not applicable in cold shutdown or refueling modes due to the limited number of safety systems required for operation.

This event will be escalated to a Site Area Emergency if a transient is in progress, the Plant Monitoring System is unavailable and a loss of annunciators occurs.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SA4
ON-122, Loss of Main Control Room Annunciators
T-101, Bases
BWROG EPG/SAG (RC/Q-6)

7.0 Internal Events

7.3 Loss of Assessment / Communication Capability

SITE AREA EMERGENCY - 7.3.3

IC Inability to Monitor a Significant Transient in Progress

EAL

Loss of safety system annunciators (Table 7-1)
AND indicators (Table 7-2)
AND PMS
AND a significant plant transient is in progress. (Table 7-4)

OPCON 1, 2, 3

BASIS

This EAL recognizes the difficulty associated in monitoring conditions without normal annunciators. In the opinion of the Shift Supervisor this loss of annunciators requires increased surveillance to safely operate the plant. This EAL represents an increase in severity above 7.3.2 in that the Plant Monitoring System can not provide compensatory indication, and that a significant transient is in progress.

Table 7-1 indicates those system annunciator panels considered to be safety related:

Table 7-1 Safety System Annunciators

ECCS
Containment Isolation
Reactor Trip
Process Radiation Monitoring

Table 7-2 indicates those indications important for monitoring:

Table 7-2 Safety Function Indicators

Reactor Power
Decay Heat Removal
Containment Safety Functions

Table 7-4 significant plant transients include response to automatic or manually initiated actions including:

Table 7-4 Significant Plant Transients

SCRAM
Recirc runbacks >25% thermal power change
Sustained power oscillations 25% peak to peak
Stuck open relief valves
ECCS injection

Planned maintenance or testing activities are included in this EAL due to the significance of this event. Control Room panels with annunciators and the restoration is included in ON-122, Loss of Main Control Room Annunciators.

DEVIATION

None

REFERENCES

NUMARC NESP-007, SS6
ON-122, Loss of Main Control Room Annunciators
T-101, Bases
BWROG EPG/SAG (RC/Q-6)

8.0 External Events

8.1 Security Events

UNUSUAL EVENT - 8.1.1

IC Confirmed Security Event Which Indicates a Potential Degradation in the Level of Safety of the Plant

EAL

Credible sabotage or bomb threat within the Protected Area
OR
Credible intrusion and attack threat to the Protected Area
OR
Attempted intrusion and attack to the Protected Area
OR
Attempted sabotage discovered within the Protected Area
OR
Hostage/Extortion situation that threatens normal plant operations

OPCON ALL

BASIS

A security threat that is identified as being directed towards the station and represents a potential degradation in the level of safety of the plant. A security threat is satisfied if physical evidence supporting the threat exists, if information independent from the actual threat exists, or if a specific group claims responsibility for the threat. The Shift Management will declare an Unusual Event subsequent to consulting with the on shift Security representative to determine the credibility of the security event.

Security threats which meet the threshold for declaration of an Unusual Event are:

1. Credible sabotage or bomb threat within the Protected Area
2. Credible intrusion and attack threat to the Protected Area
3. Attempted intrusion and attack to the Protected Area
4. Attempted sabotage discovered within the Protected Area
5. Hostage/Extortion situation that threatens normal plant operations

Security events which do not represent a potential degradation in the level of safety of the plant are reported under 10 CFR 73.71 or 10 CFR 50.72 and will not cause an Unusual Event to be declared.

This event will be escalated to an Alert based upon a hostile intrusion or act within the Protected Area.

DEVIATION

A bomb device discovered within Plant Protected Area and outside the Plant Vital Areas is an Alert declaration as determined per the site Safeguards Contingency Plan and therefore is not included as an Unusual Event in the EAL scheme.

REFERENCES

NUMARC NESP-007, HU4.1 and HU4.2
Safeguards Contingency Plan
Physical Security Plan

8.0 External Events

8.1 Security Events

ALERT - 8.1.2

IC Security Event in a Plant Protected Area

EAL

Intrusion into plant protected area by a hostile force

OR

Confirmed bomb, sabotage or sabotage device discovered in the Protected Area

OPCON ALL

BASIS

This class of security event represents an escalated threat to the level of safety of the plant. This event is satisfied if physical evidence supporting the hostile intrusion or attack exists. The Shift Management will declare an Alert subsequent to consulting with the on shift Security representative to determine the validity of the entry conditions.

Security threats which meet the threshold for declaration of an Alert are:

1. Intrusion into plant protected area by a hostile force
2. Confirmed bomb, sabotage or sabotage device discovered within the Protected Area

This event will be escalated to a Site Area Emergency based upon a hostile intrusion or act in plant Vital Areas.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA4.1 and HA4.2
Safeguards Contingency Plan
Physical Security Plan

8.0 External Events

8.1 Security Events

SITE AREA EMERGENCY - 8.1.3

IC Security Event in a Plant Vital Area

EAL

Intrusion into plant Vital area by a hostile force
OR
Confirmed bomb, sabotage or sabotage device discovered in a Vital Area

OPCON ALL

BASIS

This class of security event represents an escalated threat to plant safety above that contained in an Alert in that a hostile intrusion or attack has progressed from the Protected Area to a Vital Area. The Vital Areas are within the Protected Area and are generally controlled by key card readers. These areas contain vital equipment which includes any equipment, system, device or material, the failure, destruction or release of could directly or indirectly endanger the public health and safety by exposure to radiation. Equipment or systems which would be required to function to protect health and safety following such failure, destruction or release are also considered vital.

Security threats which meet the threshold for declaration of a Site Area Emergency are:

1. Intrusion into plant Vital area by a hostile force
2. Confirmed bomb, sabotage or sabotage device discovered in a Vital Area

This event will be escalated to a General Emergency based upon the loss of physical control of the Control Room or Remote Shutdown Capability

DEVIATION

None

REFERENCES

NUMARC NESP-007, HS1.1 and HS1.2
Safeguards Contingency Plan
Physical Security Plan

8.0 External Events

8.1 Security Events

GENERAL EMERGENCY - 8.1.4

IC Security Event Resulting in Loss of Ability to Reach and Maintain Cold Shutdown

EAL

Loss of physical control of the control room due to security event
OR
Loss of physical control of the remote shutdown capability due to security event

OPCON ALL

BASIS

This class of security event represents conditions under which a hostile force has taken physical control of areas required to reach and maintain cold shutdown. Loss of Remote Shutdown Capability would occur if the control function of the Remote Shutdown Panels was lost.

Security events which meet the threshold for declaration of a General Emergency are physical loss of the Control Room or the Remote and Alternate Shutdown Panels.

This situation leaves the plant in a very unstable condition with a high potential of multiple barrier failures.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HG1.1 and HG1.2
Safeguards Contingency Plan
Physical Security Plan

8.0 External Events

8.2 Fire / Explosion and Toxic / Flammable Gases

UNUSUAL EVENT - 8.2.1.a

IC Fire Within Protected Area Boundary Not Extinguished Within 15 Minutes of Detection

EAL

Fire within Plant Vital Structures (Table 8-1) which is not extinguished within **15 minutes** of control room notification or verification of a control room alarm

OPCON ALL

BASIS

The purpose of this IC is to address the magnitude and extent of fires that may be potentially significant precursors to damage to safety systems. This excludes such items as fires within administration buildings, waste-basket fires, and other small fires of no safety consequence. This IC applies to buildings and areas contiguous to plant vital areas or other significant buildings or areas. The intent of this IC is not to include buildings (e.g., warehouses) or areas that are not contiguous or immediately adjacent to plant vital areas. Verification of the alarm in this context means those actions taken in the control room to determine that the control room alarm is not spurious.

This EAL addresses fires in Plant Vital Structures that house safety systems. These fires may be precursors to damage to safety systems contained in these structures. There are no areas/buildings contiguous to Plant Vital Structures which could effect a safety system in one of the listed Plant Vital Structures except for those already on the list. Therefore, no additional areas/buildings are considered for this EAL. Verification that a fire exists is by operator actions to confirm that fire alarms received in the Control Room are not spurious or by any verbal notification by plant personnel. Fifteen minutes has been established to allow plant staff to respond and control small fires or to verify that no fire exists. Table 8-1 Plant Vital Structures are as follows:

Table 8-1 Plant Vital Structures

Reactor Enclosure
Control Enclosure
Turbine Enclosure
Diesel Generator Enclosure
Spray Pond Pump House/Spray Network

This event will be escalated to an Alert if the fire damages redundant trains of plant safety systems required for the current operating condition.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU2

8.0 External Events

8.2 Fire / Explosion and Toxic / Flammable Gases

UNUSUAL EVENT - 8.2.1.b

IC Release of Toxic or Flammable Gasses Deemed Detrimental to Safe Operation of the Plant

EAL

Report or detection of toxic or flammable gases that could enter within the site area boundary in amounts that can affect normal operation of the plant

OR

Report by Local, County or State Officials for potential evacuation of site personnel based on offsite event

OPCON ALL

BASIS

This EAL addresses toxic/flammable gas releases within the Protected Area in concentrations high enough to affect health of plant personnel or the safe operation of the plant. This includes releases that originate both onsite and offsite. A toxic/flammable gas is considered to be any substance that is dangerous to life or limb by reason of inhalation or skin contact. A gas release is considered to be impeding normal plant operations if concentrations are high enough to restrict normal operator movements. It also includes areas where access is only possible with respiratory equipment, as this equipment restricts normal visibility and mobility. It should not be construed to include confined spaces that must be ventilated prior to entry or situation involving the Fire Brigade who are using respiratory equipment during the performance of their duties unless it also affects personnel not involved with the Fire Brigade.

An offsite event (such as a tanker truck accident or train derailment releasing toxic gases) may place the Protected Area within the evacuation area. This evacuation is determined from the DOT Evacuation Tables for Selected Hazardous Materials in the North American Response Guidebook for Hazardous Materials.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU3.1 and HU3.2

8.0 External Events

8.2 Fire / Explosion and Toxic / Flammable Gases

UNUSUAL EVENT - 8.2.1.c

IC Natural and Destructive Phenomena Affecting the Protected Area

EAL

Report by plant personnel of an unanticipated explosion within protected area boundary resulting in visible damage to permanent structure or equipment

OPCON ALL

BASIS

The protected area boundary is typically that part within the security isolation zone and is defined in the site security plan.

Only those explosions of sufficient force to damage permanent structures or equipment within the protected area should be considered. As used here, an explosion is a rapid, violent, unconfined combustion, or a catastrophic failure of pressurized equipment, that potentially imparts significant energy to near-by structures and materials. No attempt is made in this EAL to assess the actual magnitude of the damage. The occurrence of the explosion with reports of evidence of damage (e.g., deformation, scorching) is sufficient for declaration. The Emergency Director also needs to consider any security aspects of the explosion, if applicable.

Any security aspects of this event should be considered under EAL Section 8.1, Security Events.

This event will be escalated to an Alert if the explosion damages one or more redundant trains of plant safety systems required for the current operating condition.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.5

8.0 External Events

8.2 Fire / Explosion and Toxic / Flammable Gases

ALERT - 8.2.2.a

IC Fire or Explosion Affecting the Operability of Plant Safety Systems Required to Establish or Maintain Safe Shutdown

EAL

The following conditions exist:

Fire or explosion which potentially makes inoperable:

Two or More subsystems of a Safe Shutdown System (Table 8-2) OR *Two or More* Safe Shutdown Systems OR Plant Vital Structures containing Safe Shutdown Equipment

AND

Safe Shutdown System or Plant Vital Structure is required for the present Operational Condition

OPCON ALL

BASIS

The primary concern of this EAL is the magnitude of the fire and the effects on Safe Shutdown Systems required for the present Operational Condition. A Safe Shutdown System is defined as any system required to maintain safe operation or to establish or maintain Cold Shutdown. A system being "inoperable" means that it is incapable of performing the design function. For example, the LPCI System is intended to maintain adequate core cooling by covering the core to at least 2/3 core height following a DBA LOCA. In order for the system to be unable to maintain its intended function, multiple loops would need to be disabled by the fire. In addition to indication of degraded system performance, potential inoperability may be determined by visual observation and other control room indications such as loss of indicating lights.

Table 8-2 Safe Shutdown Systems

Diesel Generators	4KV Safeguard Buses	ADS
HPCI	RCIC	RHR (All Modes)
Core Spray	RHR Service Water	ESW
SGTS	RERS	CAC
PCIS	Control Room Ventilation	

Safe Shutdown Analysis is consulted to determine systems required for the applicable mode.

Two examples of applying this methodology are as follows:

- Diesel Generators and 4 KV Safeguard Buses

The fire disables multiple Diesel Generators or 4 KV Safeguard Buses so that the number of emergency power systems available would be decreased to below what would be required to mitigate an accident under the current operating conditions. For 100% power, this could be conservatively interpreted as at least two Diesel Generators or 4 KV Buses disabled.

- RHR - LPCI Mode

The fire disables multiple loops of LPCI so that adequate core submergence could not be assured following a DBA LOCA. For 100% power, this could also be conservatively interpreted as at least two loops disabled.

The EAL includes the condition that the fire must make "TWO OR MORE" subsystems or "TWO OR MORE" systems inoperable. In those cases where it is believed that the fire may have caused damage to *Safety Systems*, then an Alert declaration is warranted, since the full extent of the damage may not be known. For Plant Vital Structure damage, classification is required under this EAL if the structure houses or otherwise supports *Safety Systems* required for the present Operational Condition.

Degraded system performance or observation of damage that could degrade system performance is used as the indicator that the safe shutdown system was actually affected or made inoperable. A report of damage should not be interpreted as mandating a lengthy damage assessment prior to classification. No attempt is made in this EAL to assess the actual magnitude of damage. The occurrence of the fire or explosion with reports of damage (e.g., deformation, scorching) is sufficient for declaration.

Fire is defined as combustion characterized by the generation of heat and smoke. Sources of smoke such as overheated electrical equipment and slipping drive belts, for example, do not constitute fires. Observation of a flame is preferred, but is NOT required if large quantities of smoke and heat are observed.

This event will be escalated to higher classifications based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA2
LGS Safe Shutdown Analysis
NUMARC Questions and Answers, June 1993, "Hazards Question #7"

8.0 External Events

8.2 Fire / Explosion and Toxic / Flammable Gases

ALERT - 8.2.2.b

IC Release of Toxic or Flammable Gases Within a Facility Structure Which Jeopardizes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown

EAL

Report or detection of toxic gases within Plant Vital Structures (Table 8-1) in concentrations that will be life threatening to plant personnel

OR

Report or detection of flammable gases within Plant Vital Structures (Table 8-1) in concentrations affecting the safe operation of the plant

OPCON ALL

BASIS

This EAL recognizes that toxic/flammable gases have entered Plant Vital Structures and are affecting safe operation of the plant by impeding operator access to the safety systems that must be operated manually in these structures. The cause and/or magnitude of the gas concentrations is not a concern, but rather that access is required to an area and is impeded. Plant Vital Structures that must be accessed are as follows:

Table 8-1 Plant Vital Structures

Reactor Enclosure
Control Enclosure
Turbine Enclosure
Diesel Generator Enclosure
Spray Pond Pump House/Spray Network

The intent of this IC is not to include buildings (e.g., warehouses) or other areas that are not contiguous or immediately adjacent to plant Vital Areas. It is appropriate that increased monitoring be done to ascertain whether consequential damage has occurred. This event will be escalated to higher classifications based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA3.1 and HA3.2

8.0 External Events

8.3 Man-Made Events

UNUSUAL EVENT - 8.3.1.a

IC Destructive Phenomena Affecting the Protected Area

EAL

Vehicle crash within protected area boundary that may potentially damage plant structures containing functions and systems required for safe shutdown of the plant.

OPCON ALL

BASIS

This EAL is intended to address such items as plane, helicopter, or train crash that may potentially damage plant structures containing functions and systems required for safe shutdown of the plant. If the crash is confirmed to affect a plant vital area, the event may be escalated to Alert.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.4

8.0 External Events

8.3 Man-Made Events

UNUSUAL EVENT - 8.3.1.b

IC Destructive Phenomena Affecting the Protected Area

EAL

Report of turbine failure resulting in casing penetration or damage to turbine or generator seals.
--

OPCON ALL

BASIS

This EAL is intended to address main turbine rotating component failures of sufficient magnitude to cause observable damage to the turbine casing or to the seals of the turbine generator. Of major concern is the potential for leakage of combustible fluids (e.g., lubricating oils) and gases (e.g., hydrogen) to the plant environs. Actual fires and flammable gas build up are appropriately classified via other EALs. This EAL is consistent with the definition of an Unusual Event while maintaining the anticipatory nature desired and recognizing the risk to non-safety related equipment. Escalation of the emergency classification is based on potential damage done by missiles generated by the failure or by the radiological releases and would be classified by the radiological ICs or Fission Product Barrier ICs.

Turbine failure of sufficient magnitude to cause observable damage to the turbine casing or seals of the turbine generator increases the potential for leakage of combustible fluids and gases (Hydrogen cooling) to the Turbine Enclosure. The damage should be readily observable and should not require equipment disassembly to locate.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.6

8.0 External Events

8.3 Man-Made Events

ALERT - 8.3.2

IC Destructive Phenomena Affecting the Plant Vital Area

EAL

Vehicle crash affecting Plant Vital Structures (Table 8-1)

OR

Turbine failure generated missiles result in any visible structural damage to or penetration of any Plant Vital Structures (Table 8-1)

OPCON ALL

BASIS

This EAL address crashes of vehicles or missile impacts that have caused damage to Plant Vital Structures, and thus damage may be assumed to have occurred to safe shutdown systems. No attempt should be made to assess the magnitude of damage to Plant Vital Structures prior to classification. The evidence of damage is sufficient for declaration. A vehicle crash includes aircraft and large motor vehicles, such as a crane. Missile impacts including flying objects from offsite, onsite rotating equipment or turbine failure causing casing penetration. Table 8-1 Plant Vital Structures are as follows:

Table 8-1 Plant Vital Structures

Reactor Enclosure
Control Enclosure
Turbine Enclosure
Diesel Generator Enclosure
Spray Pond Pump House/Spray Network

This event will be escalated to higher classifications based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA1.5 and HA1.6

8.0 External Events

8.4 Natural Events

UNUSUAL EVENT - 8.4.1.a

IC Natural and Destructive Phenomena Affecting the Protected Area

EAL

Earthquake $>.005\text{ g}$ as determined by procedure SE-5

OPCON ALL

BASIS

This EAL addresses a sensed earthquake. The magnitude of .005g is the lowest detectable earthquake measured on LGS seismic instrumentation per SE-5. An earthquake of this magnitude may be sufficient to cause minor damage to plant structures or equipment within the Protected Area. Damage is considered to be minor, as it would not affect physical or structural integrity. This event is not expected to affect the capabilities of plant safety functions.

This event will be escalated to an Alert if the earthquake reaches an Operating Basis Earthquake.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.1
SE-5, Earthquake
UFSAR, section 3.7.4.2.1

8.0 External Events

8.4 Natural Events

UNUSUAL EVENT - 8.4.1.b

IC Natural and Destructive Phenomena Affecting the Protected Area

EAL

Report by plant personnel of tornado striking within protected area

OR

Wind speeds > **75 mph** as indicated on site Meteorological data for > **15 minutes**

OPCON ALL

BASIS

A tornado touching down within the Protected Area or wind speeds > 75 mph within the owner controlled Area are of sufficient velocity to have the potential to cause damage to Plant Vital Structures. The value of 75 mph was selected to maintain consistency with plant value and to coincide with the Beaufort Scale for Hurricane wind speed winds of 73-136 mph. These conditions are indicative of unstable weather conditions and represent a potential degradation in the level of safety of the plant. Verification of a tornado will be by direct observation and reporting by station personnel. Verification of wind speeds > 75 mph will be via meteorological data in the control room.

This event will be escalated to an Alert if the tornado or high wind speeds strike Plant Vital Structures. If it is determined that the tornado or high wind speeds have caused a loss of shutdown cooling, then escalation will be by EAL IC, Loss of Decay Heat Removal Capability.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.2 and HU1.7

8.0 External Events

8.4 Natural Events

UNUSUAL EVENT - 8.4.1.c

IC Natural and Destructive Phenomena Affecting the Protected Area

EAL

Assessment by the control room that an event has occurred. (Natural and Destructive Phenomena Affecting the Protected Area)

OPCON ALL

BASIS

This EAL allows for the control room to determine that an event has occurred and take appropriate action based on personal assessment as opposed to verification (e.g., an earthquake is felt but does not register on any plant-specific instrumentation, etc.)

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU1.3

8.0 External Events

8.4 Natural Events

ALERT - 8.4.2.a

IC Natural and Destructive Phenomena Affecting the Plant Vital Area

EAL

Earthquake **>.075 g** (Operating Basis Earthquake OBE) as determined by procedure SE-5

OPCON ALL

BASIS

This EAL addresses an earthquake that exceeds the Operating Basis Earthquake level of .075g and is beyond design basis limits. An earthquake of this magnitude may be sufficient to cause damage to safety related systems and functions.

The Max Credible Earthquake for LGS is 0.15g per UFSAR section 3.7, therefore this EAL is conservative and warrants an Alert classification.

This event will be escalated to a higher emergency classification based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA1.1
SE-5, Earthquake
UFSAR section 3.7

8.0 External Events

8.4 Natural Events

ALERT - 8.4.2.b

IC Natural and Destructive Phenomena Affecting the Plant Vital Area

EAL

Tornado or wind speeds > 75 mph causing damage to Plant Vital Structures (Table 8-1)

OPCON ALL

BASIS

This EAL is based on FSAR design basis. Wind loads of this magnitude can cause damage to safety functions.

This EAL addresses events where Plant Vital Structures have been struck with high winds, and thus damage may have occurred to safe shutdown systems. No attempt should be made to assess the magnitude of damage to Plant Vital Structures prior to classification. Table 8-1 Plant Vital Structures are as follows:

Table 8-1 Plant Vital Structures

Reactor Enclosure
Control Enclosure
Turbine Enclosure
Diesel Generator Enclosure
Spray Pond Pump House/Spray Network

This event will be escalated to a higher emergency classification based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA1.2

8.0 External Events

8.4 Natural Events

ALERT - 8.4.2.c

IC Natural and Destructive Phenomena Affecting the Plant Vital Area

EAL

Report of any visible structural damage to any Plant Vital Structure (Table 8-1)
--

OPCON ALL

BASIS

The threshold value of this EAL should be determined relative to the damage that might occur from events described in EALs 8.4.2.a and 8.4.2.b.

This EAL specifies the Plant Vital Structures which contain systems and functions required for safe shutdown of the plant. Table 8-1 Plant Vital Structures are as follows:

Table 8-1 Plant Vital Structures

Reactor Enclosure
Control Enclosure
Turbine Enclosure
Diesel Generator Enclosure
Spray Pond Pump House/Spray Network

Other site structures listed in the NUMARC document are not plant vital structures and are not required for safe shutdown. Those are: Schuylkill River Pumphouse, RWST, CST.

This event will be escalated to a higher emergency classification based upon damage consequences covered under other various EAL Sections.

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA1.3

This page intentionally left blank

9.0 Other

9.1 General

UNUSUAL EVENT - 9.1.1

IC Other Conditions Existing Which in the Judgement of the Emergency Director Warrant Declaration of an Unusual Event

EAL

Other conditions exist which in the judgement of the Emergency Director indicate a potential degradation of the level of safety of the plant

OPCON ALL

BASIS

This EAL allows the Shift Management to declare an Unusual Event upon the determination that the level of safety of the plant has degraded. Where the degradation is associated with equipment or system malfunctions, the decision that it is degraded should be made upon functionality, not operability. A system, subsystem, train, component or device, though degraded in equipment condition or configuration, should be considered functional if it is capable of maintaining respective system parameters within acceptable design limits.

Releases of radioactive materials requiring offsite response or monitoring are not expected to occur at this level unless further degradation of safety systems occurs. However, if one does occur, it will be classified under "Radioactivity Releases."

DEVIATION

None

REFERENCES

NUMARC NESP-007, HU5

9.0 Other

9.1 General

ALERT - 9.1.2

IC Other Conditions Existing Which in the Judgement of the Emergency Director Warrant Declaration of an Alert

EAL

Other conditions exist which in the Judgement of the Emergency Director indicate that plant safety systems may be degraded and that increased monitoring of plant functions is warranted

OPCON ALL

BASIS

This EAL allows the Shift Management to declare an Alert upon the determination that the level of safety of the plant has substantially degraded but is not explicitly addressed by other EALs. This includes a determination by Shift Management that the TSC and OSC should be activated and command and control functions should be transferred for the event to be effectively mitigated. Transfer of command and control functions is used as an initiator since an event significant to warrant transfer is a substantial reduction in the level of safety of the plant. Other examples are:

Internal flooding affects the operability of plant safety systems required to establish or maintain cold shutdown.

Releases that are expected will be limited to a small fraction of the EPA Protective Action Guidelines and will be classified under "Radioactivity Releases."

DEVIATION

None

REFERENCES

NUMARC NESP-007, HA6

9.0 Other

9.1 General

SITE AREA EMERGENCY - 9.1.3

IC Other Conditions Existing Which in the Judgement of the Emergency Director Warrant Declaration of Site Area Emergency

EAL

Other conditions exist which in the Judgement of the Emergency Director indicate actual or likely major failures of plant functions needed for protection of the public

OPCON ALL

BASIS

This EAL allows the Shift Management to declare a Site Area Emergency upon the determination of an actual or likely major failure of plant functions needed for protection of the public, but is not explicitly addressed by other EALs.

Releases are not expected to result in exposure levels which exceed the EPA Protective Action Guidelines except within the site boundary and will be classified under "Radioactivity Releases."

DEVIATION

None

REFERENCES

NUMARC NESP-007, HS3

9.0 Other

9.1 General

GENERAL EMERGENCY - 9.1.4

IC Other Conditions Existing Which in the Judgement of the Emergency Director Warrant Declaration of General Emergency

EAL

Other conditions exist which in the Judgement of the Emergency Director indicate: (1) actual or imminent substantial core degradation with potential for loss of containment, or (2) potential for uncontrolled radionuclide releases. These releases can reasonably be expected to exceed EPA PAG plume exposure levels outside the site boundary

OPCON ALL

BASIS

This EAL allows the Shift Management to declare a General Emergency upon the determination of an actual or imminent substantial core degradation or melting with the potential for loss of containment integrity, but is not explicitly addressed by other EALs.

Releases may exceed the EPA Protective Action Guidelines for more than the immediate site area and will be classified under "Radioactivity Releases."

DEVIATION

None

REFERENCES

NUMARC NESP-007, HG2

ATTACHMENT 2

LIMERICK GENERATING STATION, UNITS 1 & 2

**Docket Nos. 50-352
50-353**

**License Nos. NPF-39
NPF-85**

EMERGENCY RESPONSE PROCEDURES

REPORT INDEX

PROCEDURE INDEX REPORT:

FAC	DOC TYPE	PROC TYPE	PROCEDURE NUMBER	CURR REV NBR	TITLE	EFFECTIVE DATE	RESP GROUP	SYSTEM NBR
LG	PROC	ERP	ERP-C-1000	0006	EMERGENCY OPERATIONS FACILITY (EOF) ACTIVATION/DEACTIVATION	06/25/01		
LG	PROC	ERP	ERP-C-1000-1	0004	EOF ACTIVATION CHECKLIST	06/25/01		
LG	PROC	ERP	ERP-C-1000-2	0003	EOF DEACTIVATION CHECKLIST	04/21/99		
LG	PROC	ERP	ERP-C-1000-3	0000	EOF BUSINESS HOURS FIRST RESPONDER CHECKLIST	04/21/99		
LG	PROC	ERP	ERP-C-1000-4	0000	EOF AFTER HOURS FIRST RESPONDER CHECKLIST	04/21/99		
LG	PROC	ERP	ERP-C-1000-5	0000	MINIMUM STAFFING POSITIONS NECESSARY TO ACTIVATE THE EOF	06/25/01		
LG	PROC	ERP	ERP-C-1100	0003	EOF STAFF AUGMENTATION INCORPORATED INTO ERP-C-1250	09/14/94		
LG	PROC	ERP	ERP-C-1200	0011	EMERGENCY RESPONSE MANAGER	06/25/01	LWE	
LG	PROC	ERP	ERP-C-1200-1	0000	EMERGENCY RESPONSE MANAGER TURNOVER/BRIEFING FORM	09/14/94		
LG	PROC	ERP	ERP-C-1200-2	0000	PROTECTIVE ACTION RECOMMENDATION WORKSHEET CANCELLED	10/24/95		
LG	PROC	ERP	ERP-C-1200-3	0000	ERM PAR DELIVERY CHECKLIST	04/03/00		
LG	PROC	ERP	ERP-C-1200-4	0000	MINIMUM STAFFING POSITIONS NECESSARY TO ACTIVATE THE EOF	03/30/01		
LG	PROC	ERP	ERP-C-1210	0002	ASSISTANT EMERGENCY RESPONSE MANAGER (AERM) CANCELLED	10/24/95		
LG	PROC	ERP	ERP-C-1250	0004	EMERGENCY PREPAREDNESS COORDINATOR/EOF	06/25/01		
LG	PROC	ERP	ERP-C-1250-1	0000	EMERGENCY POWER INSTRUCTIONS	09/14/94		
LG	PROC	ERP	ERP-C-1250-2	0002	EMERGENCY PREPAREDNESS COORDINATOR INSTRUCTIONS FOR ASPEN BACKUP NOTIFICATION SYSTEM	05/11/01		
LG	PROC	ERP	ERP-C-1250-3	0000	EMERGENCY PREPAREDNESS COORDINATOR INSTRUCTIONS TO STOP STAFFING	09/14/94		
LG	PROC	ERP	ERP-C-1250-4	0000	EMERGENCY PREPAREDNESS COORDINATOR INSTRUCTIONS FOR SYSTEM RESET	09/14/94		
LG	PROC	ERP	ERP-C-1300	0010	EMERGENCY OPERATIONS FACILITY (EOF) DOSE ASSESSMENT TEAM LEADER	08/29/00		
LG	PROC	ERP	ERP-C-1300-1	0004	DOSE ASSESSMENT TEAM LEADER (DATL) INITIAL ACTIONS	06/25/01		
LG	PROC	ERP	ERP-C-1300-2	0000	DOSE ASSESSMENT TURNOVER LIST	09/23/94		
LG	PROC	ERP	ERP-C-1300-3	0004	PROTECTIVE ACTION RECOMMENDATION WORKSHEET	03/30/01		
LG	PROC	ERP	ERP-C-1300-4	0000	OFFSITE SAMPLE ANALYSIS REQUESTS	09/23/94		
LG	PROC	ERP	ERP-C-1300-5	0001	DETERMINATION OF PROTECTIVE ACTION RECOMMENDATIONS (PARS)	11/02/98		
LG	PROC	ERP	ERP-C-1300-6	0002	DOSE ASSESSMENT GROUP MEMBER (DAGM) INITIAL ACTIONS	06/25/01		
LG	PROC	ERP	ERP-C-1300-7	0000	OBTAINING EPDS MET/RAD DATA	03/26/97		
LG	PROC	ERP	ERP-C-1300-8	0000	USE OF MODE A/MODE B CDM	03/26/97		
LG	PROC	ERP	ERP-C-1300-9	0001	OBTAINING MET DATA FROM NATIONAL WEATHER SERVICE	09/12/97		
LG	PROC	ERP	ERP-C-1310	0003	EMERGENCY OPERATIONS FACILITY (EOF) DOSE ASSESSMENT GROUP CANCELLED	03/26/97		
LG	PROC	ERP	ERP-C-1310-1	0000	DOSE ASSESSMENT GROUP LEADER INITIAL ACTIONS CANCELLED	03/26/97		
LG	PROC	ERP	ERP-C-1310-2	0000	OBTAINING MET DATA FROM NATIONAL WEATHER SERVICE CANCELLED	03/26/97		
LG	PROC	ERP	ERP-C-1310-3	0000	OBTAINING EPDS MET/RAD DATA CANCELLED	03/26/97		
LG	PROC	ERP	ERP-C-1310-4	0000	USE OF MODE A / MODE B OF CDM CANCELLED	03/26/97		
LG	PROC	ERP	ERP-C-1320	0007	EMERGENCY OPERATIONS FACILITY (EOF) FIELD SURVEY GROUP LEADER	08/29/00		
LG	PROC	ERP	ERP-C-1320-1	0002	FIELD SURVEY GROUP LEADER INITIAL ACTIONS	04/10/98		
LG	PROC	ERP	ERP-C-1320-2	0001	FIELD SURVEY GROUP LEADER TURNOVER SHEET	03/26/97		
LG	PROC	ERP	ERP-C-1320-3	0002	FIELD SURVEY GROUP LEADER DATA SHEET	08/29/00		
LG	PROC	ERP	ERP-C-1400	0005	ENGINEERING SUPPORT TEAM	06/25/01		

PROCEDURE INDEX REPORT:

FAC	DOC TYPE	PROC TYPE	PROCEDURE NUMBER	CURR REV NBR	TITLE	EFFECTIVE DATE	RESP GROUP	SYSTEM NBR
LG	PROC	ERP	ERP-C-1400-1	0002	ENGINEERING SUPPORT TEAM CHECKLIST	11/02/98		
LG	PROC	ERP	ERP-C-1410	0002	CORE DAMAGE ASSESSMENT	09/09/98		
LG	PROC	ERP	ERP-C-1410-1	0000	RADIOLOGICAL DATA	09/14/94		
LG	PROC	ERP	ERP-C-1410-2	0001	HYDROGEN CONCENTRATION DATA	09/09/98		
LG	PROC	ERP	ERP-C-1410-3	0001	CONTAINMENT RADIATION MONITOR DATA	09/09/98		
LG	PROC	ERP	ERP-C-1410-4	0000	METAL WATER REACTION CANCELLED	09/09/98		
LG	PROC	ERP	ERP-C-1410-5	0002	PERCENT OF FUEL INVENTORY AIRBORNE IN THE CONTAINMENT VS. APPROXIMATE SOURCE AND DAMAGE ESTIMATE	06/01/01		
LG	PROC	ERP	ERP-C-1410-6	0002	PROCEDURES FOR ESTIMATING FUEL DAMAGE BASED ON MEASURED I-131 AND XE-133 CONCENTRATIONS	06/25/01		
LG	PROC	ERP	ERP-C-1500	0006	LOGISTIC SUPPORT TEAM	04/14/00		
LG	PROC	ERP	ERP-C-1500-1	0001	MESSAGE AND INFORMATION INSTRUCTIONS	10/24/95		
LG	PROC	ERP	ERP-C-1500-2	0001	HELICOPTER LANDING INFORMATION	10/24/95		
LG	PROC	ERP	ERP-C-1900	0004	RECOVERY PHASE IMPLEMENTATION	11/02/98		
LG	PROC	ERP	ERP-C-1900-1	0000	RECOVERY PHASE IMPLEMENTATION FLOW CHART	06/28/93		
LG	PROC	ERP	ERP-C-1900-2	0002	PEACH BOTTOM ATOMIC POWER STATION RECOVERY ACCEPTANCE CHECKLIST	04/02/98		
LG	PROC	ERP	ERP-C-1900-3	0002	LIMERICK GENERATING STATION RECOVERY ACCEPTANCE CHECKLIST	04/02/98		
LG	PROC	ERP	ERP-C-1900-4	0002	RECOVERY PLAN OUTLINE	04/02/98		
LG	PROC	ERP	ERP-C-1900-5	0002	ASSESSMENT CONSIDERATIONS	12/28/99		
LG	PROC	ERP	ERP-101	0011	CLASSIFICATION OF EMERGENCIES	09/14/99	LWE	
LG	PROC	ERP	ERP-101 BASES	0002	LGS EAL TECHNICAL BASIS MANUAL	07/24/01		
LG	PROC	ERP	ERP-106	0003	WRITTEN SUMMARY NOTIFICATION	11/22/95	LWE	
LG	PROC	ERP	ERP-110	0033	EMERGENCY NOTIFICATION	06/12/01	LWE	
LG	PROC	ERP	ERP-120	0006	STATION EVACUATIONS	11/14/97	LWE	
LG	PROC	ERP	ERP-140	0009	STAFFING AUGMENTATION	02/03/98	LWE	
LG	PROC	ERP	ERP-200	0014	EMERGENCY DIRECTOR (ED) RESPONSE	03/27/01	LWE	
LG	PROC	ERP	ERP-200-1 APP	0011	EMERGENCY NOTIFICATION MESSAGE FORM	03/27/01	LWE	
LG	PROC	ERP	ERP-200-2 APP	0000	DOSE ASSESSMENT DATA SHEET	06/20/00		
LG	PROC	ERP	ERP-230	0014	OPERATIONS SUPPORT CENTER (OSC) DIRECTOR	04/14/00	LWE	
LG	PROC	ERP	ERP-230 APPENDIX 1	0000	OSC - EMERGENCY COMMUNICATIONS EQUIPMENT CHECK LIST	04/14/00		
LG	PROC	ERP	ERP-230 APPENDIX 2	0000	OSC DIRECTOR ACTIVATION CHECK-OFF LIST	04/14/00		
LG	PROC	ERP	ERP-230 APPENDIX 3	0000	OPERATIONS SUPPORT CENTER FACILITY ACCOUNTABILITY LOG	04/14/00		
LG	PROC	ERP	ERP-230 APPENDIX 4	0000	OSC DIRECTOR ACTIVATION	04/14/00		
LG	PROC	ERP	ERP-300	0022	TSC/MCR DOSE ASSESSMENT TEAM	04/03/00	LWE	
LG	PROC	ERP	ERP-300 APPENDIX 1	0000	DOSE ASSESSMENT TEAM ACTIVATION	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 2	0000	DOSE ASSESSMENT TEAM CHECK-OFF LIST	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 3	0001	TURNOVER OF DOSE ASSESSMENT RESPONSIBILITIES	06/19/00		
LG	PROC	ERP	ERP-300 APPENDIX 4	0000	DOSE ASSESSMENT DATA SHEET	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 5	0000	USE OF MESOREM, JR, AUTO MODE A	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 6	0000	OBTAINING RADIOLOGICAL DATA	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 7	0000	OBTAINING MET DATA FROM PLANT MONITORING SYSTEM (PMS)	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 8	0000	OBTAINING METEOROLOGICAL DATA FROM NATIONAL WEATHER SERVICE	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 9	0001	PROTECTIVE ACTION WORKSHEET	06/19/00		
LG	PROC	ERP	ERP-300 APPENDIX 10	0000	USE OF NORTH STACK DOSE RATE TO ESTIMATE RELEASE SOURCE TERM	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 11	0000	OPERATION OF IBM PS/2 MODEL L40SX	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 12	0000	LIMERICK LIQUID RELEASE DOSE CALCULATIONS	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 13	0000	DOSE ASSESSMENT SELF-CHECK	04/03/00		
LG	PROC	ERP	ERP-300 APPENDIX 14	0000	STABILITY CLASS DETERMINATION	04/03/00		
LG	PROC	ERP	ERP-316	0000	OPERATION OF THE DOSE ASSESSMENT COMPUTER (CM-4)	06/20/00		

LIMERICK GENERATING STATION

PROCEDURE INDEX REPORT:

FAC	DOC TYPE	PROC TYPE	PROCEDURE NUMBER	CURR REV NBR	TITLE	EFFECTIVE DATE	RESP GROUP	SYSTEM NBR
LG	PROC	ERP	ERP-326	0000	SHIFT DOSE ASSESSMENT PERSONNEL (SDAP)	06/20/00		
LG	PROC	ERP	ERP-330	0000	USE OF NORTH STACK-DOSE RATE TO ESTIMATE RELEASE SOURCE TERM CANCELLED INCORPORATED INTOERP-300 APP.10	11/14/94	LWE	
LG	PROC	ERP	ERP-340	0008	FIELD SURVEY GROUP	06/20/00	LWE	
LG	PROC	ERP	ERP-350	0003	RADIOACTIVE LIQUID RELEASE CANCELLED	11/10/94	LWE	
LG	PROC	ERP	ERP-360	0003	ADJUSTMENT OF WIDE RANGE GAS MONITOR CONVERSION FACTORS	10/18/99	LWE	
LG	PROC	ERP	ERP-370	0001	USE OF RMMS FOR DOSE ASSESSMENT CANCELLED	11/10/94	LWE	
LG	PROC	ERP	ERP-400	0013	CHEMISTRY SAMPLING AND ANALYSIS TEAM	07/24/01	LWE	
LG	PROC	ERP	ERP-410	0002	SAMPLE PREPARATION AND HANDLING OF HIGHLY RADIOACTIVE LIQUID SAMPLES	09/28/98	LWE	
LG	PROC	ERP	ERP-420	0002	SAMPLE PREPARATION AND HANDLING OF HIGHLY RADIOACTIVE PARTICULATE FILTERS AND IODINE CARTRIDGES	09/28/98	LWE	
LG	PROC	ERP	ERP-430	0002	SAMPLE PREPARATION AND HANDLING OF HIGHLY RADIOACTIVE GAS SAMPLES	09/28/98	LWE	
LG	PROC	ERP	ERP-440	0002	OFF-SITE ANALYSIS OF HIGH ACTIVITY SAMPLES	03/29/95	LWE	
LG	PROC	ERP	ERP-500	0016	SECURITY TEAM	04/14/00	LWE	
LG	PROC	ERP	ERP-500 APPENDIX 1	0000	SECURITY TEAM ACTIVATION	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 2	0000	SECURITY TEAM STAFFING GUIDELINES	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 3	0000	STAFFING FOR SITE EVACUATION	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 4	0000	SECURITY EVACUATION GUIDANCE	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 5	0000	SECURITY TEAM LEADER CHECK-OFF LIST	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 6	0000	EMERGENCY ASSEMBLY AREAS	04/14/00		
LG	PROC	ERP	ERP-500 APPENDIX 7	0000	FACILITY ACCOUNTABILITY LOG TECHNICAL SUPPORT CENTER	04/14/00		
LG	PROC	ERP	ERP-600	0012	HEALTH PHYSICS TEAM	05/19/98	LWE	
LG	PROC	ERP	ERP-620	0002	PLANT SURVEY GROUP CANCELLED - NO REPLACEMENT	05/02/95	LWE	
LG	PROC	ERP	ERP-630	0003	VEHICLE AND EVACUEE CONTROL GROUP	03/29/95	LWE	
LG	PROC	ERP	ERP-640	0008	EMERGENCY RESPONSE FACILITY HABITABILITY	04/17/99	LWE	
LG	PROC	ERP	ERP-650	0010	ENTRY FOR EMERGENCY REPAIR AND OPERATIONS	06/20/00	LWE	
LG	PROC	ERP	ERP-660	0006	DISTRIBUTION OF THYROID BLOCKING TABLETS	04/17/99	LWE	
LG	PROC	ERP	ERP-700	0016	TECHNICAL SUPPORT TEAM	02/15/01	LWE	
LG	PROC	ERP	ERP-800	0020	MAINTENANCE TEAM	12/15/00	LWE	
LG	PROC	ERP	ERP-800 APPENDIX 1	0000	TASK BRIEFING/DEBRIEFING SHEET	04/14/00		
LG	PROC	ERP	ERP-800 APPENDIX 2	0001	MAINTENANCE TEAM ACTIVATION	07/24/01		
LG	PROC	ERP	ERP-800 APPENDIX 3	0001	TECHNICAL SUPPORT CENTER ACTIVATION	12/15/00		
LG	PROC	ERP	ERP-800 APPENDIX 4	0001	OFFSITE SIRENS ACTIVATION (REF. 6.5.1)	12/15/00		

** END OF REPORT **