

C. This license shall be deemed to contain and is subject to all applicable provisions of the Act; to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- (1) NMC is authorized to operate the facility at steady-state reactor core power levels not in excess of 2530 Megawatts thermal (100 percent rated power) in accordance with the conditions specified herein.
- (2) The Technical Specifications contained in Appendix A, as revised through Amendment No. 202, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. NMC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
- (3) NMC shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report for the facility and as approved in the SERs dated 09/01/78, 03/19/80, 02/10/81, 05/26/83, 07/12/85, 01/29/86, 12/03/87, and 05/19/89 and subject to the following provisions:
 - a. NMC may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.
 - b. NMC may alter specific features of the approved fire protection program provided:
 - Such changes do not result in failure to complete the fire protection program as approved by the Commission. NMC shall maintain in auditable form, a current record of all such changes, including an analysis of the effects of the change on the fire protection program and shall make such records available to the Commission Inspectors upon request. All changes to the approved program shall be reported along with the FSAR revision as required by 10 CFR 50.71(e); and
 - Temporary changes to specific fire protection features which may be necessary to accomplish maintenance or modifications are acceptable provided interim compensatory measures are implemented.
- (4) Upon implementation of Amendment No. 189, the schedule for performance of new or revised surveillance requirements (SRs) shall be as follows:
 - For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval that begins on the date of implementation of this amendment.