



Entergy Nuclear Generation Company
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360

J. F. Alexander
Director
Nuclear Assessment

February 8, 2001
ENG C Ltr. 2.01.033

Tech. Spec. 5.6.4

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Docket No. 50.293
License No. DPR-35

FEBRUARY 2001 Monthly Operating Report

In accordance with Pilgrim Nuclear Power Station Technical Specification 5.6.4, the operational status summary for Pilgrim Nuclear Power Station is provided in the attachment for your information and planning. Should you have questions or comments concerning this report, please contact Jeff Rogers at (508) 830-8110.

Sincerely,

A handwritten signature in black ink, appearing to be "J.F. Alexander", is written over the printed name.

J.F. Alexander

JLR/

Attachment: February 2001 Monthly Operating Report

cc: Mr. Hubert Miller
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector

IE24

Rec'd DCB
8/2/01

OPERATING DATA REPORT

DOCKET NO. 50-293
 NAME: Pilgrim
 COMPLETED BY: J.L. ROGERS
 TELEPHONE: 1-508-830-8110
 REPORT MONTH: February 2001

OPERATING STATUS**NOTES**

- | | |
|---|---------------|
| 1. Unit Name | PILGRIM I |
| 2. Reporting Period | February 2001 |
| 3. Licensed Thermal Power (MWt) | 1998 |
| 4. Nameplate Rating (Gross MWe) | 678 |
| 5. Design Electrical Rating (Net MWe) | 655 |
| 6. Maximum Dependable Capacity (Gross MWe) | 696 |
| 7. Maximum Dependable Capacity (Net MWe) | 670 |
| 8. If Changes Occurred in Capacity Ratings (Items 3 through 7) Since Last Report, Give Reasons: | No Changes |
| 9. Power Level to Which Restricted, If Any (Net MWE) | <u>None</u> |
| 10. Reasons For Restrictions, If Any: | <u>N/A</u> |

	<u>THIS MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
11. Hours in Reporting Period	672.0	1,416.0	247,416.0
12. Hours Reactor Critical	672.0	1,416.0	167,919.6
13. Hours Reactor Reserve Shutdown	0.0	0.0	0.0
14. Hours Generator on Line	672.0	1,416.0	162,785.8
15. Hours Unit Reserve Shutdown	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,334,877.6	2,793,979.2	295,576,560.5
17. Gross Electrical Energy Generated (MWH)	467,710.0	978,700.0	100,567,664.0
18. Net Electrical Energy Generated (MWH)	449,547.1	940,684.5	96,703,074.3
19. Unit Service Factor	100.0	100.0	65.8
20. Unit Availability Factor	100.0	100.0	65.8
21. Unit Capacity Factor (Using MDC Net)	99.8	99.2	58.3
22. Unit Capacity Factor (Using DER Net)	102.1	101.4	59.7
23. Unit Forced Outage Rate	0.0	0.0	10.1
24. Shutdowns, Scheduled Outages Over Next 6 Months (Type,Date,Duration)			
Refuel Outage #13 scheduled to start April 14, 2001 and expected to last 35 days			
25. If Shutdown at End of Report Period,			
Estimated Date of Start-Up:	<u>Unit Operating</u>		

DOCKET NO. 50-293
 NAME: Pilgrim
 COMPLETED BY: J.L. Rogers
 TELEPHONE: (508) 830-8110
 REPORT MONTH: FEBRUARY 2001

OPERATIONAL SUMMARY

The plant entered the reporting period at 100 percent core thermal power (CTP) where it was essentially maintained for the entire month.

UNIT SHUTDOWNS

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	CAUSE/CORRECTIVE ACTION/COMMENTS

1

F - Forced
S - Scheduled

2

A - Equip Failure
 B - Main or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training &
 License Examination
 F - Admin
 G - Operation Error
 H - Other

3

1 - Manual
 2 - Manual Scram
 3 - Auto Scram
 4 - Continuation
 5 - Other